

August 15, 2006

Mr. Charles D. Naslund  
Senior Vice President and Chief Nuclear Officer  
Union Electric Company  
Post Office Box 620  
Fulton, MO 65251

SUBJECT: CALLAWAY PLANT, UNIT 1 - WITHDRAWAL OF EXIGENT AMENDMENT  
REQUEST TO REMOVE THE CONDENSATE MONITORING SYSTEM FROM  
THE TECHNICAL SPECIFICATIONS (TAC NO. MD2620)

Dear Mr. Naslund:

By letter dated July 19, 2006 (ULNRC-05314), Union Electric Company (the licensee) submitted an exigent license amendment request to remove the containment condensate monitoring system and atmosphere gaseous radioactivity monitor from Technical Specification (TS) 3.4.15, "RCS [reactor coolant system] Leakage Detection Instrumentation." The licensee stated that it was uncertain that the containment cooler condensate system could detect an RCS leak rate of 1 gallon per minute in 1 hour, which is the requirement for the instrumentation listed in TS 3.4.15 to be considered operable, and the condensate monitoring system was declared inoperable on July 10, 2006. With the containment atmosphere gaseous radioactivity monitor already declared inoperable and the condensate monitoring system now being inoperable, TS 3.4.15 required the licensee to shut down the Callaway Plant within 30 days of July 10, 2006, if the condensate monitoring could not be made operable. The exigent amendment request was to prevent the plant shutdown. The licensee also stated that the previous application dated August 26, 2005 (ULNRC-05197), as supplemented by letters dated December 16, 2005 (ULNRC-05242), and June 29, 2006 (ULNRC-05307), to revise TS 3.4.15 were superseded by the letter dated July 19, 2006. The licensee and the Nuclear Regulatory Commission (NRC) staff had conference calls on July 20 and 25, and August 2, 2006, to discuss the exigent amendment request.

In its letter dated August 7, 2006 (ULNRC-05321), the licensee withdrew its exigent license amendment request dated July 19, 2006, and re-instated the previous application dated August 26, 2005, and the supplemental letters. The containment condensate monitoring system was declared operable on August 3, 2006, and TS 3.4.15 did not require a plant shutdown.

This letter acknowledges that the application dated July 19, 2006, has been withdrawn, the NRC staff's review of this application has been closed, and the NRC staff's review of the

C. Naslund

- 2 -

application dated August 26, 2005, will continue. The enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License will be filed with the Office of the Federal Register for publication.

Sincerely,

***/RA/***

Jack Donohew, Senior Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Notice of Withdrawal

cc w/encl: See next page

application dated August 26, 2005, will continue. The enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License will be filed with the Office of the Federal Register for publication.

Sincerely,

**/RA/**

Jack Donohew, Senior Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

LPLIV Reading

RidsNrrDorl (CHaney/CHolden)

RidsNrrDorlLpl4 (DTerao)

RidsNrrPMJDonohew

RidsNrrLALFeizollahi

RidsOgcRp

RidsAcrsAcnwMailCenter

RidsRegion4MailCenter (BJones)

RidsNrrDirsltsb

JSegala, DSS

TKobetz, DIRS

RidsNrrDorlDpr

RHernandez, DSS  
CLi, DSS

**ACCESSION NO.: ML062290015**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	JDonohew	LFeizollahi	DTerao
DATE	8/9/06	8/9/06	8/15/06

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSIONUNION ELECTRIC COMPANYDOCKET NO. 50-483NOTICE OF WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission/NRC) has granted the request of Union Electric Company (the licensee) to withdraw its application dated July 19, 2006, for the proposed exigent amendment to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1, located in Callaway County, Missouri

By letter dated July 19, 2006, Union Electric Company (the licensee) submitted an exigent license amendment request to remove the containment condensate monitoring system and atmosphere gaseous radioactivity monitor from Technical Specification (TS) 3.4.15, "RCS [reactor coolant system] Leakage Detection Instrumentation." The licensee stated that it was uncertain that the containment cooler condensate system could detect an RCS leak rate of 1 gallon per minute in 1 hour, which is the requirement for the instrumentation listed in TS 3.4.15 to be considered operable, and the condensate monitoring system was declared inoperable on July 10, 2006. With the containment atmosphere gaseous radioactivity monitor already declared inoperable and the condensate monitoring system now being inoperable, TS 3.4.15 required the licensee to shut down the Callaway Plant within 30 days of July 10, 2006, if the condensate monitoring could not be made operable. The exigent amendment request was to prevent a plant shutdown. The licensee also stated that the previous application dated August 26, 2005, as supplemented by letters dated December 16, 2005, and June 29, 2006, to revise TS 3.4.15 were superseded by the letter dated July 19, 2006.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on July 25, 2006 (71 FR 42134).

However, by letter dated August 7, 2006, the licensee withdrew its exigent license amendment request dated July 19, 2006, and re-instated the previous application dated August 26, 2005, and the supplemental letters. The licensee declared the containment condensate monitoring system operable on August 3, 2006, and TS 3.4.15 no longer required a plant shutdown.

For further details with respect to this action, see the application for amendment dated July 19, 2006, and the licensee's letter dated August 7, 2006, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site,

<http://www.nrc.gov/NRC/ADAMS/index/html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by email to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 15th day of August 2006.

FOR THE NUCLEAR REGULATORY COMMISSION

**/RA/**

Jack N. Donohew, Senior Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Callaway Plant, Unit 1

cc:

Professional Nuclear Consulting, Inc.  
19041 Raines Drive  
Derwood, MD 20855

John O'Neill, Esq.  
Pillsbury Winthrop Shaw Pittman LLP  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. Keith A. Mills, Supervising Engineer  
Regional Regulatory Affairs/Safety Analysis  
AmerenUE  
P.O. Box 620  
Fulton, MO 65251

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
8201 NRC Road  
Steedman, MO 65077-1302

Mr. Les H. Kanuckel  
Manager, Quality Assurance  
AmerenUE  
P.O. Box 620  
Fulton, MO 65251

Missouri Public Service Commission  
Governor Office Building  
200 Madison Street  
Jefferson City, MO 65102-0360

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Mr. H. Floyd Gilzow  
Deputy Director for Policy  
Missouri Department of Natural Resources  
P. O. Box 176  
Jefferson City, MO 65102-0176

Mr. Rick A. Muench  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, KA 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition for the  
Environment  
6267 Delmar Boulevard  
University City, MO 63130

Mr. Lee Fritz, Presiding Commissioner  
Callaway County Court House  
10 East Fifth Street  
Fulton, MO 65151

Mr. David E. Shafer  
Superintendent, Licensing  
Regulatory Affairs  
AmerenUE  
P.O. Box 66149, MC 470  
St. Louis, MO 63166-6149

Mr. Keith D. Young  
Manager, Regulatory Affairs  
AmerenUE  
P.O. Box 620  
Fulton, MO 65251

Mr. Keith G. Henke, Planner  
Division of Community and Public Health  
Office of Emergency Coordination  
930 Wildwood P.O. Box 570  
Jefferson City, MO 65102

Certrec Corporation  
4200 South Hulen, Suite 630  
Fort Worth, TX 76109

Director, Missouri State Emergency  
Management Agency  
P.O. Box 116  
Jefferson City, MO 65102-0116