

CGTINKLER

~~Official Use Only~~

SANDIA REPORT

Revision 0


**Evaluation of Spent Fuel Pool Accident Response
to a Complete Loss-of-Coolant Inventory
Using MELCOR 1.8.5**

Completed: January 2003

Prepared by
K.C. Wagner
R.O. Gauntt
M.T. Leonard

Sandia National Laboratories
P.O. Box 5800
Albuquerque, NM 87185-0748

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 5 & 2
FOIA- 2004-0226

~~Ex ~~entirely~~~~ 

~~Official Use Only~~

Table of Contents

Table of Contents.....	ii
List of Tables.....	ii
List of Figures	iii
1. INTRODUCTION	1
1.1 Complete Loss-of-Coolant Accident	1
1.2 Partial Loss-of-Coolant Accident	2
1.3 Background and Scope	5
1.4 Scope of Present Analysis.....	5
2. ANALYSIS METHODOLOGY	6
2.1 Description of the Spent Pool	6
2.2 Accident Timing Selection	10
2.3 Decay Heat Calculations.....	10
2.4 Summary of the Scenario Specification.....	11
2.5 MELCOR Whole Pool Model	14
2.5.1 Summary of Other MELCOR Modeling Assumptions	20
3. SFP LOSS-OF-COOLANT INVENTORY RESPONSE.....	25
4. DISCUSSION OF UNCERTAINTIES	34
4.1 Thermal Radiative Connectivity.....	35
4.2 Radial Flow Resistance.....	37

List of Tables

Table 1. Spent Fuel Pool Data.....	8	
Table 2. Fuel Assembly Data.....	8	
Table 3. Spent Fuel Pool Rack Data.....	8	
Table 4. Summary of the SFP Assembly Decay Heat Level by the Year Discharged..	11	
Table 5. -] Ex. 2
Table 6. Summary of SFP Model Modeling Parameters.....	23	
Table 7. Summary of SFP Model MELCOR Sensitivity Coefficients.....	24	
Table 8. -] Ex. 2
	33	
Table 9. Sequence of Events for the Base Case Calculation.....	34	

List of Figures

Figure 1.1	SFP Gas Temperature Profile with Velocity Vectors Showing Bernoulli Effect from a Loss-of-Coolant Study.	4
Figure 2.1	Spent Fuel Pool Rack Layout.	7
Figure 2.2	Typical Spent Fuel Pool Rack Cross-section.	9

Ex. 2

Figure 2.5.	9x9 BWR Fuel Assembly.	17
Figure 2.6.	MELCOR Nodalization of SFP.	19
Figure 2.7.	MELCOR Reactor Building Nodalization.	21

Ex. 2

Figure 3.1	SFP Collapsed Water Level Response.	27
------------	--	----

Ex. 2

Ex.
2

Evaluation of Spent Fuel Pool Accident Response to a Complete Loss-of-Coolant Inventory Using MELCOR 1.8.5

1. INTRODUCTION

In 2001, NRC staff performed an evaluation of the potential accident risk in a spent fuel pool at decommissioning plants in the United States [Ref. 1]. The study was prepared to provide a technical basis for decommissioning rulemaking for permanently shutdown nuclear power plants. The study described a modeling approach of a typical decommissioning plant with design assumptions and industry commitments; the thermal-hydraulic analyses performed to evaluate spent fuel stored in the spent fuel pool at decommissioning plants; the risk assessment of spent fuel pool accidents; the consequence calculations; and the sensitivity study and implications for decommissioning regulatory requirements. It was known that some of the assumptions in the accident progression in Reference [1] were necessarily conservative, especially the estimation of the fuel damage. The present study continues on this work by using the best-estimate severe accident code MELCOR [Ref. 5] to predict a postulated severe accident progression following complete loss-of-coolant inventory in the spent fuel pool of a representative operating reactor nuclear power plant.

Ex.
5

Ex.
5

Ex
5

1.3 Background and Scope

The NRC recently performed a computational fluid dynamics (CFD) analysis of a complete loss-of-coolant accident using the Fluent computer code. The study was intended to improve the state-of-art of in the analysis of the SFP accidents and address limitations found in other specialized SFP models (e.g., SHARP, SFUEL, and COBRA-SFS). In particular, the specialty SFP codes included simplifications concerning the fluid mixing above, around, and below the racks, limitations in the range of burn-up of the fuel, and limitations in the bulk building response. The NRC CFD study included a relatively comprehensive analysis of many modeling uncertainties including decay heat, outer wall heat transfer, ventilation rate, flow resistance, material conductivity, the hottest fuel location, etc. Among other findings, the study identified the minimum amount of time since the discharge of fuel, such that the fuel could be cooled by natural circulation and not engage in rapid exothermic oxidation reactions. In particular, best-estimate simulations suggest that the peak fuel temperature was less than 800 K with 26 months of decay time. However, the study assumed BWR fuel in a completely full (i.e., 4200 assemblies and no open spaces), high-density rack system. The scope of the analysis did not include partial water conditions or any severe accident degradation.

Ex. 5




Figure 2.2 Typical Spent Fuel Pool Rack Cross-section.

REFERENCES

1. Collins, T. E., and Hubbard, G., "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants," NUREG-1738, February, 2001.
2. US NRC, SECY-97-186, "Changes to the Financial Protection Requirements for Permanently Shutdown Nuclear Power Plants, 10CFR 50.54(w) and 10CFR 140.11."
3. Decay Heat Power in Light Water Reactors," American Nuclear Society Standard, ANSI/ANS 5.1-1994, Copyright 1995 by American Nuclear Society.
4. Wagner, KC, Dallman, R. J., and Annon, M.C., "Best-Estimate Evaluation Of Loss-Of-Coolant Inventory In A Nuclear Power Plant Spent Fuel Pool," *International Meeting on Best-Estimate Methods in Nuclear Installation Safety Analysis (BE-2000)*, Washington, DC, November, 2000.
5. R. O. Gauntt et al, "MELCOR Computer Code Manuals, Reference Manual, Version 1.8.5, Vol. 2, Rev. 2", Sandia National Laboratories, NUREG/CR-6119, SAND2000-2417/1.

Release