

~~OFFICIAL USE ONLY~~

SANDIA REPORT

Revision 0  
Draft

---

## Evaluation of a BWR Spent Fuel Pool Accident Response to Loss-of-Coolant Inventory Scenarios Using MELCOR 1.8.5

---

Draft Completed: October 2003

Prepared by  
KC Wagner\*  
R. O. Gauntt

Sandia National Laboratories  
P.O. Box 5800  
Albuquerque, NM 87185-0748

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 2 & 5  
FOIA- 2004-0226

\*Innovative Technology Solutions Corporation  
6000 Uptown Boulevard, NE Suite 300  
Albuquerque, NM 87110

~~OFFICIAL USE ONLY~~

Portions withheld -  
Ex. 2 & Ex. 5

## EXECUTIVE SUMMARY

In 2001, United States Nuclear Regulatory Commission (NRC) staff performed an evaluation of the potential accident risk in a spent fuel pool (SFP) at decommissioning plants [NUREG-1738]. The study was prepared to provide a technical basis for decommissioning rulemaking for permanently shutdown nuclear power plants. The study described a modeling approach of a typical decommissioning plant with design assumptions and industry commitments; the thermal-hydraulic analyses performed to evaluate spent fuel stored in the spent fuel pool at decommissioning plants; the risk assessment of spent fuel pool accidents; the consequence calculations; and the implications for decommissioning regulatory requirements. It was known that some of the assumptions in the accident progression in NUREG-1738 were necessarily conservative, especially the estimation of the fuel damage. Furthermore, the NRC desired to expand the study to include accidents in the spent fuel pools of operating power plants. Consequently, the NRC has continued spent fuel pool accident research by applying best-estimate computer codes to predict the severe accident progression following various postulated accident initiators. This report presents the results of a series of parametric calculations used to better understand the postulated accident behavior in SFPs.

The MELCOR 1.8.5 severe accident computer code [Gauntt] was used to simulate the SFP accident response. MELCOR includes fuel degradation models for BWR and PWR fuel, radiation, convection, and conduction heat transfer models, air and steam oxidation models, hydrogen burn models, two-phase thermal-hydraulic models, and fission product release and transport models. Hence, it contains the basic models to address phenomena expected during a spent fuel pool accident.

Consequently, MELCOR separate effect [Wagner, 2003] and computational fluid dynamics (CFD) [Chiffelle, 2003, Ross, 2003, and Suo-Anttila, 2003] calculations were performed to develop a modeling approach for whole SFP severe accident calculations. These studies gave insights that were incorporated into the present study.

Ex.  
5

Ex.  
5

Ex.  
5

## TABLE OF CONTENTS

1.	BACKGROUND .....	1
1.1	SFP Accident Scenarios .....	2
1.1.1	Complete Loss-of-Coolant Inventory Accident .....	2
1.1.2	Partial Loss-of-Coolant inventory accident .....	5
1.2	Report Structure .....	6
2.	SFP GEOMETRY .....	7
2.1	SFP Geometry .....	7
2.2	SFP Assembly Geometry .....	9
3.	ANALYSIS METHODOLOGY .....	11
3.1	Decay Heat Calculations .....	11
3.2	MELCOR Whole Pool Model .....	13
3.2.1	Decay Heat and Radial Coupling .....	13
3.2.2	SFP Assembly Models .....	19
3.2.3	Reactor Building Model .....	22
3.2.4	Summary of Other MELCOR Modeling Assumptions .....	22
3.3	Summary of the Scenario Specifications .....	29
3.3.1	Complete Loss-of-Coolant Inventory Accidents .....	29
3.3.2	Partial Loss-of-Coolant inventory accidents .....	30
4.	COMPLETE LOSS-OF-COOLANT INVENTORY RESPONSE .....	32
4.1		
4.2		
4.3		
4.4		
4.5		
4.6		
4.7		
4.8		
4.9		
4.10		

Ex  
5

5.	PARTIAL LOSS-OF-COOLANT INVENTORY RESPONSE .....	144
5.1		
5.2		
5.3		
5.4		
5.5		
5.6		
5.7		
5.8		
5.9		
5.10		
6.	REFERENCES.....	262

Ex 5

### Table of Tables

Table 2.1	Summary of SFP Attributes.....	9
Table 2.2	Spent Fuel Pool Rack Data.....	9
Table 2.3	Fuel Assembly Data. ....	10
Table 3.1	Summary of Regional Powers for SFP Calculations. ....	18
Table 3.2	Summary of MELCOR Modeling Parameters.....	26
Table 3.3	Summary of MELCOR Sensitivity Coefficients. ....	27
Table 3.4	Summary of Complete Loss-of-Coolant Inventory SFP Calculations....	30
Table 3.5	Summary of the Partial Loss-of-Coolant SFP Calculations.....	31
Table 4.1	Summary of Case C1 Specifications and Results.....	34
Table 4.2	Summary of Case C2 Specifications and Results.....	48
Table 4.3	Summary of Case C3 Specifications and Results.....	56
Table 4.4	Summary of Case C4 Specifications and Results.....	68
Table 4.5	Summary of Case C5 Specifications and Results.....	80
Table 4.6	Summary of Case C6 Specifications and Results.....	92
Table 4.7	Summary of Case C7 Specifications and Results.....	104
Table 4.8	Summary of Case C8 Specifications and Results.....	116
Table 4.9	Summary of Case C9 Specifications and Results.....	124
Table 4.10	Summary of Case C10 Specifications and Results.....	132

Table 5.1	Summary of Case P1 Specifications and Results. ....	145
Table 5.2	Summary of Case P2 Specifications and Results. ....	157
Table 5.3	Summary of Case P3 Specifications and Results. ....	169
Table 5.4	Summary of Case P4 Specifications and Results. ....	182
Table 5.5	Summary of Case P5 Specifications and Results. ....	194
Table 5.6	Summary of Case P6 Specifications and Results. ....	206
Table 5.7	Summary of Case P7 Specifications and Results. ....	218
Table 5.8	Summary of Case P8 Specifications and Results. ....	229
Table 5.9	Summary of Case P9 Specifications and Results. ....	240
Table 5.10	Summary of Case P10 Specifications and Results. ....	251

### Table of Figures

Figure 1.1.1	Reactor Building for a Boiling Water Reactor with the Spent Fuel Pool. 4	
Figure 1.1.2	Spent Fuel Pool Rack with BWR Assemblies. ....	5
Figure 2.1.1	Spent Fuel Pool Rack Layout. ....	8
Figure 3.1.1	SFP Assembly Decay Heat as a Function of Time. ....	12
Figure 3.2.1	Spent Fuel Location Colored by Year Discharged after the Last Discharge to the SFP. ....	16
Figure 3.2.2		
Figure 3.2.3		
Figure 3.2.4	9x9 BWR Fuel Assembly [Boyd]. ....	20
Figure 3.2.5	MELCOR Nodalization of SFP. ....	21
Figure 3.2.6	MELCOR Reactor Building Nodalization. ....	24
Figure 3.2.7		25
Figure 3.2.8	New Parabolic Reaction Kinetics for Zirconium-Air Oxidation. ....	28
Figure 4.1.1	SFP Collapsed Water Level Response. ....	37
Figure 4.1.2	Midplane Cladding Temperature in the Seven SFP Regions. ....	38
Figure 4.1.3		38
Figure 4.1.4		39
Figure 4.1.5		39
Figure 4.1.6		40
Figure 4.1.7		40
Figure 4.1.8		41
Figure 4.1.9		41
Figure 4.1.10	Total Fission Product Release Fraction from the Fuel. ....	42
Figure 4.1.11		42
Figure 4.1.12	Reactor Building Decontamination Factor. ....	43
Figure 4.1.13	RB Refueling Room Temperature Response. ....	43
Figure 4.1.14	Fuel Assembly Energy Balance. ....	44
Figure 4.1.15		44
Figure 4.1.16	Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....	45

Ex.  
5

Ex.  
2

Ex  
5

Ex 5

Ex 5

Figure 4.1.17	Average Assembly Oxygen Molar Fraction.....	45	
Figure 4.1.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	46	
Figure 4.1.19			Ex. 5
Figure 4.1.20			
	Rack Base Plate Elevation.....	47	
Figure 4.2.1	SFP Collapsed Water Level Response. ....	50	
Figure 4.2.2	Midplane Cladding Temperature in the Seven SFP Regions. ....	50	
Figure 4.2.3		51	Ex. 5
Figure 4.2.4		51	
Figure 4.2.5		52	
Figure 4.2.6		52	
Figure 4.2.7		53	
Figure 4.2.8		53	
Figure 4.2.9		54	
Figure 4.2.10	Total Fission Product Release Fraction from the Fuel.....	54	
Figure 4.2.11	RB Refueling Room Temperature Response.....	55	
Figure 4.2.12	Fuel Assembly Energy Balance.....	55	
Figure 4.3.1	SFP Collapsed Water Level Response. ....	58	
Figure 4.3.2		58	Ex. 5
Figure 4.3.3		59	
Figure 4.3.4		59	
Figure 4.3.5		60	Ex. 5
Figure 4.3.6		60	
Figure 4.3.7		61	
Figure 4.3.8		61	
Figure 4.3.9		62	
Figure 4.3.10	Total Fission Product Release Fraction from the Fuel.....	62	
Figure 4.3.11		63	Ex 5
Figure 4.3.12	Reactor Building Decontamination Factor.....	63	
Figure 4.3.13	RB Refueling Room Temperature Response.....	64	
Figure 4.3.14	Fuel Assembly Energy Balance.....	64	
Figure 4.3.15		65	Ex 5
Figure 4.3.16	Overall SFP Zirconium and Zirconium-Oxide Mass. ....	65	
Figure 4.3.17	Average Assembly Oxygen Molar Fraction.....	66	
Figure 4.3.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	66	
Figure 4.3.19			Ex. 5
Figure 4.3.20			
Figure 4.4.1	SFP Collapsed Water Level Response. ....	70	
Figure 4.4.2		70	Ex 5
Figure 4.4.3		71	
Figure 4.4.4		71	
Figure 4.4.5		72	

Figure 4.4.6	.....	72	Ex. 5
Figure 4.4.7	.....	73	
Figure 4.4.8	.....	73	
Figure 4.4.9	.....	74	
Figure 4.4.10	Total Fission Product Release Fraction from the Fuel.....	74	Ex 5
Figure 4.4.11	.....	75	
Figure 4.4.12	Reactor Building Decontamination Factor.....	75	Ex 5
Figure 4.4.13	RB Refueling Room Temperature Response.....	76	
Figure 4.4.14	Fuel Assembly Energy Balance.....	76	
Figure 4.4.15	.....	77	
Figure 4.4.16	Overall SFP Zirconium and Zirconium-Oxide Mass. ....	77	Ex 5
Figure 4.4.17	Average Assembly Oxygen Molar Fraction.....	78	
Figure 4.4.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	78	
Figure 4.4.19	.....		
Figure 4.4.20	.....		Ex 5
Figure 4.5.1	SFP Collapsed Water Level Response. ....	82	
Figure 4.5.2	.....	82	Ex 5
Figure 4.5.3	.....	83	
Figure 4.5.4	.....	83	
Figure 4.5.5	.....	84	
Figure 4.5.6	.....	84	Ex 5
Figure 4.5.7	.....	85	
Figure 4.5.8	.....	85	
Figure 4.5.9	.....	86	
Figure 4.5.10	Total Fission Product Release Fraction from the Fuel.....	86	Ex 5
Figure 4.5.11	.....	87	
Figure 4.5.12	Reactor Building Decontamination Factor.....	87	Ex 5
Figure 4.5.13	RB Refueling Room Temperature Response.....	88	
Figure 4.5.14	Fuel Assembly Energy Balance.....	88	
Figure 4.5.15	.....	89	
Figure 4.5.16	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....	89	Ex 5
Figure 4.5.17	Average Assembly Oxygen Molar Fraction.....	90	
Figure 4.5.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	90	
Figure 4.5.19	.....		
Figure 4.5.20	.....		Ex 5
Figure 4.6.1	SFP Collapsed Water Level Response. ....	94	
Figure 4.6.2	.....	94	Ex 5
Figure 4.6.3	.....	95	
Figure 4.6.4	.....	95	
Figure 4.6.5	.....	96	
Figure 4.6.6	.....	96	

Figure 4.6.7	.....	97	Ex 5
Figure 4.6.8	.....	97	
Figure 4.6.9	.....	98	
Figure 4.6.10	Total Fission Product Release Fraction from the Fuel.....	98	
Figure 4.6.11	.....	99	Ex 5
Figure 4.6.12	Reactor Building Decontamination Factor.....	99	
Figure 4.6.13	RB Refueling Room Temperature Response.....	100	Ex 5
Figure 4.6.14	Fuel Assembly Energy Balance.....	100	
Figure 4.6.15	.....	101	
Figure 4.6.16	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....	101	Ex 5
Figure 4.6.17	Average Assembly Oxygen Molar Fraction.....	102	
Figure 4.6.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation.....	102	
Figure 4.6.19			
Figure 4.6.20			Ex 5
Figure 4.7.1	SFP Collapsed Water Level Response.....	106	
Figure 4.7.2	.....	106	Ex 5
Figure 4.7.3	.....	107	
Figure 4.7.4	.....	107	
Figure 4.7.5	.....	108	
Figure 4.7.6	.....	108	
Figure 4.7.7	.....	109	
Figure 4.7.8	.....	109	
Figure 4.7.9	.....	110	
Figure 4.7.10	Total Fission Product Release Fraction from the Fuel.....	110	Ex 5
Figure 4.7.11	.....	111	
Figure 4.7.12	Reactor Building Decontamination Factor.....	111	
Figure 4.7.13	RB Refueling Room Temperature Response.....	112	
Figure 4.7.14	Fuel Assembly Energy Balance.....	112	Ex 5
Figure 4.7.15	.....	113	
Figure 4.7.16	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....	113	
Figure 4.7.17	Average Assembly Oxygen Molar Fraction.....	114	
Figure 4.7.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation.....	114	
Figure 4.7.19			Ex 5
Figure 4.7.20			
Figure 4.8.1	SFP Collapsed Water Level Response.....	118	Ex 5
Figure 4.8.2	.....	118	
Figure 4.8.3	.....	119	
Figure 4.8.4	.....	119	
Figure 4.8.5	.....	120	
Figure 4.8.6	.....	120	
Figure 4.8.7	.....	121	



Figure 4.8.8	.....121	} Ex 5
Figure 4.8.9	.....122	
Figure 4.8.10	Total Fission Product Release Fraction from the Fuel.....122	
Figure 4.8.11	RB Refueling Room Temperature Response.....123	
Figure 4.8.12	Fuel Assembly Energy Balance.....123	
Figure 4.9.1	SFP Collapsed Water Level Response. ....126	
Figure 4.9.2	.....126	} Ex 5
Figure 4.9.3	.....127	
Figure 4.9.4	.....127	
Figure 4.9.5	.....128	
Figure 4.9.6	.....128	
Figure 4.9.7	.....129	
Figure 4.9.8	.....129	
Figure 4.9.9	.....130	
Figure 4.9.10	Total Fission Product Release Fraction from the Fuel.....130	
Figure 4.9.11	RB Refueling Room Temperature Response.....131	
Figure 4.9.12	Fuel Assembly Energy Balance.....131	
Figure 4.10.1	SFP Collapsed Water Level Response. ....134	
Figure 4.10.2	.....134	} Ex 5
Figure 4.10.3	.....135	
Figure 4.10.4	.....135	
Figure 4.10.5	.....136	
Figure 4.10.6	.....136	
Figure 4.10.7	.....137	
Figure 4.10.8	.....137	
Figure 4.10.9	.....138	
Figure 4.10.10	Total Fission Product Release from Fuel.....138	
Figure 4.10.11	.....139	} Ex 5
Figure 4.10.12	Reactor Building Decontamination Factor.....139	
Figure 4.10.13	RB Refueling Room Temperature Response.....140	
Figure 4.10.14	Fuel Assembly Energy Balance.....140	
Figure 4.10.15	.....141	} Ex 5
Figure 4.10.16	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....141	
Figure 4.10.17	Average Assembly Oxygen Molar Fraction.....142	
Figure 4.10.18	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....142	
Figure 4.10.19		} Ex 5
Figure 4.10.20		
Figure 5.1.1	SFP Collapsed Water Level Response. ....148	
Figure 5.1.2	SFP Water Temperature at the Bottom of the Assembly.....149	
Figure 5.1.3	.....149	} Ex 5
Figure 5.1.4	Total Fission Product Release from Fuel.....150	
Figure 5.1.5	.....150	} Ex 5
Figure 5.1.6	Reactor Building Decontamination Factor.....151	

Figure 5.1.7	RB Refueling Room Temperature Response.....	151	
Figure 5.1.8	Fuel Assembly Energy Balance.....	152	
Figure 5.1.9		152	Ex 5
Figure 5.1.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....	153	
Figure 5.1.11	Average Assembly Oxygen Molar Fraction.....	153	
Figure 5.1.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	154	
Figure 5.1.13			Ex 5
Figure 5.1.14			5
Figure 5.1.15	Integral Hydrogen Production.....	155	
Figure 5.1.16		6	Ex 5
Figure 5.1.17		6	5
Figure 5.2.1	SFP Collapsed Water Level Response. ....	160	
Figure 5.2.2	SFP Water Temperature at the Bottom of the Assembly.....	160	
Figure 5.2.3		161	Ex 5
Figure 5.2.4	Total Fission Product Release from Fuel.....	161	
Figure 5.2.5		162	Ex 5
Figure 5.2.6	Reactor Building Decontamination Factor.....	162	
Figure 5.2.7	RB Refueling Room Temperature Response.....	163	
Figure 5.2.8	Fuel Assembly Energy Balance.....	163	
Figure 5.2.9		164	Ex 5
Figure 5.2.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....	164	
Figure 5.2.11	Average Assembly Oxygen Molar Fraction.....	165	
Figure 5.2.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	165	
Figure 5.2.13			Ex 5
Figure 5.2.14			5
Figure 5.2.15	Integral Hydrogen Production.....	167	
Figure 5.2.16			Ex 5
Figure 5.2.17			5
Figure 5.3.1	SFP Collapsed Water Level Response. ....	172	
Figure 5.3.2	SFP Water Temperature at the Bottom of the Assembly.....	172	
Figure 5.3.3		173	Ex 5
Figure 5.3.4	Total Fission Product Release from Fuel.....	173	
Figure 5.3.5		174	Ex 5
Figure 5.3.6	Reactor Building Decontamination Factor.....	174	
Figure 5.3.7	RB Refueling Room Temperature Response.....	175	
Figure 5.3.8	Fuel Assembly Energy Balance.....	175	
Figure 5.3.9		176	Ex 5
Figure 5.3.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....	176	
Figure 5.3.11	Average Assembly Oxygen Molar Fraction.....	177	

Figure 5.3.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	177	
Figure 5.3.13			} Ex 5
Figure 5.3.14		8	
Figure 5.3.15	Integral Hydrogen Production.....	179	
Figure 5.3.16			} Ex 5
Figure 5.3.17			
Figure 5.3.18			
Figure 5.3.19			
Figure 5.4.1	SFP Collapsed Water Level Response. ....	185	
Figure 5.4.2	SFP Water Temperature at the Bottom of the Assembly.....	186	
Figure 5.4.3		186	Ex 5
Figure 5.4.4	Total Fission Product Release from Fuel.....	187	
Figure 5.4.5		187	Ex 5
Figure 5.4.6	Reactor Building Decontamination Factor.....	188	
Figure 5.4.7	RB Refueling Room Temperature Response.....	188	
Figure 5.4.8	Fuel Assembly Energy Balance.....	189	
Figure 5.4.9		189	Ex 5
Figure 5.4.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....	190	
Figure 5.4.11	Average Assembly Oxygen Molar Fraction.....	190	
Figure 5.4.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	191	
Figure 5.4.13			} Ex 5
Figure 5.4.14			
Figure 5.4.15	Integral Hydrogen Production.....	192	
Figure 5.4.16			} Ex 5
Figure 5.4.17		93	
Figure 5.5.1	SFP Collapsed Water Level Response. ....	197	
Figure 5.5.2	SFP Water Temperature at the Bottom of the Assembly.....	197	
Figure 5.5.3		198	Ex 5
Figure 5.5.4	Total Fission Product Release from Fuel.....	198	
Figure 5.5.5		199	Ex 5
Figure 5.5.6	Reactor Building Decontamination Factor.....	199	
Figure 5.5.7	RB Refueling Room Temperature Response.....	200	
Figure 5.5.8	Fuel Assembly Energy Balance.....	200	
Figure 5.5.9		201	Ex 5
Figure 5.5.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....	201	
Figure 5.5.11	Average Assembly Oxygen Molar Fraction.....	202	
Figure 5.5.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	202	

Figure 5.5.13

Figure 5.5.14

Figure 5.5.15

Figure 5.5.16

Figure 5.5.17

Figure 5.6.1

Figure 5.6.2

Figure 5.6.3

Figure 5.6.4

Figure 5.6.5

Figure 5.6.6

Figure 5.6.7

Figure 5.6.8

Figure 5.6.9

Figure 5.6.10

Figure 5.6.11

Figure 5.6.12

Figure 5.6.13

Figure 5.6.14

Figure 5.6.15

Figure 5.6.16

Figure 5.6.17

Figure 5.7.1

Figure 5.7.2

Figure 5.7.3

Figure 5.7.4

Figure 5.7.5

Figure 5.7.6

Figure 5.7.7

Figure 5.7.8

Figure 5.7.9

Figure 5.7.10

Figure 5.7.11

Figure 5.7.12

Figure 5.7.13

Figure 5.7.14

Figure 5.7.15

Integral Hydrogen Production.....204

SFP Collapsed Water Level Response. ....209

SFP Water Temperature at the Bottom of the Assembly.....209

.....210

Total Fission Product Release from Fuel.....210

.....211

Reactor Building Decontamination Factor.....211

RB Refueling Room Temperature Response.....212

Fuel Assembly Energy Balance.....212

.....213

Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....213

Average Assembly Oxygen Molar Fraction.....214

UO<sub>2</sub> Mass Distribution at the End of the Simulation. ....214

Integral Hydrogen Production.....216

SFP Collapsed Water Level Response. ....220

SFP Water Temperature at the Bottom of the Assembly.....221

.....221

Total Fission Product Release from Fuel.....222

.....222

Reactor Building Decontamination Factor.....223

RB Refueling Room Temperature Response.....223

Fuel Assembly Energy Balance.....224

.....224

Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....225

Average Assembly Oxygen Molar Fraction.....225

UO<sub>2</sub> Mass Distribution at the End of the Simulation. ....226

Integral Hydrogen Production.....227

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Ex  
5

Figure 5.7.16	.....	228	] Ex 5
Figure 5.7.17	Structural Damage in the Refueling Room by Hydrogen Burns.....	228	
Figure 5.8.1	SFP Collapsed Water Level Response. ....	231	
Figure 5.8.2	SFP Water Temperature at the Bottom of the Assembly.....	232	
Figure 5.8.3	.....	232	] Ex 5
Figure 5.8.4	Total Fission Product Release from Fuel.....	233	
Figure 5.8.5	.....	233	] Ex 5
Figure 5.8.6	Reactor Building Decontamination Factor.....	234	
Figure 5.8.7	RB Refueling Room Temperature Response.....	234	
Figure 5.8.8	Fuel Assembly Energy Balance.....	235	
Figure 5.8.9	.....	235	] Ex 5
Figure 5.8.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....	236	
Figure 5.8.11	Average Assembly Oxygen Molar Fraction.....	236	
Figure 5.8.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	237	
Figure 5.8.13			] Ex 5
Figure 5.8.14			
Figure 5.8.15	Integral Hydrogen Production.....	238	
Figure 5.8.16			] Ex 5
Figure 5.8.17			
Figure 5.9.1	SFP Collapsed Water Level Response. ....	242	
Figure 5.9.2	SFP Water Temperature at the Bottom of the Assembly.....	243	
Figure 5.9.3	.....	243	] Ex 5
Figure 5.9.4	Total Fission Product Release from Fuel.....	244	
Figure 5.9.5	.....	244	] Ex 5
Figure 5.9.6	Reactor Building Decontamination Factor.....	245	
Figure 5.9.7	RB Refueling Room Temperature Response.....	245	
Figure 5.9.8	Fuel Assembly Energy Balance.....	246	
Figure 5.9.9	.....	246	] Ex 5
Figure 5.9.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP. ....	247	
Figure 5.9.11	Average Assembly Oxygen Molar Fraction.....	247	
Figure 5.9.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....	248	
Figure 5.9.13			] Ex 5
Figure 5.9.14			
Figure 5.9.15	Integral Hydrogen Production.....	249	
Figure 5.9.16			] Ex 5
Figure 5.9.17			
Figure 5.10.1	SFP Collapsed Water Level Response. ....	253	
Figure 5.10.2	SFP Water Temperature at the Bottom of the Assembly.....	254	

Figure 5.10.3	.....254	] Ex 5
Figure 5.10.4	Total Fission Product Release from Fuel.....255	
Figure 5.10.5	.....255	] Ex 5
Figure 5.10.6	Reactor Building Decontamination Factor.....256	
Figure 5.10.7	RB Refueling Room Temperature Response.....256	
Figure 5.10.8	Fuel Assembly Energy Balance.....257	
Figure 5.10.9	.....257	] Ex 5
Figure 5.10.10	Summary of Zirconium and Zirconium-Oxide Masses in the SFP.....258	
Figure 5.10.11	Average Assembly Oxygen Molar Fraction.....258	
Figure 5.10.12	UO <sub>2</sub> Mass Distribution at the End of the Simulation. ....259	
Figure 5.10.13		] Ex 5
Figure 5.10.14		
Figure 5.10.15	Integral Hydrogen Production.....260	
Figure 5.10.16		] Ex 5
Figure 5.10.17		

# Evaluation of a BWR Spent Fuel Pool Accident Response to Loss-of-Coolant Inventory Scenarios Using MELCOR 1.8.5

## 1. BACKGROUND

In 2001, the NRC staff performed an evaluation of the potential accident risk in a SFP at decommissioning plants in the United States [NUREG-1738]. The study was prepared to provide a technical basis for decommissioning rulemaking for permanently shutdown nuclear power plants. The study described a modeling approach of a typical decommissioning plant with design assumptions and industry commitments; the thermal-hydraulic analyses performed to evaluate spent fuel stored in the spent fuel pool at decommissioning plants; the risk assessment of spent fuel pool accidents; the consequence calculations; and the implications for decommissioning regulatory requirements. It was known that some of the assumptions in the accident progression in NUREG-1738 were necessarily conservative, especially the estimation of the fuel damage. Furthermore, the NRC desired to expand the study to include accidents in the spent fuel pools of operating power plants. Consequently, the NRC has continued spent fuel pool accident research by applying best-estimate computer codes to predict the severe accident progression following various postulated accident initiators. The scope of the present analysis is to describe the response of a reference Boiling Water Reactor (BWR) SFP to both partial and complete-loss-of-coolant inventory accidents.

Ex 5

Ex 2

The MELCOR 1.8.5 severe accident computer code [Gauntt] was used to simulate the SFP accident response. MELCOR includes fuel degradation models for BWR and PWR fuel, radiation, convection, and conduction heat transfer models, air and steam oxidation models, hydrogen burn models, two-phase thermal-hydraulic models, and fission product release and transport models. The code contains the basic models to address questions and phenomena expected during a spent fuel pool accident.

included in MELCOR's fuel performance models that make application of MELCOR for SFP  
Consequently, MELCOR separate effect [Wagner, 2003] and  
computational fluid dynamics (CFD) [Chiffelle, 2003, Ross, 2003, and Suo-Anttila, 2003]

3 Ex 5

calculations were performed to develop a modeling approach for whole SFP severe accident calculations. These analyses helped guide the development of the whole SFP MELCOR model as well as help characterize many of the uncertainties and variability in the accident response.

Section 1.1 summarizes the two types of SFP accidents considered in the present report. They consist of a complete loss-of-coolant inventory and a partial loss-of-coolant inventory. Due to the varying phenomena, the calculated responses are discussed separately. Then Section 1.2 summarizes the structure of the report.

## 1.1 SFP Accident Scenarios

Ex  
5

### 1.1.1 Complete Loss-of-Coolant Inventory Accident

Ex.  
5



rate (i.e., the convection rate of the gases through the fuel), and heat transfer rate to adjacent assemblies.

An accurate analysis of the SFP response requires consideration of the aforementioned phenomena. As evidenced by the accident description, there is a large range of geometric length scales and modeling requirements. The length scales range from details of the individual assembly heat generation and flow patterns (e.g., also including multi-dimensional flow within an assembly, see [Ross, 2003]), intra-assembly heat transfer, large scale flow patterns above, below, and through the racks, and the refueling building response (e.g., ventilation, heat loss, structural failures, etc.). The relevant physics and phenomena include heat transfer (convection, conduction, and radiation), fluid flow (small scale to large scale), chemical reactions (i.e., oxidation), severe accident fuel degradation behavior, and fission product release and transport.




Figure 1.1.1 Reactor Building for a Boiling Water Reactor with the Spent Fuel Pool.




Figure 1.1.2 Spent Fuel Pool Rack with BWR Assemblies.

### 1.1.2 Partial Loss-of-Coolant inventory accident

In the second type of accident, the SFP is partially drained (i.e., due to partial drain or boil-off) and does not include recirculation of hot gases through the racks. Consequently, the gas in the fuel assemblies above the pool level is relatively stagnant (i.e., except for steam flow from boiling). In this condition, steam cooling and/or a level swell from the boiling will keep the fuel rods cool unless the pool level drops too far. Similar to the findings by General Electric in the 1960's, it is expected that steam cooling would be successful until the bulk pool level drops below two thirds of the fuel's height (i.e., the height of the jet pump). However, once the level drops below two thirds of the fuel height, the top of the fuel rods will heat-up and possibly degrade.

As the top of the fuel uncovers, several new phenomena occur in a partial loss-of-coolant inventory accident. First, the convective flows are much smaller than a complete loss-of-coolant inventory accident. In the complete loss-of-coolant inventory accident, there was ample air flow as the assembly heated. However, in a partial loss-of-coolant inventory accident, the fluid in the

Ex  
5

## 1.2 Report Structure

In Section 2, a summary discussion is given on the reference BWR SFP. The modeling approach using MELCOR 1.8.5 is given in Section 3. Section 3 includes a discussion of the decay heat modeling, the thermal radial coupling, the reactor building model, the SFP nodalization, and the code model settings and sensitivity coefficients. The results of complete loss-of-coolant calculations are given in Section 4. An overall summary of their results is given in the Executive Summary. Next, the results from the partial loss-of-coolant cases are given in Section 5. Similarly, a high-level overview is presented in the Executive Summary. Finally, the references are in Section 6.

Ex  
5  
Ex 5

## 2. SFP GEOMETRY

### 2.1 SFP Geometry

Ex.  
2

Ex.  
2

SFP Pool Characteristics	Description or Dimensions

**Table 2.2      Spent Fuel Pool Rack Data.**

[illegible]

## 2.2 SFP Assembly Geometry

Ex  
2

[ Ex  
5

Table 2.3 Fuel Assembly Data.

Assembly Characteristics	Description or Dimensions
[	Ex 2



### 3. ANALYSIS METHODOLOGY

#### 3.1 Decay Heat Calculations

The SFP contains fuel assemblies from [ ] separate fuel offloads from the reference BWR reactor. Within a particular offload, variations in the assembly burnup and initial uranium loading are also present. The variations in these parameters lead to different levels of heat-producing decay reactions. However, as the fuel ages, the heat produced by the decay reactions decreases.

Ex. 2

Ex. 5

Ex. 5

## 6. REFERENCES

ANSI/ANS ANSI/ANS-5.1-1994, "Decay Heat Power in Light Water Reactors," ANSI Standard, 1994.

Boyd, C., "Predictions of Spent Fuel Heatup after a Complete Loss of-Coolant Accident," NUREG-1726, July 2000.

Chiffelle, R., et al., "Analysis of Spent Fuel Pool Flow Patterns Using Computational Fluid Dynamics: Part 1 – Air Cases," Sandia National Laboratories, Informal Report, April 2003.

Collins, T. E., and Hubbard, G., "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants," NUREG-1738, February, 2001.

Gauntt, R. O., et al, "MELCOR Computer Code Manuals, Reference Manual, Version 1.8.5, Vol. 2, Rev. 2", Sandia National Laboratories, NUREG/CR-6119, SAND2000-2417/1.

Ross, K. W., et al., "Analysis of Spent Fuel Pool Flow Patterns Using Computational Fluid Dynamics: Part 2 – Partial Water Cases," Sandia National Laboratories, Informal Report, April 2003.

Suo-Anttila, A. J., Wagner, K. C., Gauntt, R. O., "Analysis of Spent Fuel Pool Flow Patterns Using Computational Fluid Dynamics: Supplement - Thermal Plume Response," Sandia National Laboratories, Informal Report, July 2003.

Wagner, K. C., et al., "Evaluation of Spent Fuel Pool Accident Response to a Complete Loss-of-Coolant Inventory Using MELCOR 1.8.5," Sandia National Laboratories, Informal Report, January 2003 [2003a].

Wagner, K. C., et al., "MELCOR 1.8.5 Separate Effect Analyses of Spent Fuel Pool Assembly Accident Response," Sandia National Laboratories, Informal Report, June 2003 [2003b].

Release