

7/03

Assessment of NPP Vulnerabilities: Accident Progression, Source Term and Consequence Estimates:

BWR and PWR Analysis and Radiological Consequences

**Jason Schaperow
Office of Nuclear Regulatory Research**

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 2
FOIA-2004-0224

~~Excluded entirely~~
—Official Use Only—

Portions Ex 5

6/1/14

Consequence Estimates

Objective

- Provide decision makers with realistic estimates of consequences for terrorist-initiated scenarios



Ex
5

Approach

- Use MACCS code to estimate consequences for specific terrorist-initiated scenarios




Ex
5

Preliminary Consequence Evaluation

Spent fuel pool analysis

- **Performed to evaluate the effect of source term from first-of-a-kind MELCOR analysis for a spent fuel pool**
 - Release fractions
 - Release timing
 - Plume heat content



EX
S

- **Other assumptions same as NUREG-1738,
“Technical Study of Spent Fuel Pool Accident
Risk at Decommissioning Nuclear Power Plants”**

Preliminary Consequence Evaluation

Spent fuel pool source term

Ex.
5

Source Term	Fraction of spent fuel pool inventory released to environment								
	Xe	I	Cs	Te	Sr	Ba	Ru	La	Ce
NUREG-1738	1	.75	.75	.31	.12	.12	.75	.035	.035

Ex. 5

Source Terms

- **Scenario-specific source terms from MELCOR important for radiological consequence predictions**
- **Start time of release vs. start time of evacuation**
 - **Affects early and cancer fatalities**
- **Release rate vs. evacuation speed**
 - **Affects early and cancer fatalities**
- **Release magnitude**
 - **Affects land contamination and economic costs**

Weather

- **Considering effect of different weather conditions on consequences**
 - Wind direction
 - Wind speed
 - Atmospheric stability
 - Precipitation
- **MACCS capabilities include**
 - Weather sampling
 - Single weather sequence

Protective Measures

- Scenario-specific protective measures
- Evacuation start time



Ex.
5

- NUREG/CR-2239 siting study assumed an average delay of evacuation start of 3 hours following warning by plant

- Evacuation distance



Ex. 5



Ex. 5

Cancer Predictions

- **MACCS cancer model based on linear no-threshold hypothesis**
- **MACCS estimates the total number of cancers by multiplying**
 - the organ-specific dose for an individual in a region (sector)
 - the cancer risk associated with that dose
 - the number of people in that sector

And summing the contribution from each sector

