

August 29, 2006

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 AND WATTS BAR NUCLEAR
PLANT UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION RE: RELIEF
REQUEST G-RR-1 - PREEMPTIVE WELD OVERLAYS ON ALLOY 600
PRESSURIZER NOZZLE-TO-PIPE WELD OVERLAYS (TACS NOS. MD2381,
MD2382, MD2383)

Dear Mr. Singer:

By letter dated June 16, 2006, Tennessee Valley Authority submitted Relief Request G-RR-1 requesting approval for use of alternatives to the requirements of the American Society of Mechanical Engineers Code, Section XI, for the specified Edition and Addenda, Article IWA-4000, for repair and replacement activities related to the performance of preemptive weld overlays, and/or needed weld overlay repairs at the Sequoyah Nuclear Plant, Units 1 and 2 and the Watts Bar Nuclear Plant, Unit 1.

As part of our review, the staff has identified the enclosed Request for Additional Information which will be necessary in order to complete our review. Based on discussions with your staff, we will expect your response by approximately September 18, 2006.

Sincerely,

/RA/

Douglas V. Pickett, Senior Project Manager
Project Directorate II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-327, 50-328, 50-390

Enclosure: As stated

cc w/enclosure: See next page

August 29, 2006

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 AND WATTS BAR NUCLEAR
PLANT UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION RE: RELIEF
REQUEST G-RR-1 - PREEMPTIVE WELD OVERLAYS ON ALLOY 600
PRESSURIZER NOZZLE-TO-PIPE WELD OVERLAYS (TACS NOS. MD2381,
MD2382, MD2383)

Dear Mr. Singer:

By letter dated June 16, 2006, Tennessee Valley Authority submitted Relief Request G-RR-1 requesting approval for use of alternatives to the requirements of the American Society of Mechanical Engineers Code, Section XI, for the specified Edition and Addenda, Article IWA-4000, for repair and replacement activities related to the performance of preemptive weld overlays, and/or needed weld overlay repairs at the Sequoyah Nuclear Plant, Units 1 and 2 and the Watts Bar Nuclear Plant, Unit 1

As part of our review, the staff has identified the enclosed Request for Additional Information which will be necessary in order to complete our review. Based on discussions with your staff, we will expect your response by approximately September 18, 2006.

Sincerely,

/RA/

Douglas V. Pickett, Senior Project Manager
Project Directorate II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-327, 50-328, 50-390

Enclosure: As stated

cc w/enclosure: See next page

DISTRIBUTION:

PUBLIC	LPL2-2 r/f	RidsOgcRp	RidsNrrDciCfeb
RidsAcrsAcnwMailCenter	RidsNrrDorLpl2-2	EAndruszkiewicz	
RidsNrrLACSola	RidsNrrPMDPickett	RidsRgn2MailCenter	

ADAMS ACCESSION NO. ML062290496

NRR-088

OFFICE	LPL2-2/PM	LPL2-2/LA	CFEB/BC	LPL2-2/BC (A)
NAME	DPickett	RSola	KGruss	JDixon-Herrity
DATE	08 / / 06	08 / 21 / 06	08 / 23 / 06	08 / 29 / 06

OFFICIAL RECORD COPY

Mr. Karl W. Singer
Tennessee Valley Authority

cc:

Mr. Ashok S. Bhatnagar, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Larry S. Bryant, Vice President
Nuclear Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Robert J. Beecken, Vice President
Nuclear Support
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Michael D. Skaggs, Site Vice President
Watts Bar Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Spring City, TN 37381

Mr. Randy Douet,
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37384-2000

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. John C. Fornicola, Manager
Nuclear Assurance and Licensing
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

**SEQUOYAH NUCLEAR PLANT
WATTS BAR NUCLEAR PLANT**

Mr. Glenn W. Morris, Manager
Corporate Nuclear Licensing
and Industry Affairs
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Paul L. Pace, Manager
Licensing and Industry Affairs
ATTN: Mr. James D. Smith
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37384-2000

Mr. David A. Kulisek, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37384-2000

Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

County Mayor
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Mr. Paul L. Pace, Manager
Licensing and Industry Affairs
Watts Bar Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Spring City, TN 37381

Jay Laughlin, Plant Manager
Watts Bar Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Spring City, TN 37381

Mr. Karl W. Singer
Tennessee Valley Authority

**SEQUOYAH NUCLEAR PLANT
WATTS BAR NUCLEAR PLANT**

cc:
Senior Resident Inspector
Watts Bar Nuclear Plant
U.S. Nuclear Regulatory Commission
1260 Nuclear Plant Road
Spring City, TN 37381

County Executive
375 Church Street
Suite 215
Dayton, TN 37321

County Mayor
P. O. Box 156
Decatur, TN 37322

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Dept. of Environment & Conservation
Third Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

Ms. Ann P. Harris
341 Swing Loop Road
Rockwood, Tennessee 37854

OFFICE OF NUCLEAR REACTOR REGULATION

REQUEST FOR ADDITIONAL INFORMATION

INSERVICE INSPECTION PROGRAM

RELIEF REQUEST G-RR-1

SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2 AND WATTS BAR NUCLEAR PLANT UNIT 1

TENNESSEE VALLEY AUTHORITY

DOCKET NOS. 50-327, 50-328 AND 50-390

1. Table 2 of Regulatory Guide 1.147, Rev. 14, identifies the Code Cases that are conditionally acceptable, i.e., for use by licensees within the limitations and conditions identified in the table. Those conditions are identified by the staff during its review of the Code Cases and are necessary to ensure an acceptable level of quality and safety. Therefore, licensees must include those conditions in their Relief Requests. No provisions are made in Regulatory Guide 1.147 for allowing licensees to delete or alter those conditions.

Tennessee Valley Authority's (TVA)'s June 16, 2006, letter requests relief from the Code Case N-638-1 condition in Table 2 of Regulatory Guide 1.147. Specifically, the letter states in part that, "In lieu of the ultrasonic examination acceptance criteria of the Construction Code in the condition for the use of Code Case N-638-1, the acceptance criteria of ASME Section XI Nonmandatory Appendix Q, as stipulated in the Conditions of RG-1.147, Rev. 14, for the use of Code Case N-504-2 will be applied for the entire structural weld overlay." Therefore, in accordance with the reasoning stated in the previous paragraph, this Relief Request must be supplemented to recognize the Licensee's compliance with the condition for N-638-1 to provide an acceptable level of quality and safety. The condition stated in the Regulatory Guide must be included in the relief request.

2. On page A4-2 of Attachment 4 to your submittal, you state that it is not practical to perform the full ultrasonic test (UT) of the 1.5T band. Your basis is that the existing nozzle configurations shown in the TVA drawings contained in Attachment 1, prevent you from completing the full UT. Please provide additional information to support your conclusion. The information provided should discuss the achievable amount of area that will be successfully examined for each pre-emptive weld overlay design configuration. Secondly, the UT examination should be performed on the maximum extent achievable.