

September 18, 2006

Mr. Christopher M. Crane, President  
and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: NRC RECEIPT OF EXELON GENERATION COMPANY, LLC'S RESPONSE TO  
GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC  
AND MT FIRE BARRIER CONFIGURATIONS" (TAC NOS. MD1592 AND  
MD1593)

Dear Mr. Crane:

The Nuclear Regulatory Commission (NRC) acknowledges the receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Under oath or affirmation, you stated that LaSalle County Station, Units 1 and 2, do not rely on either the Hemyc or MT fire barrier system. You submitted documentation under oath or affirmation that other 1-or 3-hour fire barriers that separate redundant safe shutdown trains located within the same fire area have been designed and installed in accordance with current NRC guidance. Based on your response, the basis for stating that this other fire barrier has been designed and installed in accordance with NRC guidance should be maintained on site, and will be subject to inspection during the normal NRC inspection process.

If you have any questions regarding this response, please contact me at (301) 415-3154.

Sincerely,

*/RA/*

Stephen P. Sands, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

cc: See next page

September 18, 2006

Mr. Christopher M. Crane, President  
and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: NRC RECEIPT OF EXELON GENERATION COMPANY, LLC'S RESPONSE TO  
GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC  
AND MT FIRE BARRIER CONFIGURATIONS" (TAC NOS. MD1592 AND  
MD1593)

Dear Mr. Crane:

The Nuclear Regulatory Commission (NRC) acknowledges the receipt of your response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Under oath or affirmation, you stated that LaSalle County Station, Units 1 and 2, do not rely on either the Hemyc or MT fire barrier system. You submitted documentation under oath or affirmation that other 1-or 3-hour fire barriers that separate redundant safe shutdown trains located within the same fire area have been designed and installed in accordance with current NRC guidance. Based on your response, the basis for stating that this other fire barrier has been designed and installed in accordance with NRC guidance should be maintained on site, and will be subject to inspection during the normal NRC inspection process.

If you have any questions regarding this response, please contact me at (301) 415-3154.

Sincerely,

*/RA/*

Stephen P. Sands, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

cc: See next page

DISTRIBUTION:

PUBLIC	LPL3-2 R/F	RidsNrrPMSSands	RidsOgcRp
RidsAcrsAcnwMailCenter	RidsRgn3MailCenter	DFrumkin, NRR	QNguyen, NRR
RidsNrrLADClarke	RidsNrrDorlDpr	RidsNrrDorlLpl3-2	RidsNrrDraAfpb

ADAMS ML062300114

OFFICE	LPL3-2/PM	LPL3-2/LA	AFPB/BC	LPL3-2/BC
NAME	SSands:mw	DClarke	SWeerakody	DCollins
DATE	9/6/2006	9/6/2006	9/18/2006	9/18/2006

**OFFICIAL RECORD COPY**

LaSalle County Station, Units 1 and 2

cc:

Site Vice President - LaSalle County Station  
Exelon Generation Company, LLC  
2601 North 21st Road  
Marseilles, IL 61341-9757

Plant Manager - LaSalle County Station  
Exelon Generation Company, LLC  
2601 North 21st Road  
Marseilles, IL 61341-9757

Manager Regulatory Assurance - LaSalle  
Exelon Generation Company, LLC  
2601 North 21st Road  
Marseilles, IL 61341-9757

U.S. Nuclear Regulatory Commission  
LaSalle Resident Inspectors Office  
2605 North 21st Road  
Marseilles, IL 61341-9756

Phillip P. Steptoe, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, IL 60603

Assistant Attorney General  
100 W. Randolph St. Suite 12  
Chicago, IL 60601

Chairman  
LaSalle County Board  
707 Etna Road  
Ottawa, IL 61350

Attorney General  
500 S. Second Street  
Springfield, IL 62701

Chairman  
Illinois Commerce Commission  
527 E. Capitol Avenue, Leland Building  
Springfield, IL 62706

Robert Cushing, Chief, Public Utilities Division  
Illinois Attorney General's Office  
100 W. Randolph Street  
Chicago, IL 60601

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, IL 60532-4351

Illinois Emergency Management  
Agency  
Division of Disaster Assistance &  
Preparedness  
110 East Adams Street  
Springfield, IL 62701-1109

Document Control Desk - Licensing  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Senior Vice President -Operations Support  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Director - Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Vice President - Regulatory & Legal Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Assistant General Counsel  
Exelon Generation Company, LLC  
200 Exelon Way  
Kennett Square, PA 19348

LaSalle County Station, Units 1 and 2

cc:

Manager Licensing - LaSalle  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Senior Vice President - Midwest Operations  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555