

# **Pressurized Water Reactor Steam Generator Examination Guidelines: Revision 7**

**Requirements**

**(Non-Proprietary Version of 1013706)**

Draft Report, July 2006

EPRI Project Manager  
S. Swilley

## **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES**

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

ORGANIZATION(S) THAT PREPARED THIS DOCUMENT

**Research Contractor Company Name (add others on lines below if more than one)**

### **NOTE**

For further information about EPRI, call the EPRI Customer Assistance Center at 800.313.3774 or e-mail [askepri@epri.com](mailto:askepri@epri.com).

Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc.

Copyright © 2006 Electric Power Research Institute, Inc. All rights reserved.

# CITATIONS

---

This report was prepared by the PWR Steam Generator Examination Guidelines Ad Hoc Committee

Ad Hoc Main Committee membership principal contributors:

T. Pettus	AmerenUE
D. Mayes	Duke Energy
G. Navratil	Exelon
H. Smith	Exelon
G. Boyers	Florida Power & Light
S. Redner	Nuclear Management Company
T. Bipes	Progress Energy
C. Connor	PSEG Nuclear
A. Matheny	Southern California Edison
C. Webber	Tennessee Valley Authority
S. Swilley	EPRI

Ad Hoc Sub-Committee membership principal contributors:

M. Boudreaux	Areva
M. Harris	Areva
B. Miranda	Areva
D. Hansen	Arizona Public Service
C. Visconti	Corestar
T. Mayer	Dominion
R. Lieder	Florida Power & Light
T. Smith	Southern Company
D. Ellis	TXU Power
T. Weyandt	TXU Power
R. Procratsky	Westinghouse
R. Maurer	Westinghouse
J. Siegel	Zetec
N. Farenbaugh	Zetec
R. Guill	EPRI
S. Kenefick	EPRI

This report describes research sponsored by the Electric Power Research Institute (EPRI).

The report is a corporate document that should be cited in the literature in the following manner:

*Pressurized Water Reactor Steam Generator Examination Guidelines: Revision 7, Requirements.*  
EPRI, Palo Alto, CA: 2007. 1013706.



# PRODUCT DESCRIPTION

---

This report provides requirements for examination plans and processes that are necessary to meet the performance criteria set forth in the Nuclear Energy Institute (NEI) 97-06 *Steam Generator Program*.

## Results and Findings

This document continues to provide recommendations and requirements to the industry for sampling and inspection of steam generator tubing. The qualification for techniques and personnel is described in detail. Additionally, this document recognizes the improved performance of new steam generator tubing materials in the absence of foreign objects and in the presence of good chemistry controls. Data quality parameters continue to be an important attribute of an effective steam generator inspection. Inspection frequencies as described in the Technical Specification Task Force (TSTF) document TSTF 449 *Steam Generator Tube Integrity* are contained within this document. With these recommendations and requirements in place and implemented by the utility, this document makes a significant contribution to meeting the requirements of NEI 97-06.

## Challenges and Objectives

Steam Generator tubing, when degraded, can provide a challenge to the required safety functions in terms of structural stability and leakage. It is imperative that the condition of the steam generator be known such that appropriate repairs and operating parameters can be applied. Nondestructive examination (NDE) is the first step in determining the condition of the steam generator. This document is intended to be used by utility engineers, program managers, NDE personnel and plant management in support of:

- Implementation of NEI 97-06
- Meeting the sampling and inspection requirements of TSF 449
- Technique and personnel qualification for input to condition monitoring and operational assessments

## Applications, Values, and Use

The fundamental elements of NEI 97-06 represent a balance of prevention, inspection, evaluation, repair, and leakage monitoring measures. Implementation of these elements requires maintenance of this document to ensure applicability to the utility for management of steam generator issues.

## **EPRI Perspective**

NEI 97-06 requires the performance of condition monitoring and operational assessment of the steam generator tubing during and after an outage. These guidelines provide the recommendations and requirements for inspection, technique validation, data quality, and qualification of techniques and personnel.

This document reflects the current industry practices, with enhancements where the industry felt it necessary. Data management requirements were addressed for the first time in this document. The Appendix G damage mechanisms were updated as a result of steam generator replacement projects. A new appendix on qualification of UT personnel was included to separate UT personnel qualification from Appendix G in the same manner that Appendix J was separated from Appendix H for UT technique qualifications. The Inspection frequencies as described in TSTF 449 *Steam Generator Tube Integrity* were included to ensure compliance with the utility technical specifications. The use of mandatory/shall/should/recommend was addressed in accordance with the *Steam Generator Management Program Administrative Procedures, Revision 1*. Additionally, the performance based requirements previously contained in Section 4 have been deleted.

This revision considered all previous interim guidance issued since the last revision and upon issuance of this document, all previous interim guidance should be considered superseded.

## **Approach**

A utility ad hoc committee under the direction of the NDE IRG was convened to complete this revision. The main committee was organized with utility members chairing individual sub-committees for each book section and appendix. Each sub-committee contained participants from both utility and vendor organizations. The objective of this approach was to ensure that input was received from across the industry and that the most qualified personnel were available to work on the applicable sections. The sub-committees developed draft material for review by the main committee. Numerous telecons, web conferences, and meetings were conducted over an eighteen-month period to develop the final draft.

## **Keywords**

Nuclear steam generators  
In-service inspection  
Eddy current  
PWR SG tubing  
SGMP

# CONTENTS

---

<b>1 INTRODUCTION AND BACKGROUND .....</b>	<b>1</b>
1.1 Purpose .....	1
1.2 Scope.....	1
1.3 Background.....	2
<b>2 COMPLIANCE RESPONSIBILITIES .....</b>	<b>3</b>
2.1 Introduction .....	3
2.2 Management Responsibilities.....	3
2.3 Examination and Engineering Responsibilities.....	4
<b>3 MATERIAL BASED EXAMINATION REQUIREMENTS.....</b>	<b>1</b>
3.1 Introduction .....	1
3.2 Steam Generator Pre-Service Inspection Requirements.....	1
3.2.1 Inspection of Tubes.....	1
3.2.2 Inspection of Tube Sleeves.....	1
3.2.3 Inspection of Tube Plugs.....	2
3.2.4 Inspection of Other Tube Repairs .....	2
3.3 Steam Generator In-Service Inspection Requirements .....	2
3.4 First In-Service Inspection .....	3
3.4.1 First In-Service Inspection of Tubes.....	3
3.4.2 First In-Service Inspection of Sleeves.....	4
3.4.3 First In-Service Inspection Examination of Plugs.....	4
3.4.4 First In-Service Inspection of Other Tube Repairs .....	4
3.5 Subsequent In-Service Inspections .....	4
3.5.1 Subsequent Inspections of Tubing.....	4
3.5.2 Subsequent Inspection Examination Sleeves .....	4
3.5.3 Subsequent Inspection of Plugs.....	4
3.5.4 Subsequent Inspection of Other Repairs .....	5

3.6	Tube Examination Scope and Sampling Plans.....	6
3.7	Classification of Sample Plan Results .....	7
3.8	Expansion of the Examination .....	7
3.8.1	Expansion Requirements for Sample plans .....	7
3.8.2	Expansion Requirements for Foreign Objects and Possible Loose Parts.....	9
3.9	Secondary Side Visual Examination.....	9
3.10	Forced Outage Guidance.....	9
<b>4</b>	<b>SAMPLING REQUIREMENTS FOR PERFORMANCE-BASED EXAMINATIONS .....</b>	<b>1</b>
<b>5</b>	<b>STEAM GENERATOR ASSESSMENTS .....</b>	<b>1</b>
5.1	Introduction .....	1
5.2	Degradation Assessment.....	1
5.3	Condition Monitoring Assessment .....	1
5.4	Operational Assessment.....	2
5.5	Primary-to-Secondary Leakage Assessment.....	2
5.6	Self-Assessment.....	2
<b>6</b>	<b>SYSTEM PERFORMANCE .....</b>	<b>3</b>
6.1	Introduction .....	3
6.2	Technique Performance Requirements .....	3
6.2.1	Site-Validated Techniques .....	4
6.2.2	Diagnostic Techniques.....	4
6.2.3	Calibration Requirements.....	4
6.2.3.1	Bobbin Probe Calibration Standards.....	5
6.2.3.2	Rotating and Array Probe Calibration Standards.....	5
6.2.3.3	Other Calibration Standards .....	6
6.2.3.4	Voltage Normalization Requirements .....	6
6.2.3.5	Sample Rate Requirements.....	7
6.3	Analysis Performance Requirements.....	7
6.3.1	Qualified Data Analyst.....	7
6.3.2	Site-Specific Performance Demonstration Requirements.....	7
6.3.3	Data Analysis .....	8
6.3.3.1	Site-Specific Analysis Guidelines.....	8
6.3.3.2	Independent Analysis Teams.....	10
6.3.3.3	Automated Data Analysis.....	10



6.3.3.4	Resolution .....	12
6.3.3.5	Independent QDA (IQDA) Oversight.....	12
6.4	Data Management .....	13
6.4.1	Data Management Personnel Requirements .....	13
6.4.2	System Process Requirements.....	13
6.4.2.1	Inspection Planning and Sample Plan Expansion .....	13
6.4.2.2	Uploading Analysis Results .....	14
6.4.2.3	Rescheduling .....	14
6.4.2.4	Inspection Progress .....	14
6.4.2.5	Scope Completion Accountability .....	15
6.4.2.6	Final Closeout.....	15
6.4.2.7	Final Archiving .....	16
6.5	Data Quality Requirements.....	16
6.5.1	Probe Quality Parameters.....	19
6.6	Human Performance Requirements .....	20
6.7	Data Analysis Feedback .....	21
6.8	Verification Responsibilities .....	22
6.9	Contractor Oversight.....	22
6.10	Requirements for Visual Inspection .....	22
6.10.1	Mechanical Plugs.....	22
6.10.2	Welded Plugs.....	23
6.11	Standardized Analysis Report Format .....	23
6.12	Standardized Raw Data Format.....	23
<b>7</b>	<b>SUMMARY OF REQUIREMENTS .....</b>	<b>24</b>
7.1	Introduction and Background.....	Error! Bookmark not defined.
7.2	Compliance Responsibilities .....	Error! Bookmark not defined.
7.3	Sampling Requirements for Prescriptive-Based Examinations.....	Error! Bookmark not defined.
7.4	Sampling Requirements for Performance-Based Examinations.....	Error! Bookmark not defined.
7.5	Steam Generator Assessments .....	Error! Bookmark not defined.
7.6	System Performance .....	Error! Bookmark not defined.
<b>8</b>	<b>REFERENCES .....</b>	<b>1</b>
<b>A</b>	<b>SAMPLING BASIS .....</b>	<b>A-1</b>
A.1	Periodic Sample Size.....	A-1

A.1.1	Level of Confidence Relative to Sample Size and the Number of Tubes Affected by Degradation.....	A-1
A.1.2	Statistical Basis for Level of Confidence .....	A-3
<b>B</b>	<b>STANDARDIZED ANALYSIS REPORT FORMAT.....</b>	<b>B-1</b>
<b>C</b>	<b>STANDARDIZED RAW DATA FORMAT .....</b>	<b>C-1</b>
C.1	Overview .....	C-1
C.2	Key Features of a Standardized Eddy Current Data File Format.....	C-1
C.3	General Structure.....	C-1
C.4	General File Format Rules .....	C-6
C.5	Header File Format .....	C-6
C.6	Tester Configuration File Format .....	C-6
C.7	Block Map File Format .....	C-6
C.8	Block Data File Format.....	C-7
C.9	Filelist Format.....	C-7
C.10	Message File Format .....	C-7
C.11	Summary File Format.....	C-7
C.12	Glossary .....	C-9
<b>D</b>	.....	<b>D-1</b>
<b>E</b>	.....	<b>E-1</b>
<b>F</b>	<b>TERMINOLOGY .....</b>	<b>F-1</b>
F.1	Definitions .....	F-1
F.2	Acronyms .....	Error! Bookmark not defined.
F.3	Three-Letter Codes.....	F-7
<b>G</b>	<b>QUALIFICATION OF EDDY CURRENT EXAMINATION PERSONNEL FOR ANALYSIS OF EDDY CURRENT EXAMINATION DATA .....</b>	<b>G-1</b>
G.1	Scope .....	G-1
G.2	Qualification Level.....	G-1
G.2.1	General Requirements .....	G-1
G.3	Written Practice.....	G-2
G.3.1	General Requirements .....	G-2
G.3.1.1	Training .....	G-2

G.3.1.2	Examinations.....	G-2
G.3.2	Responsibilities .....	G-2
G.3.3	Use of an Outside Agency .....	G-2
G.3.4	Transfer of QDA Qualifications .....	G-3
G.3.5	Confidentiality.....	G-3
G.3.6	Availability of Training Course Materials .....	G-3
G.4	Qualification Requirements .....	G-3
G.4.1	Training .....	G-3
G.4.1.1	Program, Facilities, and Materials.....	G-3
G.4.1.2	QDA Training Course Content and Duration.....	G-3
G.4.1.3	Site Specific Performance Demonstration (SSPD) Training .....	G-3
G.4.2	QDA Examinations.....	G-4
G.4.2.1	Qualification Examinations and Data Sets .....	G-4
G.4.2.2	Analyst Qualification Criteria .....	G-7
G.4.2.3	Re-examination .....	G-7
G.4.2.5	QDA Requalification.....	G-8
G.4.2.6	New Technique/Damage Mechanism for QDA Qualification .....	G-8
G.4.2.7	QDA Qualification Records .....	G-9
G.4.3	SSPD Examinations.....	G-9
G.4.3.1	Examinations and Data Sets.....	G-9
G.4.3.2	Examination Grading.....	G-10
G.4.3.3	Re-Examination.....	G-11
G.4.3.4	SSPD Performance Feedback.....	G-11
Attachment G-1	QDA Training And Laboratory Program Contents.....	G-12
LECTURE .....	<b>Error! Bookmark not defined.</b>	
INTRODUCTION .....	<b>Error! Bookmark not defined.</b>	
STEAM GENERATORS .....	<b>Error! Bookmark not defined.</b>	
INDUSTRY EXPERIENCE .....	<b>Error! Bookmark not defined.</b>	
INSTRUMENTATION/SOFTWARE OVERVIEW .....	<b>Error! Bookmark not defined.</b>	
EDDY CURRENT PROBES .....	<b>Error! Bookmark not defined.</b>	
CALIBRATION STANDARDS .....	<b>Error! Bookmark not defined.</b>	
DATA ANALYSIS PRINCIPLES .....	<b>Error! Bookmark not defined.</b>	
LABORATORY .....	<b>Error! Bookmark not defined.</b>	

<b>H</b>	<b>PERFORMANCE DEMONSTRATION FOR EDDY CURRENT EXAMINATION .....</b>	<b>H-2</b>
----------	---	------------

H.1	Scope .....	H-2
H.2	General Examination System Requirements .....	H-2
H.2.1	Technique Requirements .....	H-2
H.2.1.1	Examination Technique Specification Sheet .....	H-3
H.3	Performance Demonstration .....	H-4
H.3.1	General .....	H-4
H.3.2	Essential Variable Ranges .....	H-4
H.3.3	Requalification.....	H-5
H.3.4	Disqualification of Techniques .....	H-5
H.4	Essential Variable Tolerances.....	H-5
H.4.1	Instruments and Probes .....	H-5
H.4.1.1	Cable .....	H-5
H.4.1.2	Frequency/Material/Wall Thickness .....	H-6
H.4.1.3	Array Probe Sensing Area Coverage .....	H-6
H.4.2	Computerized System Algorithms.....	H-7
H.4.3	Calibration Methods .....	H-7
H.5	Record of Qualification.....	H-7
Supplement H1	Equipment Characterization .....	H-8
H1.1	Scope .....	H-8
H1.2	Eddy Current Instrument.....	H-8
H1.2.1	Signal Generation .....	H-8
H1.2.1.1	Total Harmonic Distortion.....	H-8
H1.2.1.2	Output Impedance.....	H-8
H1.2.2	Amplification, Demodulation and Filtering.....	H-9
H1.2.2.1	Input Impedance.....	H-9
H1.2.2.2	Amplifier Linearity and Stability .....	H-9
H1.2.2.3	Phase Linearity.....	H-10
H1.2.2.4	Bandwidth and Demodulation Filter Response .....	H-11
H1.2.3	Analog-to-Digital Converter .....	H-11
H1.2.3.1	Analog-to-Digital Resolution.....	H-11
H1.2.3.2	Dynamic Range.....	H-12
H1.2.3.3	Digitizing Rate .....	H-12
<b>H1.2.4</b>	<b>Channel Crosstalk.....</b>	<b>H-12</b>
H1.3	Probe Characterization .....	H-13
H1.3.1	Impedance .....	H-13

H1.3.2	Center Frequency .....	H-13
H1.3.3	Coil Configuration Sensing Area.....	H-13
H1.3.3.1	Bobbin Probes.....	H-13
H1.3.3.2	Rotating Probes.....	H-16
H1.3.3.3	Array Probes .....	H-18
Supplement H2	Qualification Requirements for Examination of Steam Generator Tubing                   H-20	
H2.1	General .....	H-20
H2.2	Qualification Data Set Requirements.....	H-20
H2.2.1	General .....	H-20
H2.2.2	Detection Data Set.....	H-22
H2.2.3	Sizing Data Set .....	H-22
H2.3	Acceptance Criteria.....	H-23
H2.3.1	Detection Acceptance Criteria .....	H-23
H2.3.2	Technique Sizing Performance.....	H-24
Supplement H3	Protocol for Performance Demonstration Database Revision .....	H-25
H3.1	Scope .....	H-25
H3.2	Administrative Responsibilities.....	H-25
H3.3	Technique Originator Responsibilities.....	H-25
H3.4	Performance Demonstration Database Curator Responsibilities.....	H-26
H3.5	Performance Demonstration Database Peer Review Procedure.....	H-26
H3.5.1	Team Structure .....	H-26
H3.5.2	Conduct of the Review.....	H-26
Supplement H4	Protocol for Technique Peer Review .....	H-27
H4.1	Scope .....	H-27
H4.2	Administrative Responsibilities.....	H-27
H4.3	Technique Originator Responsibilities.....	H-27
H4.4	Examination Technique Specification Sheet Curator Responsibilities.....	H-27
H4.5	Peer Review Procedure .....	H-27
H4.5.1	Team Structure .....	H-27
H4.5.2	Conduct of the Review.....	H-28
<b>I.....</b>		<b>I-29</b>
<b>J PERFORMANCE DEMONSTRATION FOR ULTRASONIC EXAMINATION.....</b>		<b>J-1</b>
Supplement J1	Equipment Characterization .....	J-5

Supplement J2    Qualification Requirements for Examination of Steam Generator  
Tubing            J-9

**K QUALIFICATION OF PERSONNEL FOR ANALYSIS OF ULTRASONIC  
EXAMINATION DATA..... K-1**

Scope ..... K-1

Responsibilities and Records ..... **Error! Bookmark not defined.**

Attachment K-1 U-QDA Training Program ..... K-9

## LIST OF FIGURES

---

Figure 1-1 First Figure Caption .....	Error! Bookmark not defined.
Figure 1-2 Second Figure Caption.....	Error! Bookmark not defined.
Figure A-1 First Appendix Figure Caption.....	Error! Bookmark not defined.
Figure A-2 Second Appendix Figure Caption .....	Error! Bookmark not defined.

# LIST OF TABLES

---

Table 3-1 Expansion of Sample Plans for Non-Cracks (Thinning, Pitting, Wear, and Impingement) .....	8
Table 3-2 Expansion of a Sample Plans for Cracks (PWSCC, ODSCC, and IGA).....	9
Table 6-1 Material to Be Covered in Site-Specific Data Analysis Guidelines .....	9
Table 6-2 Generic Data Quality Parameters .....	17
Table 6-3 Bobbin Probe Data Quality Parameters.....	18
Table 6-4 Rotating Probe Data Quality Parameters .....	18
Table 6-5 Array Probe Data Quality Parameters .....	19
Table 6-6 Probe Manufacturing Quality Parameters.....	20
Table A-1 Tube Sample Sizes and Associated Numbers of Affected Tubes in Steam Generators Required to Provide a 0.90 Level of Confidence That At Least One Affected Tube Is Sampled from the Steam Generator .....	A-2
Table F-1 Three-Letter Codes .....	F-8
Table G-1 Damage Mechanisms to Be Included in the Practical Examination.....	G-5
Table G-2 Example Performance Demonstration Test Matrices for Flaw Detection.....	G-5
Table G-3 Example Performance Demonstration Test Matrices for Flaw Detection and Sizing .....	G-6
Table K-1 Damage Mechanisms Categories .....	K-3
Table K-2 Example Performance Demonstration Test Matrices for Flaw Detection.....	K-4
Table K-3 Example Performance Demonstration Test Matrices for Flaw Detection and Sizing .....	K-6



# 1

## INTRODUCTION AND BACKGROUND

---

### 1.1 Purpose

This document is the seventh revision of the *PWR Steam Generator Examination Guidelines* [1], originally published in 1981 and revised in 1984, 1988, 1992, 1996, 1997, and 2002. The purpose of this document is to provide requirements and guidance for meeting the following objectives:

- Identification of degradation which is present in the steam generator tubes,
- Qualification of NDE systems used to detect and/or size degradation.

The requirements provided within this document promote accountability for the examination process, and provide for subsequent verification of compliance by internal or external audit. The protocol for deviating from specific requirements of this document is in the *EPRI Steam Generator Management Program Administrative Procedures* [2]. Where regulatory requirements differ from requirements contained in this guideline, a technical justification for deviation is not required.

The requirements provided by this document assist in meeting the objectives of NEI 97-06, *Steam Generator Program Guidelines* [3]. NEI 97-06 brings consistency to the development and implementation of a program that monitors the condition of steam generator tubes against acceptable performance criteria in a manner sufficient to provide reasonable assurance that the steam generators remain capable of fulfilling their intended safety function.

### 1.2 Scope


This revision adheres to the guidance of NEI 97-06 and the Steam Generator Management Program (SGMP) Administrative Procedure.

This document provides the requirements and associated bases for performing SG tube inspections, including selection of periodic inspection samples, validation of NDE systems to detect and size tubing flaws, and specification of requirements for qualification of examination techniques and data analysis personnel.

The development and revision protocol of this guideline and subsequent revisions are governed by the latest revision of the Steam Generator Management Program Administrative Procedures.

*Introduction and Background*

**1.3 Background**



# **2**

## **COMPLIANCE RESPONSIBILITIES**


---

### **2.1 Introduction**

The objective of this section is to identify organizational responsibilities necessary to ensure examination activities are effectively implemented for safe and reliable steam generator operation.

### **2.2 Management Responsibilities**

## **2.3 Examination and Engineering Responsibilities**



# 3

## MATERIAL BASED EXAMINATION REQUIREMENTS

---

### 3.1 Introduction

This section outlines pre-service inspection (PSI), in-service inspection (ISI) requirements, and sample plan expansions for steam generators fabricated from Alloy 600 Mill Annealed, Alloy 600 thermally treated (TT), Alloy 690 TT, and Alloy 800 materials. Additional inspections may be required based on the degradation and/or tube integrity assessments. It is recommended that the requirements contained within this Section for Alloy 600 TT be applied to Alloy 800.

Extended inspection periods for Alloy 600 thermally treated (TT), and Alloy 690 TT are predicated on the premise that these materials will not experience in-service corrosion degradation within the first inspection period.

### 3.2 Steam Generator Pre-Service Inspection Requirements

#### 3.2.1 *Inspection of Tubes*

#### 3.2.2 *Inspection of Tube Sleeves*

*Material Based Examination Requirements*

**3.2.3 Inspection of Tube Plugs**

**3.2.4 Inspection of Other Tube Repairs**

**3.3 Steam Generator In-Service Inspection Requirements**

### **3.4 First In-Service Inspection**

#### **3.4.1 First In-Service Inspection of Tubes**



*Material Based Examination Requirements*

**3.4.2 First In-Service Inspection of Sleeves**

**3.4.3 First In-Service Inspection Examination of Plugs**

**3.4.4 First In-Service Inspection of Other Tube Repairs**

**3.5 Subsequent In-Service Inspections**

**3.5.1 Subsequent Inspections of Tubing**

**3.5.2 Subsequent Inspection Examination Sleeves**


**3.5.3 Subsequent Inspection of Plugs**

#### **3.5.4 Subsequent Inspection of Other Repairs**

*Material Based Examination Requirements*

### **3.6 Tube Examination Scope and Sampling Plans**

### **3.7 Classification of Sample Plan Results**



### **3.8 Expansion of the Examination**

#### **3.8.1 *Expansion Requirements for Sample plans***

*Material Based Examination Requirements*

**Table 3-1**



**Table 3-2**

**3.8.2 Expansion Requirements for Foreign Objects and Possible Loose Parts**

**3.9 Secondary Side Visual Examination**

**3.10 Forced Outage Guidance**

# 4

## **SAMPLING REQUIREMENTS FOR PERFORMANCE-BASED EXAMINATIONS**

---

This section has been deleted.

# 5

## STEAM GENERATOR ASSESSMENTS

---

### 5.1 Introduction

The following assessments are considered important elements of a written comprehensive SG program:

- Degradation assessment
- Condition monitoring assessment
- Operational assessment
- Primary-to-secondary leakage assessment
- Self-assessment

An overview of these assessments is provided here for completeness and integration of the program. Detailed requirements are provided in the EPRI *Steam Generator Integrity Assessment Guidelines* and the NEI 97-06 *Steam Generator Program Guidelines*.

### 5.2 Degradation Assessment

### 5.3 Condition Monitoring Assessment



## **5.4 Operational Assessment**

## **5.5 Primary-to-Secondary Leakage Assessment**

## **5.6 Self-Assessment**

# 6

## SYSTEM PERFORMANCE

---

### 6.1 Introduction

This section provides requirements for technique performance, analysis performance, data management performance, data quality, human performance, analysis feedback, verification, contractor oversight and visual inspection. In combination, they are referred to as system performance and each part adds value to ensure the tube examination results are useful in condition monitoring and operational assessments. System performance needs to be capable of detecting, characterizing, and monitoring degradation that challenges the integrity of the component being examined. Under field conditions, system performance is influenced by the capabilities of the process, procedures, examination equipment, techniques, and personnel. Ultimately, the licensee is responsible for the quality and accuracy of the inspection, providing oversight, review, and approval of all processes and procedures being used, work activities, and the integrity of the final results.

Ultrasonic testing is not generally used as a production examination technique and therefore the specific requirements in this section do not apply. However, when ultrasonic testing is used as an input to tube integrity assessments, it is recommended that personnel and techniques be qualified in accordance with Appendices J and K and the intent of this section's requirements apply to the extent practical.

### 6.2 Technique Performance Requirements

*System Performance*

**6.2.1 Site-Validated Techniques**



**6.2.2 Diagnostic Techniques**

**6.2.3 Calibration Requirements**

6.2.3.1 Bobbin Probe Calibration Standards

6.2.3.2 Rotating and Array Probe Calibration Standards

*System Performance*

6.2.3.3 Other Calibration Standards

6.2.3.4 Voltage Normalization Requirements

#### **6.2.3.5 Sample Rate Requirements**

### **6.3 Analysis Performance Requirements**

#### **6.3.1 Qualified Data Analyst**

#### **6.3.2 Site-Specific Performance Demonstration Requirements**

*System Performance*

### **6.3.3 Data Analysis**


#### **6.3.3.1 Site-Specific Analysis Guidelines**

Table 6-1






*System Performance*



**6.3.3.2 Independent Analysis Teams**




**6.3.3.3 Automated Data Analysis**




*System Performance*

6.3.3.4 Resolution



6.3.3.5 Independent QDA (IQDA) Oversight



## **6.4 Data Management**

### **6.4.1 Data Management Personnel Requirements**

### **6.4.2 System Process Requirements**

#### **6.4.2.1 Inspection Planning and Sample Plan Expansion**

*System Performance*

6.4.2.2      Uploading Analysis Results

6.4.2.3      Rescheduling

6.4.2.4      Inspection Progress

6.4.2.5 Scope Completion Accountability

6.4.2.6 Final Closeout

*System Performance*

6.4.2.7 Final Archiving

**6.5 Data Quality Requirements**

### Table 6-2



System Performance

Table 6-3




Table 6-4



Table 6-5

### 6.5.1 Probe Quality Parameters

*System Performance*

**Table 6-6**

**6.6 Human Performance Requirements**



## 6.7 Data Analysis Feedback

## **6.8 Verification Responsibilities**

## **6.9 Contractor Oversight**

## **6.10 Requirements for Visual Inspection**

### **6.10.1 Mechanical Plugs**

### **6.10.2 Welded Plugs**

## **6.11 Standardized Analysis Report Format**

## **6.12 Standardized Raw Data Format**

# 7


## SUMMARY OF REQUIREMENTS


---






*Summary of Requirements*





*Summary of Requirements*




*Summary of Requirements*






*Summary of Requirements*








*Summary of Requirements*




*Summary of Requirements*





*Summary of Requirements*



# 8

## REFERENCES

---

1. *PWR Steam Generator Examination Guidelines*, originally published in 1981 and revised in 1984, 1988, 1992, 1996, 1997, and 2002. EPRI, Palo Alto, CA: 2002, 1003138.
2. *Steam Generator Management Program Administrative Procedures, Revision 1*. EPRI, Palo Alto, CA: 2004. 1011274.
3. *Steam Generator Program Guidelines*. Nuclear Energy Institute (NEI) 97-06. 2005.
4. *The American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code*, Sections V and XI.
5. *American Society of Nondestructive Testing (ASNT) SNT-TC-1A*.
6. *American National Standard Institute (ANSI) CP-189*.
7. *The Code of Federal Regulations*, 10CFR50, Appendix B.
8. *Steam Generator Integrity Assessment Guidelines, Revision 2*. EPRI, Palo Alto, CA: 2006. 1012987.
9. *PWR Steam Generator Tube Plug Assessment Document*. EPRI, Palo Alto, CA: 1997. TR-109495.
10. *PWR Primary-to-Secondary Leakage Guidelines, Revision 3*. EPRI, Palo Alto, CA: 2004. 1008219.

# A

## SAMPLING BASIS

---

### A.1 Periodic Sample Size

The objective of conducting inspections of steam generator (SG) tubes is to monitor the condition of SG tubes against acceptable performance criteria in a manner sufficient to provide reasonable assurance that SGs remain capable of fulfilling their intended safety function. The purpose of examining samples of tubes rather than examining all tubes in SGs is to reduce the impact of meeting this objective. Consequently, the principal consideration in determining the appropriate sample size for tube examinations is the level of confidence that can be placed in the information obtained about the condition of SG tubes from examining a tube sample of given size.

#### ***A.1.1 Level of Confidence Relative to Sample Size and the Number of Tubes Affected by Degradation***

**Table A-1**







**A.1.2 Statistical Basis for Level of Confidence**

***B***

## STANDARDIZED ANALYSIS REPORT FORMAT

---







# **C**

## **STANDARDIZED RAW DATA FORMAT**

---

### **C.1 Overview**


This document proposes a standard format archive for EC data files. The intent of this proposal is standardize format and content and to leverage existing file format standards to enable all vendors and researchers to easily access the data using existing industry standard tools.

### **C.2 Key Features of a Standardized Eddy Current Data File Format**

### **C.3 General Structure**

**Table C-1**

Table C-2







**Figure C-1**


## **C.4 General File Format Rules**

## **C.5 Header File Format**

## **C.6 Tester Configuration File Format**

## **C.7 Block Map File Format**


**C.8 Block Data File Format**



**C.9 Filelist Format**

**C.10 Message File Format**

**C.11 Summary File Format**



**Figure C-2**

## **C.12 Glossary**

**D**

---



**E**

---



# **F**


## **TERMINOLOGY**


---


### **F.1 Definitions**

The following definitions are provided to ensure a uniform understanding of terms used in this guideline.












### **F.3 Three-Letter Codes**

The purpose of defining three-letter codes is to standardize their use in the industry. The use of Table F-1 codes on an industry-wide basis is recommended. A three-letter designation is used to describe eddy current inspection results. The codes are grouped into seven categories that describe actions required to assist in the correct disposition of the results. If new three letter codes are developed, then it is recommended that the user assign the applicable category.

**Table F-1**





**Table F-1 (cont.)**



# **G**

## **QUALIFICATION OF EDDY CURRENT EXAMINATION PERSONNEL FOR ANALYSIS OF EDDY CURRENT EXAMINATION DATA**

---

### **G.1 Scope**

This appendix specifies personnel training and qualification requirements for eddy current examination personnel who analyze eddy current examination data for pressurized water reactor steam generator (SG) tubing. Its purpose is to ensure a continuing uniform knowledge base and skill level for data analysts. The appropriate knowledge base is imparted using a comprehensive classroom and laboratory training program.

This appendix uses depth as a basis to establish flawed grading units based on the premise that repair criteria is expressed in terms of percent through-wall (TW). Other NDE parameters, for example, amplitude can be substituted as grading units to demonstrate performance in accordance with this appendix when the applicable repair limit is expressed in terms of other NDE parameters. It is recommended that grading units be established over the full range of the parameter.

Analysts are qualified by successful completion of written and practical examinations defined in this appendix.

### **G.2 Qualification Level**

#### **G.2.1 General Requirements**

### **G.3 Written Practice**

#### ***G.3.1 General Requirements***

##### **G.3.1.1 Training**

##### **G.3.1.2 Examinations**

#### ***G.3.2 Responsibilities***

#### ***G.3.3 Use of an Outside Agency***

### ***G.3.4 Transfer of QDA Qualifications***

### ***G.3.5 Confidentiality***

### ***G.3.6 Availability of Training Course Materials***

## **G.4 Qualification Requirements**

### ***G.4.1 Training***

#### **G.4.1.1 Program, Facilities, and Materials**

#### **G.4.1.2 QDA Training Course Content and Duration**

#### **G.4.1.3 Site Specific Performance Demonstration (SSPD) Training**


## **G.4.2 QDA Examinations**

### **G.4.2.1 Qualification Examinations and Data Sets**

#### **G.4.2.1.1 Written Examinations**

#### **G.4.2.1.2 Practical Examination**

**Table G-1**





**Table G-2**



**Table G-3**

#### G.4.2.2 Analyst Qualification Criteria



#### G.4.2.3 Re-examination



G.4.2.3.1 *Written Examination*

G.4.2.3.2 *Practical Examination*

G.4.2.5 QDA Requalification

G.4.2.6 New Technique/Damage Mechanism for QDA Qualification

**G.4.2.7 QDA Qualification Records**

**G.4.3 SSPD Examinations**

**G.4.3.1 Examinations and Data Sets**

**G.4.3.1.1 Written Examinations**

**G.4.3.1.2**     *Practical Examinations*

**G.4.3.2**        **Examination Grading**

**G.4.3.2.1**     *Written Examination*

**G.4.3.2.2**     *Practical Examination*

G.4.3.3 Re-Examination

G.4.3.4 SSPD Performance Feedback


**Attachment G-1**  
**QDA Training And Laboratory Program Contents**





**Figure G-1: Qualification Flow Chart**





**Figure G-2: Requalification Flow Chart**

**Figure G-3: New Technique/Damage Mechanism Qualification without Requalification Flow Chart**



# **H**

## **PERFORMANCE DEMONSTRATION FOR EDDY CURRENT EXAMINATION**

---


### **H.1 Scope**

- a. This appendix provides performance demonstration requirements for eddy current examination techniques and equipment.

### **H.2 General Examination System Requirements**

#### ***H.2.1 Technique Requirements***

## H.2.1.1 Examination Technique Specification Sheet



### **H.3 Performance Demonstration**

#### ***H.3.1 General***

#### ***H.3.2 Essential Variable Ranges***

### ***H.3.3 Requalification***

### ***H.3.4 Disqualification of Techniques***

## **H.4 Essential Variable Tolerances**

### ***H.4.1 Instruments and Probes***

#### **H.4.1.1 Cable**

#### H.4.1.2 Frequency/Material/Wall Thickness

#### H.4.1.3 Array Probe Sensing Area Coverage



#### ***H.4.2 Computerized System Algorithms***

#### ***H.4.3 Calibration Methods***

### **H.5 Record of Qualification**

## **Supplement H1 Equipment Characterization**

### **H1.1 Scope**

This supplement specifies essential variables associated with eddy current data acquisition instrumentation and establishes a protocol for essential variable measurement.

### **H1.2 Eddy Current Instrument**

#### ***H1.2.1 Signal Generation***

##### **H1.2.1.1 Total Harmonic Distortion**

##### **H1.2.1.2 Output Impedance**


## ***H1.2.2 Amplification, Demodulation and Filtering***

### **H1.2.2.1 Input Impedance**

### **H1.2.2.2 Amplifier Linearity and Stability**

**Figure H-1**

**H1.2.2.3 Phase Linearity**



#### H1.2.2.4 Bandwidth and Demodulation Filter Response

### ***H1.2.3 Analog-to-Digital Converter***

#### H1.2.3.1 Analog-to-Digital Resolution

H1.2.3.2      Dynamic Range

H1.2.3.3      Digitizing Rate

***H1.2.4Channel Crosstalk***

## **H1.3 Probe Characterization**

### ***H1.3.1 Impedance***

### ***H1.3.2 Center Frequency***

### ***H1.3.3 Coil Configuration Sensing Area***

#### **H1.3.3.1 Bobbin Probes**

##### ***H1.3.3.1.1 Effective Scan Field Width***

#### *H1.3.3.1.2 Fill Factor Coefficient*



#### *H1.3.3.1.3 Depth Coefficient*







#### *H1.3.3.1.4 Axial Length Coefficient*

#### *H1.3.3.1.5 Transverse Width Coefficient*

#### ***H1.3.3.1.6 Phase-to-Depth Curve***



#### ***H1.3.3.1.7 Direct Current Saturation Strength***



#### **H1.3.3.2 Rotating Probes**

##### ***H1.3.3.2.1 Effective Scan Field Width***

##### ***H1.3.3.2.2 Effective Track Field Width***


*H1.3.3.2.3 Lift-Off Value*



*H1.3.3.2.4 Depth Coefficient*



*H1.3.3.2.5 Axial Length Coefficient*



*H1.3.3.2.6 Transverse Width Coefficient*

*H1.3.3.2.7 Phase-to-Depth Curve*

*H1.3.3.3 Array Probes*

*H1.3.3.3.1 Effective Scan Field Width*

*H1.3.3.3.2 Diametral Off-Set Value*

*H1.3.3.3.3 Depth Coefficient*

*H1.3.3.3.4 Axial Length Coefficient*

*H1.3.3.3.5 Transverse Width Coefficient*

#### *H1.3.3.3.6 Phase-to-Depth Curve*

#### *H1.3.3.3.7 Tube Circumference Coverage*



## **Supplement H2 Qualification Requirements for Examination of Steam Generator Tubing**


### **H2.1 General**

SG tubing examination techniques and equipment used to detect and size flaws are qualified by performance demonstration.

### **H2.2 Qualification Data Set Requirements**


#### ***H2.2.1 General***

**Table H-1**



### ***H2.2.2 Detection Data Set***

**Table H-2**




### ***H2.2.3 Sizing Data Set***



## **H2.3 Acceptance Criteria**

### ***H2.3.1 Detection Acceptance Criteria***

### ***H2.3.2 Technique Sizing Performance***



## **Supplement H3**

### **Protocol for Performance Demonstration Database Revision**

#### **H3.1 Scope**

This supplement establishes the method to revise the Appendix G performance demonstration database (PDD). Revisions include additions/deletions of existing data, inclusion of new techniques or deletion of existing techniques.

#### **H3.2 Administrative Responsibilities**

##### ***H3.2.1 New Techniques***

##### ***H3.2.2 Existing Techniques***

#### **H3.3 Technique Originator Responsibilities**

### **H3.4 Performance Demonstration Database Curator Responsibilities**

### **H3.5 Performance Demonstration Database Peer Review Procedure**

#### ***H3.5.1 Team Structure***

#### ***H3.5.2 Conduct of the Review***

## **Supplement H4 Protocol for Technique Peer Review**

### **H4.1 Scope**

This supplement establishes the method and protocol for conducting industry peer reviews of Appendix H or J techniques.

### **H4.2 Administrative Responsibilities**

### **H4.3 Technique Originator Responsibilities**

### **H4.4 Examination Technique Specification Sheet Curator Responsibilities**

### **H4.5 Peer Review Procedure**

#### ***H4.5.1 Team Structure***

#### **H4.5.2 Conduct of the Review**

**I**

---



# **J**

## **PERFORMANCE DEMONSTRATION FOR ULTRASONIC EXAMINATION**

---

### **J.1 SCOPE**

- a. This appendix provides performance demonstration requirements for ultrasonic examination techniques and equipment for examination of steam generator (SG) tubing.

### **J.2 PERFORMANCE DEMONSTRATION**

#### **J.2.1 General**



**J.2.2 Essential Variable Ranges**

**J.2.3 Requalification**

**J.2.4 Disqualification of Techniques**

**J.3 ESSENTIAL VARIABLE TOLERANCES**

**J.3.1 Instruments and Search Units**

**J.3.2 Computerized System Algorithms**

**J.3.3 Calibration Methods**

**J.4 RECORD OF QUALIFICATION**

**J.4.1 Examination Technique Specification Sheet (ETSS)**



## **Supplement J1 Equipment Characterization**

### **J1.1 SCOPE**

This supplement specifies essential variables associated with ultrasonic data acquisition instrumentation and establishes a protocol for essential variable measurement.

### **J1.2 PULSERS, RECEIVERS, SEARCH UNIT, AND CABLE**

#### **J1.2.1 Search Unit**

##### ***J1.2.1.1 Transducer Wave Propagation Mode***

##### ***J1.2.1.2 Transducer Measured Angle***

##### ***J1.2.1.3 Search Unit Transducer Evaluation***

#### ***J1.2.1.4 Focused Search Units***


#### ***J1.2.1.5 Signal-to-Noise Ratio***

**J1.2.1.6 Confirmation**

**J1.2.1.7 Requirements for Pulse Echo Tip Diffraction Sizing Techniques**

**J1.2.2 Substituting a Pulser/Receiver or Ultrasonic Instrument**

**J1.2.3 Cable**



**J1.3 DOCUMENTATION AND REVIEW OF CHANGES**



## **Supplement J2**

### **Qualification Requirements for Examination of Steam Generator Tubing**

#### **J2.1 GENERAL**

SG tubing examination techniques and equipment used to detect and size flaws are qualified by performance demonstration. New industry qualified techniques shall meet the requirements of Supplement H4 for conduct of the peer review process. It is recommended that new site specific qualified techniques meet the intent of Supplement H4 for conduct of the peer review process by the developing organization.

#### **J2.2 QUALIFICATION DATA SET REQUIREMENTS**

##### **J2.2.1 General**



**Table J2-1**

**J2.2.2      Detection Data Set**

Table J2-2

**J2.2.3 Sizing Data Set**

## **J2.3      ACCEPTANCE CRITERIA**

### **J2.3.1      Detection Acceptance Criteria**



## J2.3.2      Technique Sizing Performance

DRAFT

CONFIDENTIAL - SECURITY INFORMATION

# **K**

## **QUALIFICATION OF PERSONNEL FOR ANALYSIS OF ULTRASONIC EXAMINATION DATA**

---

### **Scope**

This appendix specifies training and qualification requirements for personnel who analyze steam generator (SG) tubing ultrasonic examination data. Its purpose is to ensure a uniform knowledge base and skill level for ultrasonic data analysts. Analysts are qualified by successful completion of written and practical examinations as defined in this appendix.

**1.1 WRITTEN PRACTICE REQUIREMENTS**

**1.1.1 Training and Examination**

**1.1.2 Responsibilities**

**1.1.3 Use of an Outside Agency**


**1.1.4 Transfer Qualifications**

**1.1.5 Confidentiality**

**1.1.6 Availability of Training Course Materials**

## 1.2 QUALIFICATION REQUIREMENTS

Table K-1



### 1.2.1 Training



### 1.2.2 Written Examination





### **1.2.3      Practical Examination**

#### **1.2.3.1      *General***

#### **1.2.3.2      *Practical Data Set***

#### **1.2.3.3      *Analysis Qualification Criteria***

**Table K-2**





Table K-3



**1.3 RE-EXAMINATION**

**1.3.1 Written Examination**

**1.3.2 Practical Examination**

**1.4 INTERRUPTED SERVICE**

**1.5 REQUALIFICATION**

**1.6 SITE SPECIFIC PERFORMANCE DEMONSTRATION (SSPD)**

**1.6.1 SSPD Training**

**1.6.2 Written Examinations**

**1.6.3 Practical Examination**

**1.6.3.1 *Detection and Orientation***

**1.6.3.2 *Sizing***

**1.6.4 Retesting**

## Attachment K-1



