



- NOTES:
- FOR NOTES, SYMBOLS AND UNIT #2 ABBREVIATIONS SEE 26001 SH. 1, 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y11.
  - VALVES 2-SI-701A, 2-SI-702A THRU 2-SI-701D, 2-SI-702D, SHOULD BE LOCATED OUTSIDE THE SECONDARY SHIELD WALL AT EL. (+14')±AS CLOSE AS PRACTICAL TO A DRAIN.
  - CLOSE COIL REMOVED FROM MCC CONTACTOR WHEN UNIT IS IN MODES 1, 2, OR 3 (2-SI-614, 2-SI-624, 2-SI-634 & 2-SI-644)
  - PORTIONS OF LINE HCD-31(S.I. TEST HEADER) WAS UPGRADED TO SEISMIC CLASS 1 PER PDCR 2-222-76. THE UPGRADED PORTIONS OF THE LINE TO SEISMIC CLASS 1 ARE NOW REFLECTED AS HCD-31C1

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 13

**FSAR FIGURE**  
SAFETY EVALUATION MAY BE REQUIRED PRIOR TO CHANGES

**CAD**  
NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REVISIONS DURING CONSTRUCTION		
NO.	DATE	REVISIONS

**OPERATIONS CRITICAL**  
SUPERSEDES 25203-26015 THRU REV. 19

**Dominion Nuclear Connecticut, Inc.**  
Millstone Power Station

TITLE  
MILLSTONE NUCLEAR POWER STATION - UNIT 2  
PIPING AND INSTRUMENTATION DIAGRAM  
SAFETY INJECTION TANKS  
WATERFORD, CT

BY	DATE	CHKD.	APP.	DATE	CHKD.	APP.	DATE	CHKD.	APP.
N/A	24	5-28-03	INC. DCN DM2-00-0150-02	DWJ	MP	DLW	DEB	BY	M. 00151
N/A	23	5-24-02	INC. DCN DM2-00-0545-01	BLM	TP	SBK	CAM	SCALE	NONE
NO.	DATE	REVISIONS	BY	CHK.	APP.	APP.	APP.	84-024	25203-26015 SH. 3 OF 3