



NOTES:

- FOR NOTES, SYMBOLS AND UNIT 2 ABBREVIATIONS SEE 26001 SH.1, 2, & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STD. 11.1.
- RAD WASTE LINES DESIGNATED AS HSC-35, HSC-75, HSC-113 AND HSC-117 AS SHOWN ON THIS DRAWING ARE NOT PART OF THE ISI PROGRAM. RAD WASTE LINES DESIGNATED AS HSC-35, -75, -113, AND -117 WHICH ARE ASME SECTION III CODE CLASS 3 LINES AS SHOWN ON THIS DRAWING ARE DOWNGRADED TO ANSI B31.1 PER REG. GUIDE 1.143 REV. 1. DESIGN GUIDANCE FOR RADIOACTIVE WASTE MANAGEMENT SYSTEMS, STRUCTURES, AND COMPONENTS INSTALLED IN LIGHT WATER NUCLEAR POWER PLANTS. PIPE CLASSES FOR THE LINE NUMBERS WILL REMAIN THE SAME FOR HISTORICAL PURPOSES. ALL NEW PIPING SHALL BE INSTALLED TO THE APPLICABLE ANSI B31.1 PIPE CLASS, WITH A (R) FORTH LETTER CODE FOR RAD WASTE QA PER DCM 02-00-0216-03.
- EQUIPMENT ELECTRICALLY RETIRED.

FSAR FIGURE

SAFETY EVALUATION  
MAYBE REQUIRED  
PRIOR TO CHANGES

OPERATIONS CRITICAL

Q.A.

SUPERSEDES 25203-26017 THRU REV 20

NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REVISIONS DURING CONSTRUCTION

NO.	DATE	REVISIONS	BY	CHKD.	APP.	CU	JGR	APP.	SBR
33	5-16-05	INCORP. DCM 02-00-0355-04	JSJ	MP	WBZ	DED			
32	5-13-05	INC. DCM 02-00-0138-04	EAL	ASK	WBZ	MP			
31	8-28-03	INC. DCM 02-00-0216-03	EAL	CSJ	DLW	DED			
30	5-24-02	INC. DCM 02-00-0546-01	BLM	TP	SBB	CAM			
29	3-21-02	INCORP. DCM 02-00-0729-00	JSJ	MBR	RFL	DED			

BY CHK. APP. APP.

84-024

DATE 10-14-86

DATE 4-13-87

DATE 4-13-87

SCALE NONE

DWG. NO.

25203-26017 SH. 2 OF 3

33

REV

Dominion Nuclear Connecticut, Inc.

Millstone Power Station

TITLE

MILLSTONE NUCLEAR POWER STATION-UNIT 2  
PIPING & INSTRUMENTATION DIAGRAM  
DEBORATING & PURIFICATION SYSTEM  
WATERFORD, CT

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 15