



NOTES:
1. FOR GENERAL NOTES AND REFERENCE DRAWINGS SEE EM-102A (26902 SH 11).
2. DELETED
3. RUPTURE DISCS, 3RCS-PSE37 AND 3RCS-PSE38, ARE SET AT A NOMINAL VALUE OF 31 PSIG WITH A RANGE OF 86 TO 100 PSIG AT 200°F. REFER TO EDS-AT-002 WHICH WAS TRANSMITTED VIA LETTER NEU-1895. REFERENCE DCN DM3-00-1029-97.
4. VALVE IS INSTALLED WITH FLOW OVER THE DISC.

NUCLEAR SAFETY RELATED
QA CAT. I, II

FSAR FIGURE
OPERATIONS CRITICAL

| REV. | DATE | DESCRIPTION | BY | CHK | CORR | APP |
|-------------------------------|------|-------------|----|-----|------|-----|
| REVISIONS DURING CONSTRUCTION | | | | | | |
| P.A. NO. | | | | | | |

| | | | | | | | | |
|-------|--|-----|----------|---|-----|------|------|-----|
| N/A | | 16 | 11-7-05 | INCORP. DCN DM3-00-0460-05 | SMC | MP | DLW | DED |
| N/A | | 15 | 2-25-04 | INCORP. DCN DM3-00-0013-04 | EAL | MP | DLW | DED |
| N/A | | 14 | 10-13-99 | INCORP. DCN DM3-00-0961-98 | KF | RFL | AJS | AGR |
| N/A | | 13 | 3-10-99 | INCORP. DCN DM3-00-1072-98 | KF | CSJ | AJS | MP |
| N/A | | 12 | 1-7-99 | INCORP. DCN DM3-00-0749-98 | KF | MP | AJS | RFL |
| N/A | | 11 | 7-28-98 | INCORP. DCN DM3-00-0682-98 | KF | RJK | RFL | RFL |
| N/A | | 10 | 1-6-98 | INCORP. DCN DM3-00-1905-97 | KF | RFL | AJS | MP |
| N/A | | 9 | 10-29-97 | INCORP. DCN'S DM3-00-1029-97 & DM3-00-0941-97 | AC | MP | PAM | PAM |
| P.A.* | | NO. | DATE | REVISIONS | | | | |
| | | | | BY | CHK | CORR | APP. | |

S&W DWG. NO. 12179-EM-102F