

August 25, 2006

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF CONFERENCE CALL ON AUGUST 1, 2006 WITH ENTERGY NUCLEAR OPERATIONS, INC., ON POTENTIAL TIME LIMITED AGING ANALYSIS QUESTIONS ON THE PILGRIM LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission staff conducted a conference call with Entergy Nuclear Operations, Inc. (Entergy or the applicant), on potential time-limited aging analysis (TLAA) questions on the Pilgrim License Renewal Application (LRA). The conference call was conducted on Tuesday, August 1, 2006, between 12:30 p.m. and 1:30 p.m. at 11555 Rockville Pike, Rockville, MD 20852. The list of participants is shown in the enclosure. The following is a summary of the meeting.

The Project Manager for the LRA provided an introduction and said that there were a few remaining questions from the staff's previous Generic Aging Lessons Learned audit conducted at the applicant site during May - July, 2006. These were related to the following three unresolved audit questions that could become potential TLAA's: (i) Control rod drive nozzle-to-end cap weld, (ii) Reactor recirculation nozzle thermal sleeves, and (iii) N2F reactor recirculation nozzle. At the end of the conference call it was resolved that with the exception of item (ii), the other two items were TLAA's. It was decided during the call that a request for additional information would follow in the future.

The applicant had an opportunity to comment on the meeting summary.

/RA/

Ram Subbaratnam, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure:
List of Participants

cc w/encl: See next page

August 25, 2006

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF CONFERENCE CALL ON AUGUST 1, 2006 WITH ENTERGY NUCLEAR OPERATIONS, INC., ON POTENTIAL TIME LIMITED AGING ANALYSIS QUESTIONS ON THE PILGRIM LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission staff conducted a conference call with Entergy Nuclear Operations, Inc. (Entergy or the applicant), on potential time-limited aging analysis (TLAA) questions on the Pilgrim License Renewal Application (LRA). The conference call was conducted on Tuesday, August 1, 2006, between 12:30 p.m. and 1:30 p.m. at 11555 Rockville Pike, Rockville, MD 20852. The list of participants is shown in the enclosure. The following is a summary of the meeting.

The Project Manager for the LRA provided an introduction and said that there were a few remaining questions from the staff's previous Generic Aging Lessons Learned audit conducted at the applicant site during May - July, 2006. These were related to the following three unresolved audit questions that could become potential TLAA's: (i) Control rod drive nozzle-to-end cap weld, (ii) Reactor recirculation nozzle thermal sleeves, and (iii) N2F reactor recirculation nozzle. At the end of the conference call it was resolved that with the exception of item (ii), the other two items were TLAA's. It was decided during the call that a request for additional information would follow in the future.

The applicant had an opportunity to comment on the meeting summary.

/RA/

Ram Subbaratnam, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure:
List of Participants

cc w/encl: See next page

ADAMS Accession No.: ML062410379

E:\Filenet\ML062410379.wpd

OFFICE	PM:RLRA:DLR	PM:RLRC:DLR	LA:DLR	BC:REBB:DLR
NAME	RSubbaratnam	JDavis	YEdmonds	LLund
DATE	8/ 24 /06	8/ 24 /06	8/ 24 /06	8/ 25 /06

OFFICIAL RECORD COPY

Conference Call Summary dated August 25, 2006

SUBJECT: SUMMARY OF A CONFERENCE CALL WITH ENTERGY NUCLEAR
OPERATIONS, INC., ON POTENTIAL TIME LIMITED AGING ANALYSIS
QUESTIONS ON PILGRIM LICENSE RENEWAL APPLICATION
(TAC NO. MC9669)

HARD COPY

DLR R/F

E-MAIL:

JFair
RWeisman
AMurphy
RPettis
GGalletti
DShum
GBagchi
SSmith (srs3)
SDuraiswamy
YL (Renee) Li
RidsNrrDlr
RidsNrrDlrRlra
RidsNrrDlrRlrb
RidsNrrDe
RidsNrrDci
RidsNrrEemb
RidsNrrDeEeeb
RidsNrrDeEqva
RidsNrrDss
RidsNrrDnrl
RidsOgcMailCenter
RidsNrrAdes
DLR Staff

RSubbaratnam
SHoffman
SUttal
JShea
JDavis
CAnderson, Region 1
WRaymond, Region 1
NSheehan, Region 1

Pilgrim Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, MA 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, MA 02360

Chairman
Nuclear Matters Committee
Town Hall
11 Lincoln Street
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen
Town Hall
878 Tremont Street
Duxbury, MA 02332

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, MA 02108

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

MA Department of Public Health
Radiation Control Program
Schrafft Center, Suite 1M2A
529 Main Street
Charlestown, MA 02129

Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, MA 02108

Director, Massachusetts Emergency
Management Agency
Attn: James Muckerheide
400 Worcester Road
Framingham, MA 01702-5399

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056-0426

Mr. Michael A. Balduzzi
Site Vice President
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Stephen J. Bethay
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Bryan S. Ford
Manager, Licensing
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

cc:

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Oscar Limpias
Vice President, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwarz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. James Sniezek
5486 Nithsdale Drive
Salisbury, MD 21801

Mr. Travis C. McCullough
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Ross
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Plymouth Public Library
Attn: Dinah O'Brien
132 South Street
Plymouth, MA 02360

Duxbury Free Library
ATTN: Ms. Elaine Winquist
77 Alden Street
Duxbury, MA 02332

Kingston Public Library
ATTN: Reference Librarian
6 Green Street
Kingston, MA 02364

Ms. Mary Lampert
Duxbury Nuclear Advisory, Chair
Pilgrim Watch, Director
148 Washington Street
Duxbury, MA 02332

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL
TO DISCUSS THE PILGRIM NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION**

August 1, 2006

PARTICIPANTS

Ram Subbaratnam
James Davis
Peter Wen
Dan Hoang
Kenneth Chang
James Medoff
Ganesh Cheruvenki
Simon Scheng
Bryan Ford
Fred Mogolesko
Laris Chan
Erac Patel
Doug Ellis

AFFILIATION

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NRC
NRC
NRC
NRC
NRC
Entergy Nuclear Operations, Inc. (Entergy)
Entergy
Entergy
ATL
Entergy

ENCLOSURE