

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 145 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- (3) Southern Nuclear Operating Company shall be capable of establishing containment hydrogen monitoring within 90 minutes of initiating safety injection following a loss of coolant accident.

(4) DELETED

(5) DELETED

(6) DELETED

(7) DELETED

(8) DELETED

(9) DELETED

(10) Additional Conditions

The Additional Conditions contained in Appendix D, as revised through Amendment No. 102, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Additional Conditions.

- D. The facility requires exemptions from certain requirements of 10 CFR Part 50 and 10 CFR Part 70. These include (a) an exemption from the requirements of 10 CFR 70.24 for two criticality monitors around the fuel storage area, and (b) an exemption from the requirements of Paragraph III.D.2(b)(ii) of Appendix J of 10 CFR 50, the testing of containment air locks at times when containment integrity is not required. The special circumstances regarding exemption b are identified in Section 6.2.6 of SSER 5.

An exemption was previously granted pursuant to 10 CFR 70.24. The exemption was granted with NRC materials license No. SNM-1967, issued August 21, 1986, and relieved GPC from the requirement of having a criticality alarm system. GPC and Southern Nuclear are hereby exempted from the criticality alarm system provision of 10 CFR 70.24 so far as this section applies to the storage of fuel assemblies held under this license.

These exemptions are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. The exemptions in items b and c above are granted pursuant to 10CFR 50.12. With

- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect, and is subject to the additional conditions specified or incorporated below.

(1) Maximum Power Level

Southern Nuclear is authorized to operate the facility at reactor core power levels not in excess of 3565 megawatts thermal (100 percent power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 125 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

The Surveillance Requirements (SRs) contained in the Appendix A Technical Specifications and listed below are not required to be performed immediately upon implementation of Amendment No. 74. The SRs listed below shall be successfully demonstrated prior to the time and condition specified below for each:

- a) DELETED
 - b) DELETED
 - c) SR 3.8.1.20 shall be successfully demonstrated at the first regularly scheduled performance after implementation of this license amendment.
- (3) Southern Nuclear Operating Company shall be capable of establishing containment hydrogen monitoring within 90 minutes of initiating safety injection following a loss of coolant accident.
- (4) Additional Conditions

The Additional Conditions contained in Appendix D, as revised through Amendment No. 80, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Additional Conditions.

- D. The facility requires exemptions from certain requirements of 10 CFR Part 50 and 10 CFR Part 70. These include (a) an exemption from the requirements of 10 CFR 70.24 for two criticality monitors around the fuel storage area, and (b) an exemption from the requirements of Paragraph III.D.2(b)(ii) of Appendix J of 10 CFR 50, the testing of containment air locks at times when containment integrity is not required. The special circumstances regarding exemption b are identified in Section 6.2.6 of SSER 8.

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
R. One or more channels inoperable.	R.1 Verify interlock is in required state for existing unit conditions.	1 hour
	<u>OR</u> R.2 Be in MODE 3.	7 hours
S. One or more channels inoperable.	S.1 Verify interlock is in required state for existing unit conditions.	1 hour
	<u>OR</u> S.2 Be in MODE 2.	7 hours
T. One RTB train inoperable.	-----NOTE----- One train may be bypassed for up to 4 hours for surveillance testing, provided the other train is OPERABLE.	
	T.1 Restore train to OPERABLE status.	24 hours
	<u>OR</u> T.2 Be in MODE 3.	30 hours

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.4	<p>-----NOTE-----</p> <p>This Surveillance must be performed on the reactor trip bypass breaker prior to placing the bypass breaker in service.</p> <p>-----</p> <p>Perform TADOT.</p>	62 days on a STAGGERED TEST BASIS
SR 3.3.1.5	Perform ACTUATION LOGIC TEST.	92 days on a STAGGERED TEST BASIS
SR 3.3.1.6	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Not required to be performed until 7 days after THERMAL POWER is $\geq 75\%$ RTP. 2. Neutron detectors are excluded from CHANNEL CALIBRATION. <p>-----</p> <p>Calibrate excore channels to agree with incore detector measurements.</p>	92 EFPD
SR 3.3.1.7	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. For the Source Range Instrumentation this surveillance shall include verification that interlocks P-6 and P-10 are in their required state for existing unit conditions. 2. Not required to be performed for Source Range Instrumentation prior to entering MODE 3 from MODE 2 until 4 hours after entry into MODE 3. <p>-----</p> <p>Perform COT.</p>	184 days

(continued)

SURVEILLANCE REQUIREMENTS

NOTE

Refer to Table 3.3.2-1 to determine which SRs apply for each ESFAS Function.

SURVEILLANCE		FREQUENCY
SR 3.3.2.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.2.2	Perform ACTUATION LOGIC TEST.	92 days on a STAGGERED TEST BASIS
SR 3.3.2.3	Perform MASTER RELAY TEST.	92 days on a STAGGERED TEST BASIS
SR 3.3.2.4	Perform COT.	184 days
SR 3.3.2.5	Perform SLAVE RELAY TEST.	18 months
SR 3.3.2.6	-----NOTE----- Verification of setpoint not required for manual initiation functions.	18 months
	Perform TADOT.	

(continued)

SURVEILLANCE REQUIREMENTS

-----NOTE-----

Refer to Table 3.3.6-1 to determine which SRs apply for each Containment Purge and Exhaust Isolation Function.

SURVEILLANCE		FREQUENCY
SR 3.3.6.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.6.2	Perform ACTUATION LOGIC TEST.	92 days on a STAGGERED TEST BASIS
SR 3.3.6.3	Perform MASTER RELAY TEST.	92 days on a STAGGERED TEST BASIS
SR 3.3.6.4	Perform COT.	92 days
SR 3.3.6.5	Perform SLAVE RELAY TEST.	18 months
SR 3.3.6.6	-----NOTE----- Verification of setpoint not required. -----	18 months
	Perform TADOT.	
SR 3.3.6.7	Perform CHANNEL CALIBRATION.	18 months
SR 3.3.6.8	Verify RESPONSE TIMES are within limits.	18 months on a STAGGERED TEST BASIS

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
<p>-----NOTE----- Not required to be performed prior to entering MODE 3 from MODE 2 until 4 hours after entry into MODE 3.</p>		
SR 3.3.8.1	Perform COT.	184 days
SR 3.3.8.2	Perform CHANNEL CALIBRATION.	18 months