

From: Mohan Thadani
To: Internet:dbuschb1@txu.com; Internet:fred.madden@txu.com
Date: 7/6/2006 10:23:57 AM
Subject: Preliminary Request for Additional Information- TAC Numbers MC9500 and MC9501

Fred/Denny:

The NRC staff has reviewed the TXU Generation Company LP's request for amendments, dated February 21, 2005, revising the Technical Specifications to reflect the replacement of Steam Generators. The staff has identified the following preliminary request for additional information. I will appreciate your assistance in providing your response to the following questions in a timely manner.

Please let me know, by an email, when the TXU Generation Company LP will be able to respond. Also, let me know if you need a formal letter for this request. I will then promptly process a formal letter for this request.

Thank you for your cooperation.

Mohan
301 415-1476

PRELIMINARY REQUEST FOR ADDITIONAL INFORMATION
LICENSE AMENDMENT REQUEST 05-08
REVISION TO TECHNICAL SPECIFICATIONS FOR
NOMINAL TRIP SETPOINTS AND AV SETPOINTS FOR SG WATER
LEVEL LOW-LOW AND HIGH-HIGH
COMANCHE PEAK STEAM ELECTRIC STATION UNITS 1 AND 2
TXU GENERATION COMPANY, LP
TAC NOS. MD0187 AND MD0188

By letter dated February 21, 2006, the licensee of the Comanche Peak Steam Electric Station proposed to revise the nominal trip setpoints (NTS) and Allowable Values (AV) of setpoints for steam generator (SG) water level low-low and high-high. The changes are applicable to the replacement SGs in Unit 1. The licensee indicated that the changes had included the SG water level measurement uncertainties discussed in Westinghouse Nuclear Safety Advisory Letters (NSALs).

NSAL-02-3 and its revision dealt with the uncertainty in the SG water level measurement caused by the placement of mid-deck plate between the upper and lower pressure taps. NSAL-02-4 dealt with uncertainties in the measurement created because the void content of the two-phase mixture above the mid-deck plate was not reflected in typical setpoint calculations. NSAL-02-5 dealt with potential inaccuracies in the initial conditions assumed in safety analysis affected by SG water level. NSAL-03-9 discussed a program for Westinghouse Owners' Group that evaluated the effects on the SG water level control system uncertainties from various items, including the mid-deck plate, feedwater ring and feedwater ring supports, lower-deck plate supports, on-recoverable losses due to carryunder, decrease in subcooling due to carryunder, and transient conditions due to event such as single loop loss of normal feedwater, etc..

(a) Please discuss how the specific plant accounted for the applicable uncertainties documented in the above Westinghouse NSALs in determining the SG water level (low-low and high-high) NTS and AV setpoints.

(b) Please discuss the results of non-LOCA transients that were analyzed to determine uncertainties for the SG water level low-low and high-high setpoints. Identify and justify the limiting cases used to determine the proposed NTS and AV setpoints. The discussion should include a description of the methods or computer codes used in the analysis, and demonstrate

the appropriateness of the methods and codes used.

(c) Please provide the actual calculations or the results of summary sheets for the proposed NTS and AV setpoints.

CC: Nakoski, John; Reyes-Maldonado, Ruth; Sun, Summer

Mail Envelope Properties (45080639.B3F : 23 : 35106)

Subject: Fwd: Preliminary Request for Additional Information- TAC Numbers
MC9500 and MC9501
Creation Date 9/13/2006 9:23:05 AM
From: Mohan Thadani
Created By: MCT@nrc.gov

Recipients

nrc.gov
OWGWPO01.HQGWDO01
JCB2 (Janet Burkhardt)

Post Office

OWGWPO01.HQGWDO01

Route

nrc.gov

Files	Size	Date & Time
MESSAGE	5052	9/13/2006 9:23:05 AM

Options

Expiration Date:	None
Priority:	Standard
ReplyRequested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

Junk Mail Handling Evaluation Results

Message is not eligible for Junk Mail handling
Message is from an internal sender

Junk Mail settings when this message was delivered

Junk Mail handling disabled by User
Junk Mail handling disabled by Administrator
Junk List is not enabled
Junk Mail using personal address books is not enabled
Block List is not enabled