

- (3) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source, and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (4) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source, or special nuclear material without restriction to chemical or physical form for sample analysis or equipment and instrument calibration or associated with radioactive apparatus or components;
- (5) Pursuant to the Act and 10 CFR Parts 30 and 70, to possess but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 3293 megawatts thermal.

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 258, are hereby incorporated in the renewed operating license. The licensee shall operate the facility in accordance with the Technical Specifications.

For Surveillance Requirements (SRs) that are new in Amendment 234 to Facility Operating License DPR-33, the first performance is due at the end of the first surveillance interval that begins at implementation of the Amendment 234. For SRs that existed prior to Amendment 234, including SRs with modified acceptance criteria and SRs whose frequency of performance is being extended, the first performance is due at the end of the first surveillance interval that begins on the date the surveillance was last performed prior to implementation of Amendment 234.

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
d. Downscale	1	2	F	SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.14	≥ 3% RTP
e. Inop	1,2	2	G	SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.14	NA
3. Reactor Vessel Steam Dome Pressure - High ^(d)	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.8 SR 3.3.1.1.10 SR 3.3.1.1.14	≤ 1055 psig
4. Reactor Vessel Water Level - Low, Level 3 ^(d)	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.8 SR 3.3.1.1.13 SR 3.3.1.1.14	≥ 528 inches above vessel zero
5. Main Steam Isolation Valve - Closure	1	8	F	SR 3.3.1.1.8 SR 3.3.1.1.13 SR 3.3.1.1.14	≤ 10% closed
6. Drywell Pressure - High	1,2	2	G	SR 3.3.1.1.8 SR 3.3.1.1.13 SR 3.3.1.1.14	≤ 2.5 psig
7. Scram Discharge Volume Water Level - High					
a. Resistance Temperature Detector	1,2	2	G	SR 3.3.1.1.8 SR 3.3.1.1.13 SR 3.3.1.1.14	≤ 50 gallons
	5(a)	2	H	SR 3.3.1.1.8 SR 3.3.1.1.13 SR 3.3.1.1.14	≤ 50 gallons

(continued)

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

(d) During instrument calibrations, if the As Found channel setpoint is conservative with respect to the Allowable Value but outside its acceptable As Found band as defined by its associated Surveillance Requirement procedure, then there shall be an initial determination to ensure confidence that the channel can perform as required before returning the channel to service in accordance with the Surveillance. If the As Found instrument channel setpoint is not conservative with respect to the Allowable Value, the channel shall be declared inoperable.

Prior to returning a channel to service, the instrument channel setpoint shall be calibrated to a value that is within the acceptable As Left tolerance of the setpoint; otherwise, the channel shall be declared inoperable.

The nominal Trip Setpoint shall be specified on design output documentation which is incorporated by reference in the Updated Final Safety Analysis Report. The methodology used to determine the nominal Trip Setpoint, the predefined As Found Tolerance, and the As Left Tolerance band, and a listing of the setpoint design output documentation shall be specified in Chapter 7 of the Updated Final Safety Analysis Report.

Table 3.3.5.1-1 (page 5 of 6)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
4. ADS Trip System A (continued)					
b. Drywell Pressure - High ^(e)	1, 2(d), 3(d)	2	F	SR 3.3.5.1.2 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 2.5 psig
c. Automatic Depressurization System Initiation Timer	1, 2(d), 3(d)	1	G	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 115 seconds
d. Reactor Vessel Water Level - Low, Level 3 (Confirmatory) ^(e)	1, 2(d), 3(d)	1	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 528 inches above vessel zero
e. Core Spray Pump Discharge Pressure - High	1, 2(d), 3(d)	4	G	SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 175 psig and ≤ 195 psig
f. Low Pressure Coolant Injection Pump Discharge Pressure - High	1, 2(d), 3(d)	8	G	SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 90 psig and ≤ 110 psig
g. Automatic Depressurization System High Drywell Pressure Bypass Timer	1, 2(d), 3(d)	2	G	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 322 seconds
5. ADS Trip System B					
a. Reactor Vessel Water Level - Low Low Low, Level 1 ^(e)	1, 2(d), 3(d)	2	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 398 inches above vessel zero
b. Drywell Pressure - High ^(e)	1, 2(d), 3(d)	2	F	SR 3.3.5.1.2 SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 2.5 psig

(continued)

(d) With reactor steam dome pressure > 150 psig.

(e) During instrument calibrations, if the As Found channel setpoint is conservative with respect to the Allowable Value but outside its acceptable As Found band as defined by its associated Surveillance Requirement procedure, then there shall be an initial determination to ensure confidence that the channel can perform as required before returning the channel to service in accordance with the Surveillance. If the As Found instrument channel setpoint is not conservative with respect to the Allowable Value, the channel shall be declared inoperable.

Prior to returning a channel to service, the instrument channel setpoint shall be calibrated to a value that is within the acceptable As Left tolerance of the setpoint; otherwise, the channel shall be declared inoperable.

The nominal Trip Setpoint shall be specified on design output documentation which is incorporated by reference in the Updated Final Safety Analysis Report. The methodology used to determine the nominal Trip Setpoint, the predefined As Found Tolerance, and the As Left Tolerance band, and a listing of the setpoint design output documentation shall be specified in Chapter 7 of the Updated Final Safety Analysis Report.

Table 3.3.5.1-1 (page 6 of 6)
Emergency Core Cooling System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. ADS Trip System B (continued)					
c. Automatic Depressurization System Initiation Timer	1, 2(d), 3(d)	1	G	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 115 seconds
d. Reactor Vessel Water Level - Low, Level 3 (Confirmatory) ^(e)	1, 2(d), 3(d)	1	F	SR 3.3.5.1.1 SR 3.3.5.1.2 SR 3.3.5.1.5 SR 3.3.5.1.6	≥ 528 inches above vessel zero
e. Core Spray Pump Discharge Pressure - High	1, 2(d), 3(d)	4	G	SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 175 psig and ≤ 195 psig
f. Low Pressure Coolant Injection Pump Discharge Pressure - High	1, 2(d), 3(d)	8	G	SR 3.3.5.1.2 SR 3.3.5.1.3 SR 3.3.5.1.6	≥ 90 psig and ≤ 110 psig
g. Automatic Depressurization System High Drywell Pressure Bypass Timer	1, 2(d), 3(d)	2	G	SR 3.3.5.1.5 SR 3.3.5.1.6	≤ 322 seconds

(d) With reactor steam dome pressure > 150 psig.

(e) During instrument calibrations, if the As Found channel setpoint is conservative with respect to the Allowable Value but outside its acceptable As Found band as defined by its associated Surveillance Requirement procedure, then there shall be an initial determination to ensure confidence that the channel can perform as required before returning the channel to service in accordance with the Surveillance. If the As Found instrument channel setpoint is not conservative with respect to the Allowable Value, the channel shall be declared inoperable.

Prior to returning a channel to service, the instrument channel setpoint shall be calibrated to a value that is within the acceptable As Left tolerance of the setpoint; otherwise, the channel shall be declared inoperable.

The nominal Trip Setpoint shall be specified on design output documentation which is incorporated by reference in the Updated Final Safety Analysis Report. The methodology used to determine the nominal Trip Setpoint, the predefined As Found Tolerance, and the As Left Tolerance band, and a listing of the setpoint design output documentation shall be specified in Chapter 7 of the Updated Final Safety Analysis Report.

Primary Containment Isolation Instrumentation

3.3.6.1

Table 3.3.6.1-1 (page 1 of 3)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Main Steam Line Isolation					
a. Reactor Vessel Water Level - Low Low Low, Level 1	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 398 inches above vessel zero
b. Main Steam Line Pressure - Low(c)	1	2	E	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 825 psig
c. Main Steam Line Flow - High	1,2,3	2 per MSL	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 140% rated steam flow
d. Main Steam Tunnel Temperature - High	1,2,3	8	D	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 200°F
2. Primary Containment Isolation					
a. Reactor Vessel Water Level - Low, Level 3	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 528 inches above vessel zero
b. Drywell Pressure - High	1,2,3	2	G	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 2.5 psig
3. High Pressure Coolant Injection (HPCI) System Isolation					
a. HPCI Steam Line Flow - High	1,2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 90 psi
b. HPCI Steam Supply Line Pressure - Low	1,2,3	3	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 100 psig
c. HPCI Turbine Exhaust Diaphragm Pressure - High	1,2,3	3	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 20 psig

(continued)

- (c) During instrument calibrations, if the As Found channel setpoint is conservative with respect to the Allowable Value but outside its acceptable As Found band as defined by its associated Surveillance Requirement procedure, then there shall be an initial determination to ensure confidence that the channel can perform as required before returning the channel to service in accordance with the Surveillance. If the As Found instrument channel setpoint is not conservative with respect to the Allowable Value, the channel shall be declared inoperable.

Prior to returning a channel to service, the instrument channel setpoint shall be calibrated to a value that is within the acceptable As Left tolerance of the setpoint; otherwise, the channel shall be declared inoperable.

The nominal Trip Setpoint shall be specified on design output documentation which is incorporated by reference in the Updated Final Safety Analysis Report. The methodology used to determine the nominal Trip Setpoint, the predefined As Found Tolerance, and the As Left Tolerance band, and a listing of the setpoint design output documentation shall be specified in Chapter 7 of the Updated Final Safety Analysis Report.

Primary Containment Isolation Instrumentation 3.3.6.1

Table 3.3.6.1-1 (page 3 of 3)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Reactor Water Cleanup (RWCU) System Isolation					
a. Main Steam Valve Vault Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.6	≤ 201°F
b. Pipe Trench Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.6	≤ 135°F
c. Pump Room A Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.6	≤ 152°F
d. Pump Room B Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.6	≤ 152°F
e. Heat Exchanger Room Area (West Wall) Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.6	≤ 143°F
f. Heat Exchanger Room Area (East Wall) Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.6	≤ 170°F
g. SLC System Initiation	1,2	1(a)	H	SR 3.3.6.1.6	NA
h. Reactor Vessel Water Level - Low, Level 3	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 528 inches above vessel zero
6. Shutdown Cooling System Isolation					
a. Reactor Steam Dome Pressure - High	1,2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 115 psig
b. Reactor Vessel Water Level - Low, Level 3	3,4,5	2(b)	I	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 528 inches above vessel zero
c. Drywell Pressure - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 2.5 psig

(a) One SLC System Initiation signal provides logic input to close both RWCU valves.

(b) Only one channel per trip system required in MODES 4 and 5 when RHR Shutdown Cooling System integrity maintained.

Secondary Containment Isolation Instrumentation 3.3.6.2

Table 3.3.6.2-1 (page 1 of 1)
Secondary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level - Low, Level 3	1,2,3, (a)	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4	≥ 528 inches above vessel zero
2. Drywell Pressure - High	1,2,3	2	SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4	≤ 2.5 psig
3. Reactor Zone Exhaust Radiation - High	1,2,3, (a)	1	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4	≤ 100 mR/hr
4. Refueling Floor Exhaust Radiation - High	1,2,3, (a)	1	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4	≤ 100 mR/hr

(a) During operations with a potential for draining the reactor vessel.

Table 3.3.7.1-1 (page 1 of 1)
Control Room Emergency Ventilation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level - Low, Level 3	1,2,3,(a)	2	B	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.5 SR 3.3.7.1.6	≥ 528 inches above vessel zero
2. Drywell Pressure - High	1,2,3	2	B	SR 3.3.7.1.2 SR 3.3.7.1.5 SR 3.3.7.1.6	≤ 2.5 psig
3. Reactor Zone Exhaust Radiation - High	1,2,3 (a)	1	C	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.5 SR 3.3.7.1.6	≤ 100 mR/hr
4. Refueling Floor Exhaust Radiation - High	1,2,3, (a)	1	C	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.5 SR 3.3.7.1.6	≤ 100 mR/hr
5. Control Room Air Supply Duct Radiation - High	1,2,3, (a)	1	D	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.3 SR 3.3.7.1.4	≤ 270 cpm above background

(a) During operations with a potential for draining the reactor vessel.