

From: Peter Tam
To: Scarpello, Michael; Simpson, Sue; Waters, Joe
Date: 09/25/2006 3:11:28 PM
Subject: Draft RAI re. DC Cook's Response to GL 2003-01, Control Room Habitability (TAC MB9794, 5)

Mike, Joe:

We are reviewing your 12/4/03 submittal on this GL, and identified the following need for information:

Generic Letter 2003-01 requested confirmation that your facility's control room meets the applicable habitability regulatory requirements and that it is designed, constructed, configured, operated, and maintained in accordance with the facility's design and licensing bases. The Generic Letter further states that emphasis should be placed on confirming that the most limiting unfiltered inleakage into your CRE (and the filtered inleakage if applicable) is no more than the value assumed in your design-basis radiological analyses and hazardous chemical assessments, and requested that you describe how and when you performed the analyses, tests, and measurements for this confirmation. In your 12/4/03 response, you reported the results of your unfiltered inleakage test which you performed using the 1993 edition of ASTM E741 test method, rather than the 2000 edition endorsed by the NRC Regulatory Guide 1.197, Regulatory Position 1.1. In order for the NRC staff to evaluate the acceptability of the results from your alternative test method, the NRC staff requests that you submit the information listed in RG 1.197, Regulatory Position 1.3 that you have not included in your 12/4/03 response. The NRC staff is particularly interested in correlations of results of the 1993 method with a test performed with a methodology described in 2000 edition of the ASTM E471.

This e-mail aims solely to prepare you and others for a proposed conference call. **This e-mail does not formally request for additional information, nor does it convey an official NRC staff position.** Please call me after 10/2/06 to schedule the proposed conference call.
Thanks.

Peter S. Tam, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

e-mail: pst@nrc.gov Tel.: 301-415-1451

CC: Getachew Tesfaye

Mail Envelope Properties

(451829E0.C5C : 12 : 35330)

Subject: Draft RAI re. DC Cook's Response to GL 2003-01, Control Room Habitability (TAC MB9794, 5)
Creation Date 09/25/2006 3:11:28 PM
From: Peter Tam

Created By: PST@nrc.gov

Recipients
aep.com
PM
jrwaters (Joe Waters)

Action
Transferred

Date & Time
09/25/2006 3:12:09

mkscarpello (Michael Scarpello)
sdsimpson (Sue Simpson)

nrc.gov		
TWGWPO02.HQGWDO01	Delivered	09/25/2006 3:11:28
PM		
GXT2 CC (Getachew Tesfaye)	Opened	09/25/2006 3:19:40
PM		

Post Office

TWGWPO02.HQGWDO01

Delivered

09/25/2006 3:11:28 PM
nrc.gov

Route

aep.com

Files

MESSAGE

Size

2635

Date & Time

09/25/2006 3:11:28 PM

Options

Auto Delete:

No

Expiration Date:

None

Notify Recipients:

Yes

Priority:

Standard

ReplyRequested:

No

Return Notification:

None

Concealed Subject:

No

Security:

Standard

To Be Delivered:

Immediate

Status Tracking:

Delivered & Opened