

From: <michael_okeefe@fpl.com>
To: <GXM@nrc.gov>
Date: 09/28/2006 4:24:13 PM
Subject: Re: LAR 05-08

Ed,

FPL Energy Seabrook LLC concurs with the proposed license condition to limit primary-to-secondary leakage to 150 gallons per day per steam generator and if the limit is exceeded to take appropriate action in accordance with Technical Specification 3.4.6.2, Reactor Coolant System Leakage."

Mike O'Keefe
FPLE Seabrook
Regulatory Compliance Supervisor
603-773-7745 (office)
603-771-7939 (pager)
765-6319 (cell)

"Ed Miller"
<GXM@nrc.gov> To: michael_okeefe@fpl.com

cc:
09/28/2006 03:04 Subject: LAR 05-08

PM

Mike,

Currently, FPLE procedurally limits operational primary-to-secondary leakage to 150 gallons per day (gpd) per Steam Generator (SG) compared to the Technical Specification (TS) limit of 500 gpd per SG. Upon further review, the staff determined that this procedural restriction needs to be contained in a license condition stating that FPLE will maintain the operational limit of primary-to-secondary leakage at 150 gpd per SG and if this limit is exceeded, Seabrook will take the appropriate actions in accordance with TS 3.4.6.2, "Reactor Coolant System Leakage." An e-mail, to be docketed, confirming the acceptability of this condition will be sufficient.

G. Edward Miller
Project Manager
Division of Operating Reactor Licensing
U.S. Nuclear Regulatory Commission
(301) 415-2481

Mail Envelope Properties

(451C2F61.42C : 22 : 21548)

Subject: Re: LAR 05-08
Creation Date 09/28/2006 4:25:39 PM
From: <michael_okeefe@fpl.com>

Created By: michael_okeefe@fpl.com

Recipients

nrc.gov
TWGWPO01.HQGWDO01
GXM (Ed Miller)

Post Office

TWGWPO01.HQGWDO01

Route

nrc.gov

Files	Size	Date & Time
MESSAGE	2306	09/28/2006 4:25:39 PM
Mime.822	3683	

Options

Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

Junk Mail Handling Evaluation Results

Message is eligible for Junk Mail handling
This message was not classified as Junk Mail

Junk Mail settings when this message was delivered

Junk Mail handling disabled by User
Junk Mail handling disabled by Administrator
Junk List is not enabled
Junk Mail using personal address books is not enabled
Block List is not enabled