

September 28, 2006

Mr. Michael Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601-1839

SUBJECT: REQUESTS FOR ADDITIONAL INFORMATION FOR THE REVIEW OF
VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL
APPLICATION

Dear Mr. Kansler:

By letter dated January 25, 2006, the U.S. Nuclear Regulatory Commission (NRC) received the Entergy Nuclear Operations, Inc., application for renewal of Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station (VYNPS). The NRC staff is reviewing the information contained in the license renewal application and has identified, in the enclosure, areas where additional information is needed to complete the review. Specifically, the enclosed requests for additional information are from Section 3.5, "Structures and Component Supports," of the VYNPS license renewal application.

Based on discussions with Mr. Jim DeVincentis of your staff, a mutually agreeable date for your response is within 30 days of the date of this letter. If you have any questions regarding this letter or if circumstances result in your need to revise the response date, please contact me at 301-415-4053 or by e-mail at jgr@nrc.gov.

Sincerely,

/RA/

Jonathan Rowley, Project Manager
License Renewal Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosure:
Requests for Additional Information

cc w/encl: See next page

September 28, 2006

Mr. Michael Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601-1839

SUBJECT: REQUESTS FOR ADDITIONAL INFORMATION FOR THE REVIEW OF
VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL
APPLICATION

Dear Mr. Kansler:

By letter dated January 25, 2006, the U.S. Nuclear Regulatory Commission (NRC) received the Entergy Nuclear Operations, Inc., application for renewal of Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station (VYNPS). The NRC staff is reviewing the information contained in the license renewal application and has identified, in the enclosure, areas where additional information is needed to complete the review. Specifically, the enclosed requests for additional information are from Section 3.5, "Structures and Component Supports," of the VYNPS license renewal application.

Based on discussions with Mr. Jim DeVincentis of your staff, a mutually agreeable date for your response is within 30 days of the date of this letter. If you have any questions regarding this letter or if circumstances result in your need to revise the response date, please contact me at 301-415-4053 or by e-mail at jgr@nrc.gov.

Sincerely,

/RA/

Jonathan Rowley, Project Manager
License Renewal Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosure:
Requests for Additional Information

cc w/encl: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: **ML062720029**

OFFICE	PM:RLRB:DLR	LA:DLR	BC:RLRB:DLR
NAME	Jrowley /RA/	lking /RA/	Jzimmerman /RA/
DATE	09/ 11 /06	09/ 8 /06	09/ 28 /06

OFFICIAL RECORD COPY

Letter to Michael Kansler from Jonathan Rowley dated September 28, 2006

SUBJECT: REQUESTS FOR ADDITIONAL INFORMATION FOR THE REVIEW OF
VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL
APPLICATION

HARD COPY

DLR R/F

E-MAIL:

JFair
RWeisman
AMurphy
RPettis
GGalletti
DShum
GBagchi
SSmith (srs3)
SDuraiswamy
YL (Renee) Li
RidsNrrDlr
RidsNrrDlrRIra
RidsNrrDlrRIrb
RidsNrrDlrRIrc
RidsNrrDlrReba
RidsNrrDlrRebb
RidsNrrDe
RidsNrrDci
RidsNrrEemb
RidsNrrDeEeeb
RidsNrrDeEqva
RidsNrrDss
RidsNrrDnrl
RidsOgcMailCenter
RidsNrrAdes

JRowley
RLaufer
JShea
CAnderson, RI
R.Powell, RI
DScrenci, RI
MModes, RI
DPelton, Sr. Resident
MYoung
RidsOpaMail

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. David R. Lewis
Pillsbury, Winthrop, Shaw, Pittman, LLP
2300 N Street, N.W.
Washington, DC 20037-1128

Mr. David O'Brien, Commissioner
Vermont Department of Public Service
112 State Street
Montpelier, VT 05620-2601

Mr. James Volz, Chairman
Public Service Board
State of Vermont
112 State Street
Montpelier, VT 05620-2701

Chairman, Board of Selectmen
Town of Vernon
P.O. Box 116
Vernon, VT 05354-0116

Operating Experience Coordinator
Vermont Yankee Nuclear Power Station
320 Governor Hunt Road
Vernon, VT 05354

G. Dana Bisbee, Esq.
Deputy Attorney General
33 Capitol Street
Concord, NH 03301-6937

Chief, Safety Unit
Office of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Ms. Deborah B. Katz
Box 83
Shelburne Falls, MA 01370

Ms. Carla A. White, RRPT, CHP
Radiological Health
Vermont Department of Health
P.O. Box 70, Drawer #43
108 Cherry Street
Burlington, VT 05402-0070

Mr. James M. DeVincentis
Manager, Licensing
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Resident Inspector
Vermont Yankee Nuclear Power Station
U. S. Nuclear Regulatory Commission
P.O. Box 176
Vernon, VT 05354

Director, Massachusetts Emergency
Management Agency
ATTN: James Muckerheide
400 Worcester Rd.
Framingham, MA 01702-5399

Jonathan M. Block, Esq.
Main Street
P.O. Box 566
Putney, VT 05346-0566

Mr. John F. McCann
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

Vermont Yankee Nuclear Power Station

cc:

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Oscar Limpas
Vice President, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwartz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Travis C. McCullough
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Ted Sullivan
Site Vice President
Entergy Nuclear Operations, Inc.
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Mr. James H. Snizek
5486 Nithsdale Drive
Salisbury, MD 21801

Ms. Stacey M. Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. Raymond Shadis
New England Coalition
Post Office Box 98
Edgecomb, ME 04556

Mr. James P. Matteau
Executive Director
Windham Regional Commission
139 Main Street, Suite 505
Brattleboro, VT 05301

Mr. William K. Sherman
Vermont Department of Public Service
112 State Street
Drawer 20
Montpelier, VT 05620-2601

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306

Ms. Charlene D. Faison
Manager, Licensing
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Ross
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Diane Curran, Esq.*
Harmon, Curran, Spielberg
& Eisenberg, L.L.P.
1726 M Street, NW., Suite 600
Washington, DC 20036

VERMONT YANKEE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION
REQUESTS FOR ADDITIONAL INFORMATION (RAIs)

RAI 3.5-2

Table 3.5.2-1 of the Vermont Yankee Nuclear Power Station (VYNPS) license renewal application (LRA) does not list downcomers as a component. However, downcomers are listed in Table 3.5.1 under line item 3.5.1-13. The applicant is requested to explain why there is neither an aging management program (AMP) nor an aging management review provided for downcomers in Table 3.5.2-1.

RAI 3.5-5

VYNPS AMP B.1.15, Inservice Inspection, states that “For containment inservice inspection, general visual and detailed visual examinations are used in addition to VT [visual testing] examinations as allowed by 10 CFR 50.55(a) to include applicable relief requests.” The applicant is requested to describe the differences between the general visual, detailed visual, and VT examinations. In addition, the applicant is requested to state the relief requests referenced in AMP B.1.15.

RA 3.5-6

AMP B.1.15, Inservice Inspection, and A.2.1.16, Inservice Inspection—Containment Inservice Inspection Program, states that “The program includes augmented ultrasonic exams to measure wall thickness of the containment structure.” Explain the difference between the augmented portion of the ultrasonic exams performed in the two programs mentioned and that of the American Society of Mechanical Engineers Section XI Inservice Inspection program.

RAI 3.5-7

Section 3.5.2.2.1.1 of the VYNPS LRA states that the below-grade environment is not aggressive. The staff requests that the applicant provide actual values of pH, chlorides, and sulfates in the groundwater/soil adjacent to structures in order to verify the claim of a non-aggressive below-grade environment.

RAI 3.5-9

The applicant is requested to confirm whether or not the aggregates used for the concrete base mat that supports the steel containment have been tested for reactivity in accordance with American Society for Testing and Materials C-289 and C-295.

Enclosure