Development of a Performance-Based Approach in Seismic Siting and Design

Andrew J. Murphy

Presenting for

Seismic Issues Technical Advisory Group

Office of Nuclear Regulatory Research, USNRC

SMiRT-19

Division K

Toronto, Canada

August 13-17, 2007

NRC Seismic Issues Technical Advisory Group

U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

- Andrew J. Murphy, RES, Chairman
- Goutam Bagchi, NRO
- Syed Ali, RES
- Mahendra Shah, NMSS
- Herman Graves, RES
- Clifford Munson, NRO
- Yong Li, NRO
- Vaughn Thomas, RES
- Ann Kammerer, RES

Outline of the Presentation

- Background
- Seismic Issues Technical Advisory Group
- 1997 Regulatory Guidance – R.G. 1.165
  - Reference Probability – Hazard-Consistent Approach
  - Based on 29 Operating Nuclear Power Plants - newest units
- 2007 Regulatory Guidance – R.G. 1.208
  - High Frequency Exceedances in PSHA
    - New Ground Motion Attenuation Models
  - Risk Consistent Approach – Performance-Based
- Technical Basis/Content
- Additional Discussion of Topics

Background

R.G. 1.208

- Intended to provide guidance to applicants for ESPs or COLs
  - RG 1.165, "Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motion", remains as an acceptable alternative
- Utilizes a performance-based method for developing a site-specific safe shutdown earthquake ground motion (SSE)
- Technical basis informed by:
  - SITAG knowledge and expertise
  - ASCE 43-05
  - Industry research

Regulatory Guide 1.165 – Identification & Characterization of Seismic Sources & Determination of SSE Ground Motion

U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

- Describes geological and seismological investigation for a site
- Provides a Hazard-Consistent approach to siting
- Establish a Reference Probability (RP) Method to determine SSE
- RP is a Hazard-Consistent measure, based on the annual probability of exceedance of SSE at 29 operating reactor
- Since RP depends on specific hazard curves being used, periodic update is needed
- Published in 1997, and used in two ESP applications
- New studies need to be incorporated

New Regulatory Guide 1.208 – A Performance-Based Approach to Define the Site-Specific Earthquake Ground Motion – Published Final March 2007

U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

- Uses a Risk-Consistent approach
- Describes a Performance-Based approach to determine SSE and PB approach is a risk consistent method
- Achieves both high and consistent level of seismic safety in the design of future NPPs
- Uses a Mean Performance Target of 10-5/year
- Has been used in DOE practice for 10 years
- Reflects recent improvements in PSHA methodology, such as applying Cumulative Absolute Velocity (CAV) method to eliminate non-damaging earthquakes
- Provides probabilistic site response guidance

U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

Performance-Based Approach to Determine SSE

$$PB\ SSE = DF \times UHRS_{10^{-4}}$$

$$DF = \text{Max}\ (0.6 A_R^{\ 0.8}, 1.0)$$

$$A_R = \frac{UHRS_{10^{-5}}}{UHRS_{10^{-4}}}$$

DF: Design Factor
AR: Hazard curve slope
$UHRS_{10\text{-}5}$ and $UHRS_{10\text{-}4}$: mean Uniform hazard response spectra with annual probability of exceedance of 10^{-5} and 10^{-4}

Performance Target

- Performance Target (P_{FT}) is $1x10^{-5}$ per year
  - Median SCDF is $1.2x10^{-5}$/yr
  - IPEEE seismic PRAs conducted for 25 NPPs during mid/late 1990s determined annual SCDF values
- Implies a Mean Seismic Hazard of 10^{-4}/year – Empirical
- Performance is measured in terms of Frequency of Onset of Significant Inelastic Deformation (FOSID), essentially elastic behavior
- Therefore, P_{FT} corresponds to a damage state which is more conservative than the SCDF

What does Reg Guide 1.208 do?



Collect Information

- Site Specific Investigations
  - Geological
  - Geophysical
  - Seismological
  - Geotechnical
  - Regulatory Position 1
  - Appendix C
- Regional Seismic Sources
  - Shaking
  - Surface rupture
  - Latest models incorporated
  - Regulatory Position 2
  - Appendix C

New Issue: CAV Filtering

- Cumulative Absolute Velocity
- Small close quakes = short high-f motions

  Current methods over-predict damage for sites in area sources
- Better predictor of damage than peak acceleration
- Removes quakes too short to cause damage



Regulatory Position 3



Cumulative Absolute Velocity vs. Minimum Magnitude Truncation

- Current PSHA uses minimum magnitude (step function) as a threshold for hazard input
- Recommend the use of Cumulative Absolute Velocity (CAV) to determine ground motion cut-off

Cumulative Absolute Velocity vs. Minimum Magnitude Truncation

U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

Magnitude Truncation



Cumulative Absolute Velocity



CAV Effects


0.01
0.001
0.0001
0.00001
Annual Probability of Being Exceeded
0.01
0.1
1
2
Spectral Acceleration (g)
Standard PSHA
CAV > 0.16 g-sec


1
0.1
0.01
Spectral Acceleration (g)
0.1
1
10
100
Frequency (Hz)
Standard PSHA (1E-4)
CAV > 0.16 g-s (1E-4)

Pending/Potential Issues

- Potential Use of an Incoherency Function to Reduce Effects of High Frequency Ground Motions
  - Topic to be addressed in Standard Review Plan (SRP)
- SSE is not a Design Response Spectrum for all cases (DRS)
  - Current document does not address the development of a site-specific DRS
  - Assumed that the DRS will be included in the NRC SRP


10 m (0.2 increase 10-20 Hz)
25
50
100
10 m (0.2 increase 10-30 Hz)
25
50
100
10 m (0.2 increase 10-35 Hz)
25
50
100
1
0.9
0.8
0.7
0.6
0.5
0.4
0.3
0.2
0.1
0
0
5
10
15
20
25
30
35
40
45
50
Coherency between 2 points
Frequency


Motions are in phase
(perfectly coherent)
Motions are random
(perfectly incoherent)
Coherency between 2 points
Frequency
10 m (0.2 increase 10-20 Hz)
25
50
100
10 m (0.2 increase 10-30 Hz)
25
50
100
10 m (0.2 increase 10-35 Hz)
25
50
100
1
0.9
0.8
0.7
0.6
0.5
0.4
0.3
0.2
0.1
0
0
5
10
15
20
25
30
35
40
45
50


Coherency between 2 points
Frequency
Increasing distance between points
10 m (0.2 increase 10-20 Hz)
25
50
100
10 m (0.2 increase 10-30 Hz)
25
50
100
10 m (0.2 increase 10-35 Hz)
25
50
100
0
0.1
0.2
0.3
0.4
0.5
0.6
0.7
0.8
0.9
1
0
5
10
15
20
25
30
35
40
45
50

Conforming Standard Review Plan Changes

- Standard Review Plan (NUREG – 0800)
  - Chapter 3 – Design of Structures, Components, Equipment, and Systems
    - Section 3.2.1 – Seismic Classification - reviews the seismic classification of SSCs important to safety & designed for the effects of the SSE
    - Section 3.7.1 – Seismic Design Parameters – review of OBE & SSE as three components of the design ground motion
    - Section 3.7.2 – Seismic System Analysis – reviews dynamic analysis methods (response spectra, time history, equivalent static load, etc.) for all Seismic Category I SSCs
    - Section 3.7.3 – Seismic Subsystem Analysis – reviews dynamic analysis methods for all Seismic Category I subsystems