

ACTIONS (continued)

| CONDITION  | REQUIRED ACTION   | COMPLETION TIME   |
|--|---|---|
| B. As required by Required Action A.1 and referenced in Table 3.3.5.1-1. | <p>B.1</p> <p>-----NOTES-----</p> <p>1. Only applicable in MODES 1, 2, and 3.</p> <p>2. Only applicable for Functions 1.a, 1.b, 2.a and 2.b.</p> <p>-----</p> <p>Declare supported feature(s) inoperable when its redundant feature ECCS initiation capability is inoperable.</p> | 1 hour from discovery of loss of initiation capability for feature(s) in both divisions |
|  | <p><u>AND</u></p> <p>B.2</p> <p>-----NOTES-----</p> <p>1. Only applicable in MODES 1, 2, and 3.</p> <p>2. Only applicable for Functions 3.a and 3.b.</p> <p>-----</p> <p>Declare High Pressure Core Spray (HPCS) System inoperable.</p>   |   |
|  | <p><u>AND</u></p> <p>B.3 Place channel in trip.</p>   |   |

(continued)

ACTIONS

| CONDITION  | REQUIRED ACTION   | COMPLETION TIME   |
|--|---|---|
| C. As required by Required Action A.1 and referenced in Table 3.3.5.1-1. | C.1 -----NOTES-----<br>1. Only applicable in MODES 1, 2, and 3.<br><br>2. Only applicable for Functions 1.c, 1.d, 1.e, 2.c, and 2.d.<br>-----<br><br>Declare supported feature(s) inoperable when its redundant feature ECCS initiation capability is inoperable. | 1 hour from discovery of loss of initiation capability for feature(s) in both divisions |
|  | <u>AND</u>  |   |
|  | C.2 Restore channel to OPERABLE status.   | 24 hours  |

(continued)

ACTIONS

| CONDITION  | REQUIRED ACTION   | COMPLETION TIME   |
|--|---|---|
| D. As required by Required Action A.1 and referenced in Table 3.3.5.1-1. | D.1 -----NOTE-----<br>Only applicable if HPCS pump suction is not aligned to the suppression pool.<br>----- |   |
|  | Declare HPCS System inoperable.   | 1 hour from discovery of loss of HPCS initiation capability |
|  | <u>AND</u>  |   |
|  | D.2.1 Place channel in trip.  | 24 hours  |
|  | <u>OR</u>   |   |
|  | D.2.2 Align the HPCS pump suction to the suppression pool.  | 24 hours  |

(continued)