

REVISED LICENSE PAGES

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

REMOVE

12  
--

INSERT

12  
12a

- (2) TVA shall maintain interim emergency support facilities (Technical Support Center, Operations Support Center and the Emergency Operations Facility) until the final facilities are complete.

J. Relief and Safety Valve Test Requirements (Section 22.2, II.D.1)

TVA shall conform to the results of the EPRI test program. TVA shall provide documentation for qualifying (a) reactor coolant system relief and safety valves, (b) piping and supports, and (c) block valves in accordance with the review schedule given in SECY 81-491 as approved by the Commission.

(24) Compliance with Regulatory Guide 1.97

TVA shall implement modifications necessary to comply with Revision 2 of Regulatory Guide 1.97, "Instrumentation for Light Water Cooled Nuclear Power Plants to Assess Plant Conditions During and Following An Accident," dated December 1980 by startup from the Unit 2 Cycle 4 refueling outage.

(25) Mixed Core DNBR Penalty

TVA will obtain NRC approval prior to startup for any cycle's core that involves a reduction in the departure from nucleate boiling ratio initial transition core penalty below that value stated in TVA's submittal on Framatome fuel conversion dated April 6, 1997.

(26) Control Room Air-Conditioning System Maintenance

TVA commits to the use of a portable chiller package and air-handling unit to provide alternate cooling if both trains of the control room air condition system become inoperable during the maintenance activities to upgrade the compressors and controls or immediately enter Technical Specification 3.0.3.

(27) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
  - 1. Pre-defined coordinated fire response strategy and guidance
  - 2. Assessment of mutual aid fire fighting assets
  - 3. Designated staging areas for equipment and materials
  - 4. Command and control
  - 5. Training of response personnel
- (b) Operations to mitigate fuel damage considering the following:
  - 1. Protection and use of personnel assets
  - 2. Communications
  - 3. Minimizing fire spread
  - 4. Procedures for implementing integrated fire response strategy

5. Identification of readily-available pre-staged equipment
6. Training on integrated fire response strategy
7. Spent fuel pool mitigation measures

- (c) Actions to minimize release to include consideration of:
1. Water spray scrubbing
  2. Dose to onsite responders

- (28) The licensee shall implement and maintain all Actions required by Attachment 2 to NRC Order EA-06-137, issued June 20, 2006, except the last action that requires incorporation of the strategies into the site security plan, contingency plan, emergency plan and/or guard training and qualification plan, as appropriate.

- D. Exemptions from certain requirements of Appendices G and J to 10 CFR Part 50 are described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplements No. 1. These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. The exemptions are, therefore, hereby granted. The granting of these exemptions are authorized with the issuance of the License for Fuel Loading and Low Power Testing, dated February 29, 1980. The facility will operate, to the extent authorized herein, Act, and the regulations of the Commission. Additional exemptions are listed in Attachment 1.
- E. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "Sequoyah Nuclear Plant Security Plan, Training And Qualification Plan, And Safeguards Contingency Plan" submitted by letter dated May 8, 2006.

REVISED LICENSE PAGES

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

REMOVE

11  
12  
--

INSERT

11  
12  
12a

s. Primary Coolant Outside Containment (Section 22.2, III.D.1.1)

Prior to exceeding 5 percent power level, TVA is required to complete the leak tests on Unit 2, and results are to be submitted within 30 days from the completion of the testing.

(17) Surveillance Interval Extension

The performance interval for the 36-month surveillance requirements in TS 4.3.2.1.3 shall be extended to May 18, 1996, to coincide with the Cycle 7 refueling outage. The extended interval shall not exceed a total of 50 months for the 36-month surveillances.

(18) Mixed Core DNBR Penalty

TVA will obtain NRC approval prior to startup for any cycle's core that involves a reduction in the departure from nucleate boiling ratio initial transition core penalty below that value stated in TVA's submittal on Framatome fuel conversion dated April 6, 1997.

(19) Steam Generator Replacement Project

During the Unit 1 Cycle 12 refueling and steam generator replacement outage, lifts of heavy loads will be performed in accordance with Table 3.1 of NRC Safety Evaluation dated March 26, 2003.

(20) Control Room Air-Conditioning System Maintenance

TVA commits to the use of a portable chiller package and air-handling unit to provide alternate cooling if both trains of the control room air condition system become inoperable during the maintenance activities to upgrade the compressors and controls or immediately enter Technical Specification 3.0.3.

(21) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
  - 1. Pre-defined coordinated fire response strategy and guidance
  - 2. Assessment of mutual aid fire fighting assets
  - 3. Designated staging areas for equipment and materials
  - 4. Command and control
  - 5. Training of response personnel

- (b) Operations to mitigate fuel damage considering the following:
  - 1. Protection and use of personnel assets
  - 2. Communications
  - 3. Minimizing fire spread
  - 4. Procedures for implementing integrated fire response strategy
  - 5. Identification of readily-available pre-staged equipment
  - 6. Training on integrated fire response strategy
  - 7. Spent fuel pool mitigation measures
- (c) Actions to minimize release to include consideration of:
  - 1. Water spray scrubbing
  - 2. Dose to onsite responders

(22) The licensee shall implement and maintain all Actions required by Attachment 2 to NRC Order EA-06-137, issued June 20, 2006, except the last action that requires incorporation of the strategies into the site security plan, contingency plan, emergency plan and/or guard training and qualification plan, as appropriate.

- D. Exemptions from certain requirements of Appendices G and J to 10 CFR Part 50 are described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplements No. 1 and No. 5. These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. Therefore, these exemptions are hereby granted. The facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission.

A temporary exemption from General Design Criterion 57 found in Appendix A to 10 CFR part 50 is described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplement No. 5, Section 6.2.4. This exemption is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. The exemption, therefore, is hereby granted and shall remain in effect through the first refueling outage as discussed in Section 6.2.4 of Supplement 5 to the Safety Evaluation Report. The granting of the exemption is authorized with the issuance of the Facility Operating License. The facility will operate, to the extent authorized herein, in conformity with the application as amended, the provisions of the Act, and the regulations of the Commission. Additional Exemptions are listed in Attachment 2.

E. Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contain Safeguards Information protected under

10 CFR 73.21, is entitled: "Sequoyah Nuclear Plant Security Plan, Training And Qualification Plan, And Safeguards Contingency Plan" submitted by letter dated May 8, 2006.

F. Reactor Safety Methodology Applications Programs (Section 24.0)

TVA will provide a report prepared by the Kaman Sciences Corporation (KSC) on a full scale nuclear safety and availability analysis within six months from the date of the KSC report.

G. This amended license is subject to the following additional condition for the protection of the environment:

Before engaging in additional construction or operational activities which may result in an environmental impact that was not evaluated by the Commission, Tennessee Valley Authority will prepare and record an environmental evaluation of such activity. When the evaluation indicates that such activity may result in a significant adverse environmental impact that was not evaluated, or that is significantly greater than that evaluated in the Final Environmental Statement prepared by the Tennessee Valley Authority and the Environmental Impact Appraisal prepared by the Commission in May 1979, the Tennessee Valley Authority shall provide a written evaluation of such activities and obtain prior approval from the Director, Office of Nuclear Reactor Regulation.

H. Deleted

I. TVA shall immediately notify the Commission of any accident at this facility which could result in an unplanned release of quantities of fission products in excess of allowable limits for normal operation established by the Commission.

J. TVA shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.