

ENCLOSURE 1

REVISED PAGES OF FACILITY OPERATING LICENSE NPF-57

DOCKET NO. 50-354

HOPE CREEK GENERATING STATION

Replace the following pages of the Facility Operating License. The revised pages are identified by the date of the letter issuing these pages and contain marginal lines indicating the areas of change.

REMOVE

Page 7

Page 8

- - -

INSERT

Page 7

Page 8

Page 9

- 4) The trust agreement shall not be modified in any material respect without prior written notification to the Director, Office of Nuclear Reactor Regulation.
 - 5) The trustee, investment advisor, or anyone else directing the investments made in the trust shall adhere to a "prudent investor" standard, as specified in 18 CFR 35.32(3) of the Federal Energy Regulatory Commission's regulations.
- c. PSEG Nuclear LLC shall not take any action that would cause PSEG Power LLC or its parent companies to void, cancel, or diminish the commitment to fund an extended plant shutdown as represented in the application for approval of the transfer of this license from PSE&G to PSEG Nuclear LLC.
- (16) Mitigation Strategy
- The licensee shall develop and maintain strategies for addressing large fires and explosions and that include the following key areas:
- (a) Fire fighting response strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel
 - (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy
 - 5. Identification of readily-available pre-staged equipment
 - 6. Training on integrated fire response strategy
 - 7. Spent fuel pool mitigation measures
 - (c) Actions to minimize release to include consideration of:
 - 1. Water spray scrubbing
 - 2. Dose to onsite responders
- (17) The licensee shall implement and maintain all Actions required by Attachment 2 to NRC Order EA-06-137, issued June 20, 2006, except the last action that requires incorporation of the strategies into the site security plan, contingency plan, emergency plan and/or guard training and qualification plan, as appropriate.

D. The facility requires exemptions from certain requirements of 10 CFR Part 50 and 10 CFR Part 70. An exemption from the criticality alarm requirements of 10 CFR 70.24 was granted in Special Nuclear Material License No. 1953, dated August 21, 1985. This exemption is described in Section 9.1 of Supplement No. 5 to the SER. This previously granted exemption is continued in this operating license. An exemption from certain requirements of Appendix A to 10 CFR Part 50, is described in Supplement No. 5 to the SER. This exemption is a schedular exemption to the requirements of General Design Criterion 64, permitting delaying functionality of the Turbine Building Circulating Water System-Radiation Monitoring System until 5 percent power for local indication, and until 120 days after fuel load for control room indication (Appendix R of SSER 5). Exemptions from certain requirements of Appendix J to 10 CFR Part 50, are described in Supplement No. 5 to the SER. These include an exemption from the requirement of Appendix J, exempting main steam isolation valve leak-rate testing at 1.10 Pa (Section 6.2.6 of SSER 5); an exemption from Appendix J, exempting Type C testing on traversing incore probe system shear valves (Section 6.2.6 of SSER 5); an exemption from Appendix J, exempting Type C testing for instrument lines and lines containing excess flow check valves (Section 6.2.6 of SSER 5); and an exemption from Appendix J, exempting Type C testing of thermal relief valves (Section 6.2.6 of SSER 5). These exemptions are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. These exemptions are hereby granted. The special circumstances regarding each exemption are identified in the referenced section of the safety evaluation report and the supplements thereto. These exemptions are granted pursuant to 10 CFR 50.12. With these exemptions, the facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission.

Amendment No. 129, 138
Revised by letter dated ~~October 28, 2004,~~
~~February 21, 2007,~~
August 9, 2007

- E. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54 (p). The plans, submitted by letter dated May 19, 2006 are entitled: "Salem-Hope Creek Nuclear Generating Station Security Training and Qualification Plan," and "Salem-Hope Creek Nuclear Generating Station Security Contingency Plan." The plans contain Safeguards Information protected under 10 CFR 73.21.
- F. Except as otherwise provided in the Technical Specifications or Environmental Protection Plan, PSEG Nuclear LLC shall report any violations of the requirements contained in Section 2.C of this license in the following manner: initial notification shall be made within 24 hours to the NRC Operations Center via the Emergency Notification System with written followup within thirty days in accordance with the procedures described in 10 CFR 50.73(b), (c), and (e).
- G. The licensees shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.
- H. This license is effective as of the date of issuance and shall expire at midnight on April 11, 2026.

FOR THE NUCLEAR REGULATORY COMMISSION

- original signed by H.R. Denton -

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Appendix A - Technical Specifications (NUREG-1202)
- 2. Appendix B - Environmental Protection Plan

Date of Issuance: July 25, 1986

Revised by letter dated August 9, 2007