

July 25, 2007  
L-07-102

Department of Environmental Protection  
Bureau of Water Quality Management  
Attention: DMR Clerk  
400 Waterfront Drive  
Pittsburgh, PA 15222

Beaver Valley Power Station Discharge Monitoring Report (NPDES) Permit No. PA0025615

To Whom It May Concern:


Enclosed is the June 2007 NPDES Discharge Monitoring Report (DMR) for FirstEnergy Nuclear Operating Company (FENOC), Beaver Valley Power Station, in accordance with the requirements of the Permit. Attachment 1 to this letter is supplemental monitoring data for Outfall 001 (dissolved oxygen). Attachment 2 to this letter is a quarterly stormwater report as required by NPDES Permit Part C.21.

Review of the data indicates no Permit parameters were exceeded during the month.

Included with the report this month are two Supplemental Laboratory Accreditation Forms for analyses performed to support permit requirements as required by 25 Pa. Code § 252.

Should you have any questions regarding the attached and enclosed documents, please direct them to Mr. Michael Banko, at 724-682-4117.

Sincerely,

  
for Peter P. Sena  
Director, Site Operations

Attachments (2)  
Enclosures (2)

cc: Document Control Desk US NRC (NOTE: No new US NRC commitments are contained in this letter.)  
US Environmental Protection Agency  
Central File: **Keyword- DMR**

IE25  
MRR

**ATTACHMENT 1**

**Weekly Dissolved Oxygen Monitoring Results at Outfall 001**

The following supplemental dissolved oxygen monitoring data for Outfall 001 is provided as agreed.

<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>VALUE</b>	<b>UNITS</b>
5/30/07	1200	7.03	mg/L
6/4/07	1040	7.26	mg/L
6/11/07	0930	7.30	mg/L
6/18/07	0908	8.42	mg/L
6/27/07	0950	8.56	mg/L

- Attachment 1 END -

**ATTACHMENT 2**

**Permit Part C.21 Iron and Zinc Stormwater Monitoring Results**

Sample Date	Sample Time	Outfall	Parameter	Result	Units
06-19-07	1757	Outfall #003,	Zinc	8564	ug/l
06-19-07	1757	Outfall #003,	Iron	27020	ug/l
06-08-07	1741	Outfall #008,	Zinc	131	ug/l
06-08-07	1741	Outfall #008,	Iron	989	ug/l
06-19-07	1757	Outfall #011,	Zinc	746	ug/l
06-19-07	1757	Outfall #011,	Iron	2426	ug/l

- Attachment 2 END -

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 55

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

001A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNITS 1&2 COOLG. TOWER BLWDN  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.75	N/A	8.38	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	**
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	37.7	51.7	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.01	0.08	mg/L	0	8 / 30	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 AVERAGE	11.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02***	<0.02***	mg/L	0	CONT	RCRD
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here) *\* Not in wet layup this period.*  
HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX  
*\*\*No Clamicide this Period. \*\*\*0.02 mg/L is minimum detectable level. JPC 7-12-07*

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 56

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

002A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)


INTAKE SCREEN BACKWASH  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	TO	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg Mon MO AVG	Reg Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-5203	07	07	26
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

Page 57

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

003A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
003  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

FROM

TO

No Data Indicator

☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.030	0.046	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR  
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 58

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	004A
PERMIT NUMBER	DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT ONE COOLG TOWER OVERFLOW  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT				7.38		7.38	pH	0	1 / 7*	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	3.85	3.85	MGD					-	1 / 7*	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT					0.19	0.19	mg/L	0	1 / 7*	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT					0.16	0.16	mg/L	0	1 / 7*	GRAB
50084 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	6 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			724	682-5203	07	07	26
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

\*Discharge only occurred one day. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 59

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

006A  
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
AUX. INTAKE SCREEN BACKWASH  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD								
YEAR	MO	DAY		YEAR	MO	DAY		
07	06	01	FROM	07	06	30	TO	

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.016	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon: MO AVG	Req. Mon: DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED					724	682-5203	07	07	26
					AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 60

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

007A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
AUX. INTAKE SYSTEM  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****			Weekly	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT										
50080 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 61

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	008A
PERMIT NUMBER	DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 COOLING TOWER PUMPHOUSE  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 62

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

010A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 COOLING WATER  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.70	N/A	8.42	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.33	4.32	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.046	0.15	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.02	0.07	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

\*No Clamicides this period. JPC 7-12-07

The BETS DT-1 daily maximum was 31.4 mg/L

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

Page 63

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA.150770004

PA0025615  
PERMIT NUMBER

011A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
DIESEL GEN & TURBINE DRAINS  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD									
YEAR	MO	DAY		YEAR	MO	DAY			
07	06	01	TO	07	06	30			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 64

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

012A  
**DISCHARGE NUMBER**


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
BLOWDOWN FROM THE HVAC UNIT  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.81	N/A	8.11	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Once Per Month	GRAB
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.090	0.091	mg/L	0	2 / 30	GRAB
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Reg Mon MO AVG	Reg Mon DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.115	0.215	mg/L	0	2 / 30	GRAB
01092 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.5 MO AVG	1.5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg Mon MO AVG	Reg Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	2596	4520	mg/L	0	2 / 30	GRAB
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Reg Mon MO AVG	Reg Mon DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			724 682-5203	07 07 26	AREA Code	NUMBER	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 65

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	013A
PERMIT NUMBER	DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
OUTFALL 013  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	TO	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.48	N/A	6.94	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Cyanide, total (as CN)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01*	<0.01*	mg/L	0	2 / 30	24 HR COMP
00720 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.019	0.022	mg/L	0	2 / 30	24 HR COMP
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	05 MO AVG	1 DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005**	<0.005**	mg/L	0	2 / 30	24 HR COMP
34301 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.003	0.003	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

\* 0.01 mg/L is minimum detectable level. \*\* 0.005 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 66

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

101A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
101 CHEMICAL WASTE TREATMENT  
Internal Outfall

**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	TO	07	06 30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.60	N/A	8.46	pH	0	8 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	1.1	6.3	mg/L	0	6 / 31	2 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	COMP-2
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	6 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req Mon MO AVG	Req Mon DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.009	0.012	MGD	N/A	N/A	N/A	N/A	0	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		DAILY	CONTIN
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req Mon MO AVG	Req Mon DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER. \*5 mg/L is minimum detectable level. \*\* Not in wet layup this period. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 67

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	102A
PERMIT NUMBER	DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
102 INTAKE SCREEN HOUSE  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	TO	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.70	N/A	7.75	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	26.4	92.2	mg/L	0	7 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

\*5 mg/L is minimum detectable level. JPC 7-12-07



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 68

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

103A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
SLUDGE SETTLING BASIN  
Internal Outfall


ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	TO	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.96	N/A	7.16	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	8.6	17.2	mg/L	0	2 / 30	24 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MG AVG	100 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 69

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

111A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
111 DIESEL GENERATOR BLDG  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	TO	07	06 30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.53	N/A	7.96	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	6.5	11.6	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
\* 5 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 70

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

113A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 SEWAGE TMT PLANT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

FROM

TO

No Data Indicator

X

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	048 MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

Page 71

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

203A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
MAIN SEWAGE TMT PLANT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	023 MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 72

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

211A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
211 TURBINE BLDG  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD							
YEAR			MO			DAY	
FROM	07	06	01	TO	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.36	N/A	7.00	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	8 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.8	4.0	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
\* 5 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 73

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

213A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 COOL TOWER PUMPHOUSE  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	125 INST MAX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 74

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

301A  
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 AUX BOILER BLOWDOWN  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD								
YEAR	MO	DAY		YEAR	MO	DAY		
07	06	01	FROM	07	06	30	TO	

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-5203	07	07	26
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 7-12-07

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 75

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

303A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 OIL WATER SEPARATOR  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
07	06	01	TO	07	06	30

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE OIL WATER SEPARATOR PRIOR TO MIXING WITH ANY OTHER WATER.



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 76

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

313A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR  
(SUBR05)  
313 TURBINE BLDG DRAIN  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	TO	07	06 30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.51	N/A	6.94	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	13.0	18.5	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	2.1	12.4	mg/L	0	6 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon: MO AVG	Req: Mon: DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #21 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 77

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

401A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
CHEM.FEED AREA OF AUX BOILERS  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.25	N/A	9.71	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	Req Mon MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, In conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 78

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

403A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR  
(SUBR05)

CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD							
YEAR			MO			DAY	
FROM	07	06	01	TO	07	06	30

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT										
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 79

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

403A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY/MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 80

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

413A
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
BULK FUEL STORAGE DRAIN  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD								
YEAR	MO	DAY				YEAR	MO	DAY
07	06	01	FROM			07	06	30
			TO					

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-5203	07	07	26
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 81

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

501A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 GENRTR BLWDWN FILT BW  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY/MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

## SUPPLEMENTAL LABORATORY ACCREDITATION FORM<sup>1</sup>

<b>Permittee Name:</b> <u>FirstEnergy Nuclear Operating Company</u>							
<b>Address:</b> <u>P.O. Box 4</u>							
<u>Shippingport, PA 15077</u>							
<u>Beaver Valley Power Station</u>							
<b>PERMIT NUMBER</b>				<b>MONITORING PERIOD</b> Year/Month/Day			
PA0025615				2007	06	01	TO 2007 06 30
<b>PARAMETER</b>	<b>ANALYSIS METHOD</b>	<b>LAB NAME</b>	<b>LAB ID NUMBER<sup>2</sup></b>				
Powerline 3627 (Clamtrol)	Photometric Determination	Beaver Valley Power Station	04-2742				
Bentonite Detoxicant (Betz DT-1)	Estimated using feed rate and discharge flow rate per NPDES Permit PA0025645	Beaver Valley Power Station	04-2742				
Total Residual Chlorine	SM 4500-CL G [20 <sup>th</sup> ]	Beaver Valley Power Station	04-2742				
Free Available Chlorine	EPA 330.5	Beaver Valley Power Station	04-2742				
pH	SM 4500-H+ B [20 <sup>th</sup> ]	Beaver Valley Power Station	04-2742				
Temperature	SM 2550 B [20 <sup>th</sup> ]	Beaver Valley Power Station	04-2742				
Flow	NA	Beaver Valley Power Station	04-2742				
Total Suspended Solids	SM 2540 D [20 <sup>th</sup> ]	Beaver Valley Power Station	04-2742				
Hydrazine	ASTM D1385-01	Beaver Valley Power Station	04-2742				
Fecal Coliform <sup>3</sup>	Standard Method 9222D	Beaver Valley Power Station	04-2742				
Oil and Grease	EPA 1664 Rev A	FirstEnergy Corp-Beta Lab	68-01120				
Total Dissolved Solids	SM 2540 C [20 <sup>th</sup> ]	FirstEnergy Corp-Beta Lab	68-01120				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

**Name/Title Principal Executive Officer**

**Phone:** 724-682-7773

**Signature of Principal Executive Officer or Authorized Agent**

Peter P. Sena  
Director Site Operations

**Date:** 7/26/17

*[Signature]*  
For P. Sena

<sup>1</sup> Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

<sup>2</sup> For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

<sup>3</sup> Analysis no longer performed.



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

## SUPPLEMENTAL LABORATORY ACCREDITATION FORM<sup>1</sup>

<b>Permittee Name:</b> <u>FirstEnergy Nuclear Operating Company</u>										
<b>Address:</b> <u>P.O. Box 4</u>										
<u>Shippingport, PA 15077</u>										
<u>Beaver Valley Power Station</u>										
<b>PERMIT NUMBER</b>				<b>MONITORING PERIOD</b> Year/Month/Day						
PA0025615				2007	06	01	TO	2007	06	30
<b>PARAMETER</b>		<b>ANALYSIS METHOD</b>		<b>LAB NAME</b>			<b>LAB ID NUMBER<sup>2</sup></b>			
Zinc		EPA 200.7 Rev 4.4		FirstEnergy Corp-Beta Lab			68-01120			
Copper		EPA 200.7 Rev 4.4		FirstEnergy Corp-Beta Lab			68-01120			
Iron		EPA 200.7 Rev 4.4		FirstEnergy Corp-Beta Lab			68-01120			
Chromium		EPA 200.7 Rev 4.4		FirstEnergy Corp-Beta Lab			68-01120			
Ammonia		SM 4500-NH3 D [20 <sup>th</sup> ]		FirstEnergy Corp-Beta Lab			68-01120			
CBOD-5 Day		SM5210 B		Firstechnology, Inc.			68-00434			
Cyanide		SM 4500-CN E [20 <sup>th</sup> ]		Firstechnology, Inc.			68-00434			
Chlorobenzene		EPA 624		Firstechnology, Inc.			68-00434			

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

**Name/Title Principal Executive Officer**

**Phone:** 724-682-7773

**Signature of Principal Executive Officer or  
Authorized Agent**

Peter P. Sena  
Director, Site Operations

**Date:**

7/26/17

*[Signature]*  
P. Sena

<sup>1</sup> Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

<sup>2</sup> For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 55

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	001A
PERMIT NUMBER	DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNITS 1&2 COOLG. TOWER BLWDN  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.75	N/A	8.38	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO/AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	**
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO/AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	37.7	51.7	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO/AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.01	0.08	mg/L	0	8 / 30	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 AVERAGE	1.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02***	<0.02***	mg/L	0	CONT	RCRD
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO/AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here) *\* Not in wet layup this period.*  
HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX  
*\*\*No Clamicide this Period. \*\*\*0.02 mg/L is minimum detectable level. JPC 7-12-07*

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 56

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

002A  
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
INTAKE SCREEN BACKWASH  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>		<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 <b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS					724	682-5203	07	07	26
<b>TYPED OR PRINTED</b>				<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 57

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

003A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
003  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.030	0.046	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 58

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

004A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR  
(SUBR05)  
UNIT ONE COOLG TOWER OVERFLOW  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT				7.38		7.38	pH	0	1 / 7*	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	3.85	3.85	MGD					-	1 / 7*	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT					0.19	0.19	mg/L	0	1 / 7*	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST. MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT					0.16	0.16	mg/L	0	1 / 7*	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

\*Discharge only occurred one day. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 59

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

006A  
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
AUX. INTAKE SCREEN BACKWASH  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD							
YEAR			MO			DAY	
FROM	07	06	01	TO	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.016	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon MO AVG	Reg. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS					724	682-5203	07	07	26
TYPED OR PRINTED				AREA Code	NUMBER	YEAR	MO	DAY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 60

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

007A  
**DISCHARGE NUMBER**


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
AUX. INTAKE SYSTEM  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD								
YEAR	MO	DAY		YEAR	MO	DAY		
07	06	01	FROM	07	06	30	TO	

No Data Indicator **X**

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	0 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-5203	07	07	26
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 61

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

008A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 COOLING TOWER PUMPHOUSE  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg Mon MO AVG	Reg Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR  
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 62

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	010A
PERMIT NUMBER	DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 COOLING WATER  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.70	N/A	8.42	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.33	4.32	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MAX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.046	0.15	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.02	0.07	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to ensure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26	
<b>TYPED OR PRINTED</b>		<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>		<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

\*No Clamicides this period. JPC 7-12-07

Computer Generated Version of EPA Form 3320-1 (rev. 01/06)



**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 63

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

011A  
**DISCHARGE NUMBER**


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
DIESEL GEN & TURBINE DRAINS  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Reg. Mon MO AVG	Reg. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 <b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>TELEPHONE</b>		<b>DATE</b>		
<b>Peter P. Sena, DIRECTOR OF SITE OPERATIONS</b>  <b>TYPED OR PRINTED</b>			724	682-5203	07	07	26
			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 64

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	012A
PERMIT NUMBER	DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
BLOWDOWN FROM THE HVAC UNIT  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	06	01		07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.81	N/A	8.11	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Once Per Month	GRAB
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.090	0.091	mg/L	0	2 / 30	GRAB
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.115	0.215	mg/L	0	2 / 30	GRAB
01092 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.5 MO AVG	1.5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	2596	4520	mg/L	0	2 / 30	GRAB
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Twice Per Month	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED			724	682-5203	07	07	26
			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 65

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615	013A
PERMIT NUMBER	DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
OUTFALL 013  
External Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	TO	07	06 30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.48	N/A	6.94	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Cyanide, total (as CN)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01*	<0.01*	mg/L	0	2 / 30	24 HR COMP
00720 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.019	0.022	mg/L	0	2 / 30	24 HR COMP
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	05 MO AVG	1 DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005**	<0.005**	mg/L	0	2 / 30	24 HR COMP
34301 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.003	0.003	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724 682-5203		07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

\* 0.01 mg/L is minimum detectable level. \*\* 0.005 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 66

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

101A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
101 CHEMICAL WASTE TREATMENT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	TO	07	06 30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.60	N/A	8.46	pH	0	8 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	1.1	6.3	mg/L	0	6 / 31	2 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	COMP-2
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	6 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req: Mon MO AVG	Req: Mon DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.009	0.012	MGD	N/A	N/A	N/A	N/A	0	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		DAILY	CONTIN
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req: Mon MO AVG	Req: Mon DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER. \*5 mg/L is minimum detectable level. \*\* Not in wet layup this period. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 67

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

102A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
102 INTAKE SCREEN HOUSE  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 07	06	01	TO 07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.70	N/A	7.75	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	26.4	92.2	mg/L	0	7 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

\*5 mg/L is minimum detectable level. JPC 7-12-07

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 68

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

103A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
SLUDGE SETTLING BASIN  
Internal Outfall


ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.96	N/A	7.16	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	8.6	17.2	mg/L	0	2 / 30	24 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO/AVG	100 DAILY/MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg Mon MO/AVG	Reg Mon DAILY/MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	EST/IMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 69

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

111A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
111 DIESEL GENERATOR BLDG  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.53	N/A	7.96	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	6.5	11.6	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
\* 5 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 70

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

113A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 SEWAGE TMT PLANT  
Internal Outfall


ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator

X

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	80 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	043 MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS				724	682-5203	07 07 26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 71

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

203A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
MAIN SEWAGE TMT PLANT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		8 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	023 MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST. MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 72

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

211A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05).  
211 TURBINE BLDG  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD								
YEAR	MO	DAY	YEAR	MO	DAY			
07	06	01	07	06	30			

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.36	N/A	7.00	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.8	4.0	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
\* 5 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 73

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

213A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 COOL TOWER PUMPHOUSE  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30
			TO			

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST. MAX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 74

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

301A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 AUX BOILER BLOWDOWN  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 07	06	01	TO 07	06	30

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 30	GRAB
00530 1 0	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 30	GRAB
00556 1 0	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 7-12-07

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 75

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

303A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 OIL WATER SEPARATOR  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
FROM 07	06	01	TO 07	06	30	

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg Mon MO AVG	Reg Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE OIL WATER SEPARATOR PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 76

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

313A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
313 TURBINE BLDG DRAIN  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	06	01	07	06	30

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.51	N/A	6.94	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	13.0	18.5	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	2.1	12.4	mg/L	0	6 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #21 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 77

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

401A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
CHEM.FEED AREA OF AUX BOILERS  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD								
YEAR	MO	DAY				YEAR	MO	DAY
07	06	01	FROM			07	06	30
			TO					

No Data Indicator ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.25	N/A	9.71	pH	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	Req. Mon MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 7-12-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 78

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

403A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD									
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY		
	07	06	01		07	06	30		

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT										
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.); MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

Page 79

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

403A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)

CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	06	01	FROM	07	06	30

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT					MO AVG	DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 80

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

413A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
BULK FUEL STORAGE DRAIN  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD							
YEAR		MO		DAY			
FROM	07	06	01	TO	07	06	30

No Data Indicator **X**

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		8 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26	
<b>TYPED OR PRINTED</b>		<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>		<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 81

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

501A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 GENRTR BLWDWN FILT BW  
Internal Outfall

ATTN: DONALD J SALERA/MGR ENV & CHEM

MONITORING PERIOD									
YEAR	MO	DAY				YEAR	MO	DAY	
07	06	01	TO			07	06	30	

No Data Indicator ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0	PERMIT	*****	*****		*****	30	100			Weekly	GRAB
Effluent Gross	REQUIREMENT					MO AVG	DAILY MX	mg/L			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0	PERMIT	Req Mon	Req Mon		*****	*****	*****			Weekly	ESTIMA
Effluent Gross	REQUIREMENT	MO AVG	DAILY MX	Mgal/d							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-5203	07	07	26
TYPED OR PRINTED		AREA Code	NUMBER	YEAR	MO	DAY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.