

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)		Prior to entering MODE 2 or 3 from MODE 4, if not performed within the previous 92 days, for isolation devices inside primary containment, drywell, or steam tunnel
B. One or more penetration flow paths with two PCIVs inoperable except due to leakage not within limit.	<p>-----NOTE-----</p> <p>Relief valves are not required to be de-activated provided the relief setpoint is at least 23 psig and one of the following criteria is met:</p> <ol style="list-style-type: none"> 1. the relief valve is one-inch nominal size or less, or 2. the flow path is into a closed system whose piping pressure rating exceeds the containment design pressure rating. <p>-----</p> <p>B.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange.</p>	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more penetration flow paths with leakage rate not within limit except for purge valve leakage.	C.1 Restore leakage rate to within limit.	4 hours

(continued)

ACTION (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more penetration flow paths with one PCIV inoperable except due to leakage not within limit.	<p>-----NOTE-----</p> <p>Relief valves are not required to be de-activated provided the relief setpoint is at least 23 psig and one of the following criteria is met:</p> <ol style="list-style-type: none"> 1. the relief valve is one-inch nominal size or less, or 2. the flow path is into a closed system whose piping pressure rating exceeds the containment design pressure rating. <p>-----</p>	
	<p>A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.</p>	<p>4 hours except for main steam line</p> <p><u>AND</u></p> <p>8 hours for main steam line</p>
	<p><u>AND</u></p> <p>A.2 -----NOTE-----</p> <p>Isolation devices in high radiation areas may be verified by use of administrative means.</p> <p>-----</p> <p>Verify the affected penetration flow path is isolated.</p>	<p>Once per 31 days for isolation devices outside primary containment, drywell, and steam tunnel</p> <p><u>AND</u></p>
		(continued)