

**Maximum Safety Dry-Bulb Temperature and Coincident Wet-Bulb Temperature:** These values represent a maximum dry-bulb temperature that exists for 2 hours or more, combined with the maximum wet-bulb temperature that exists in that population of dry-bulb temperatures.

Time Frame	DegC	DegF	Date	Duration
1966-1967	35.6	96.08	7/11/1966	2-hours
			8/21/1968 8/22/1968	
1967-1972	37.8	100.04	8/23/1968	2-hours
1972-1981	40.6	105.08	7/13/1980	2-hours
<b>1981-1988</b>	<b>41.7</b>	<b>107.06</b>	<b>8/21/1983</b>	<b>2-hours</b>
1988-1995	39.4	102.92	6/21/1990	2-hours
1995-1996	37.2	98.96	7/2/1996	2-hours
Time Frame	DegC	DegF	Date	
Coincident Wet-bulb Temperature	26.57	79.83	8/21/1983	

**Maximum Safety Noncoincident Wet-Bulb Temperature:** This site parameter value represents a maximum wet-bulb temperature that exists within a set of hourly data for a duration of 2 hours or more.

Time Frame	DegC	DegF	Date	Duration
1966-1997	28.4	83.12	7/3/1997	2-hours