

Tier 2 Chapter 13 Revision 2 to Revision 3 Change List

Item	Location (e.g., subsection with paragraph/sentence/item, table with column/row, or figure)	Description of Change
1.	S13.02.03.01, 1 st para, 1 st sent	For clarity, appended reference NUREG-0737 to the end of the first sentence and deleted the text “Appendix 1A”. This appendix only addresses engineering design organization compliance with TMI action item 1.C.5, not the COL item described here.
2.	S13.02.03.02, 1 st para, 2 nd sent	For clarity, appended reference NUREG-0737 to the end of the second sentence.
3.	S13.02.04, References	Added reference, NUREG-0737, Clarification of TMI Action Plan Requirements, November 1980, since this reference is now used in previous sections.
4.	S13.03.03, section title	For clarification deleted the word “License” from the title.
5.	S13.03.03.01, 2 nd para, 1 st sent	For flexibility removed the text “touch-tone”, given the on-going evolution of telephone technology.
6.	S13.03.03.01, 2 nd para, 2 nd sent	Added clarification, flexibility, and division of responsibility, by revising the second sentence to read, “Any supplemental communications systems are also to be specified by the COL applicant as appropriate.”
7.	S13.03.03.02, new 3 rd para	Additional COL info provided in response to <u>RAI 9.5-25, 9.5-28, and 9.5-43</u> . For clarification of responsibility, added new 3 rd paragraph to read, “The COL applicant is responsible for the design of the communication system and the backup power supply for non-portable communication equipment located in the EOF in accordance 10 CFR 73.55(e) and 73.55(f) and NUREG-0696.”
8.	S13.03.04, new 2 nd reference	Added new reference that was used in the previous sections as follows: 13.3-2 NUREG-0696, Functional Criteria for Emergency Response Facilities, December 1980.
9.	S13.04.01, 2 nd sent	Added “Draft Regulatory Guide” in front of DG-1145 for clarity.
10.	S13.05.03.01, 2 nd bullet	For clarity, appended reference NUREG-0737 to the end of the second sentence of the second bullet. Deleted TMI Item I.C.9, because TMI Item I.C.9 (from NUREG-0660, May 1980), was addressed in I.C.1 of NUREG-0737 as stated in NUREG-0933 Task I.C, Operating Procedures Rev. 4.
11.	S13.05.03.03, 2 nd bullet	In response to <u>RAI 18.9-2</u> , for clarification appended 2 nd bulleted item to read, “1994: R1999, as endorsed by Regulatory Guide 1.33 Revision 2.”

Item	Location (e.g., subsection with paragraph/sentence/item, table with column/row, or figure)	Description of Change
12.	S13.05.03.03, 6 th bullet	For clarity, appended reference NUREG-0737 to the end of the second sentence of the sixth bullet.
13.	S13.05.03.04, 2 nd , 4 th , 5 th and 7 th para	In response to RAI 18.9-2, for clarification for all occurrences of ANSI/ANS-3.2 appended to read, “1994: R1999, as endorsed by Regulatory Guide 1.33 Revision 2.”
14.	S13.05.03.04, 8 th para, new 2 nd sent	In response to <u>RAI 7.1-38</u> , added new second sentence to section to read, “The COL Holder will ensure that all portions of the safety-related logic circuitry are adequately covered in the surveillance procedures as described in Generic Letter 96-01”.
15.	S13.05.04, new 2 nd and 3 rd reference	For completeness because of new references, added new references as follows: 13.5-2 ANSI/ANS-3.2-1994: R1999, Administrative Controls and Quality Assurance for the Operational Phase of Nuclear Power Plants. 13.5-3 NUREG-0737, Clarification of TMI Action Plan Requirements, November 1980.
16.	Acronym List	Revised the acronym list to include only acronyms used in this DCD Chapter 13.