

ENCLOSURE 1

REVISED PAGES OF RENEWED FACILITY OPERATING LICENSES DPR-67 and NPF-16

DOCKET NOS. 50-335 AND 50-389

ST. LUCIE PLANT, UNITS 1 AND 2

Replace the following pages of the Renewed Facility Operating Licenses. The revised pages are identified by the date of the letter issuing these pages and contain marginal lines indicating the areas of change.

REMOVE

License DPR-67

Page 4

License NPF-16

Page 6

INSERT

License DPR-67

Page 4

Page 5

License NPF-16

Page 6

E. Fire protection

FPL shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Analysis Report for the facility (The fire protection program and features were originally described in FPL submittals L-83-514 dated October 7, 1983, L-83-227 dated April 12, 1983, L-83-261 dated April 25, 1983, L-83-453 dated August 24, 1983, L-83-488 dated September 16, 1983, L-83-588 dated December 14, 1983, L-84-346 dated November 28, 1984, L-84-390 dated December 31, 1984, and L-85-71 dated February 21, 1985) and as approved by NRC letter dated July 17, 1984, and supplemented by NRC letters dated February 21, 1985, March 5, 1987, and October 4, 1988, subject to the following provision:

FPL may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

F. Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provision of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contains Safeguards Information protected under 10 CFR 73.21, is entitled: "Florida Power and Light & FPL Energy Seabrook Physical Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan - Revision 3," submitted by letter dated May 18, 2006.

G. Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel

Renewed License No. DPR-67
~~Revised by letter dated May 3, 2007~~
Revised by letter dated August 16, 2007

- (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy
 - 5. Identification of readily-available pre-staged equipment
 - 6. Training on integrated fire response strategy
 - 7. Spent fuel pool mitigation measures
- (c) Actions to minimize release to include consideration of:
 - 1. Water spray scrubbing
 - 2. Dose to onsite responders

- 4. This renewed license is effective as of the date of issuance, and shall expire at midnight March 1, 2036.

FOR THE NUCLEAR REGULATORY COMMISSION

ORIGINAL SIGNED BY
J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Attachments:

- 1. Appendix A, Technical Specification
- 2. Appendix B, Environmental Protection Plan

L. Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that includes the following key areas:

- (a) Fire fighting responses strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel
- (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy
 - 5. Identification of readily-available pre-staged equipment
 - 6. Training on integrated fire response strategy
 - 7. Spent fuel pool mitigation measures
- (c) Actions to minimize release to include consideration of:
 - 1. Water spray scrubbing
 - 2. Dose to onsite responders

4. This renewed license is effective as of the date of issuance, and shall expire at midnight April 6, 2043.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Attachments:

- 1. Appendix A, Technical Specifications
- 2. Appendix B, Environmental Protection Plan
- 3. Appendix C, Antitrust Conditions
- 4. Appendix D, Antitrust Conditions

Date of Issuance: October 2, 2003

Renewed License No. NPF-16
Revised by letter dated August 16, 2007