

From: Johnny Hughey
To: thomas.loomis@exeloncorp.com
Date: 07/31/2007 8:57:34 AM
Subject: DRAFT RAI For MD3717/3718

Tom:

NRC technical staff have provided the following draft Request for Additional Information (RAI) related to the Exelon amendment request dated November 17, 2006, regarding revisions to the local power range monitor calibration frequency (TACs MD3717/3718). After reviewing this draft RAI, please contact me at 301-415-3204 to discuss the need for a teleconference concerning the RAI and to discuss a due date for the response.

Thank you,
John Hughey, PM
NRR/DORL/LPL1-2
U.S. Nuclear Regulatory Commission
Mail Stop #: O-8B3
Phone #: 301-415-3204
E-Mail jd4@nrc.gov

DRAFT RAI (TACs MD 3717/3718)

Confirm that the change in LPRM calibration frequency continues to allow the 25 percent extension of the calibration interval as stated in the TS provisions of SR 3.0.2. Provide the analysis that shows that the LPRM response uncertainty remains bounded by the MCPR safety limits at 2500 MWD/T

Mail Envelope Properties (46AF31BE.3C7 : 20 : 10978)

Subject: DRAFT RAI For MD3717/3718
Creation Date 07/31/2007 8:57:34 AM
From: Johnny Hughey

Created By: JDH4@nrc.gov

Recipients

exeloncorp.com
thomas.loomis (thomas.loomis@exeloncorp.com)

Post Office

Route

exeloncorp.com

Files	Size	Date & Time
MESSAGE	1861	07/31/2007 8:57:34 AM

Options

Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No

Security:

Standard