

August 21, 2007

Mr. William Levis  
President & Chief Nuclear Officer  
PSEG Nuclear LLC - N09  
Post Office Box 236  
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - REQUEST FOR ADDITIONAL  
INFORMATION REGARDING REQUEST FOR EXTENDED POWER UPRATE  
(TAC NO. MD3002)

Dear Mr. Levis:

By letter dated September 18, 2006, as supplemented on October 10 and October 20, 2006; February 14, February 16, February 28, March 13, April 18, April 30, May 10, May 18, June 22, and August 3, 2007, PSEG Nuclear, LLC submitted an amendment request for an extended power uprate for Hope Creek Nuclear Generating Station. The proposed amendment would increase the authorized maximum power level by approximately 15 percent, from 3339 megawatts thermal (MWt) to 3840 MWt.

The Nuclear Regulatory Commission staff has been reviewing the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information. The questions were sent by e-mail to you to ensure that the questions were understandable, the regulatory basis was clear and to determine if the information was previously docketed. Mr. Paul Duke of your staff agreed to respond by August 31, 2007.

Please note that if you do not respond to this letter within the prescribed response times or provide an acceptable alternate date in writing, we may reject your application for amendment under the provisions of Title 10 of the *Code of Federal Regulations*, Section 2.108. If you have any questions, I can be reached at (301) 415-3100.

Sincerely,

/ra/ (R.B. Ennis for)

John G. Lamb, Senior Project Manager  
Project Directorate I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosure: As stated

cc: See next page

August 21, 2007

Mr. William Levis  
President & Chief Nuclear Officer  
PSEG Nuclear LLC - N09  
Post Office Box 236  
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - REQUEST FOR ADDITIONAL  
INFORMATION REGARDING REQUEST FOR EXTENDED POWER UPRATE  
(TAC NO. MD3002)

Dear Mr. Levis:

By letter dated September 18, 2006, as supplemented on October 10 and October 20, 2006; February 14, February 16, February 28, March 13, April 18, April 30, May 10, May 18, June 22, and August 3, 2007, PSEG Nuclear, LLC submitted an amendment request for an extended power uprate for Hope Creek Nuclear Generating Station. The proposed amendment would increase the authorized maximum power level by approximately 15 percent, from 3339 megawatts thermal (MWt) to 3840 MWt.

The Nuclear Regulatory Commission staff has been reviewing the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information. The questions were sent by e-mail to you to ensure that the questions were understandable, the regulatory basis was clear and to determine if the information was previously docketed. Mr. Paul Duke of your staff agreed to respond by August 31, 2007.

Please note that if you do not respond to this letter within the prescribed response times or provide an acceptable alternate date in writing, we may reject your application for amendment under the provisions of Title 10 of the *Code of Federal Regulations*, Section 2.108. If you have any questions, I can be reached at (301) 415-3100.

Sincerely,

*/ra/ (R.B. Ennis for)*

John G. Lamb, Senior Project Manager  
Project Directorate I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosure: As stated

cc: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDorLp1-2	RidsOgcRP	LPL1-2 R/F
RidsNrrLASLittle	RidsNrrLAABaxter	RidsAcrcAcnwMailCenter	TScarborough
RodsNrrPMJLamb	RidsNrrDorIDpr	RidsRgn1MailCenter	GPurciarello
JQuichocho			

ADAMS Accession No: ML072320134

OFFICE	LPL1-2/PM	LPL1-2/LA	LPL1-1/LA	SBPB/BC	LPL1-2/BC
NAME	JLamb(REnnis for)	ABaxter	SLittle(RSola	DHarrison	HChernoff (GEMiller for)
DATE	8/21/07	8/21/07	8/21/07	8/21/07	8/21/07

OFFICIAL RECORD COPY

Hope Creek Generating Station

cc:

Mr. Thomas Joyce  
Senior Vice President - Operations  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Dennis Winchester  
Vice President - Nuclear Assessment  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. George Barnes  
Site Vice President - Hope Creek  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Carl Fricker  
Vice President - Operations Support  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. John Perry  
Plant Manager - Hope Creek  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. James Mallon  
Manager - Licensing  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Jeffrie J. Keenan, Esquire  
PSEG Nuclear - N21  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Michael Gaffney  
Manager - Hope Creek Regulatory Assurance  
PSEG Nuclear  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Township Clerk  
Lower Alloways Creek Township  
Municipal Building, P.O. Box 157  
Hancocks Bridge, NJ 08038

Mr. Paul Bauldauf, P.E., Asst. Director  
Radiation Protection Programs  
NJ Department of Environmental  
Protection and Energy  
CN 415  
Trenton, NJ 08625-0415

Mr. Brian Beam  
Board of Public Utilities  
2 Gateway Center, Tenth Floor  
Newark, NJ 07102

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector  
Hope Creek Generating Station  
U.S. Nuclear Regulatory Commission  
Drawer 0509  
Hancocks Bridge, NJ 08038

REQUEST FOR ADDITIONAL INFORMATION  
REGARDING TECHNICAL SPECIFICATION CHANGES FOR  
EXTENDED POWER UPRATE  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354

By letter dated September 18, 2006, as supplemented on October 10 and October 20, 2006; February 14, February 16, February 28, March 13, April 18, April 30, May 10, May 18, June 22, and August 3, 2007, PSEG Nuclear, LLC submitted an amendment request for an extended power uprate for Hope Creek Nuclear Generating Station. The proposed amendment would increase the authorized maximum power level by approximately 15 percent, from 3339 megawatts thermal (MWt) to 3840 MWt.

The Nuclear Regulatory Commission staff is reviewing your submittal and has determined that additional information is needed to complete its review. The specific information requested is addressed below.

**7      Balance of Plant Branch (SBPB)**

- 7-19    Updated Final Safety Analysis Report, Section 9.1.3.2.3 refers to Seismic Category I emergency fuel pool water makeup from station service water system (SSWS) loop A and a redundant makeup line from SSWS loop B. In addition, a fire hose fill connection located in the auxiliary building ties into the makeup line from SSWS loops A and B and provides supplementary makeup water.

Power Uprate Safety Analysis Report, Section 6.3.1 states that three Seismic Category I emergency makeup sources, the low pressure coolant injection, emergency fire makeup system, and the service water system, have a makeup capability greater than 130 gallons per minute.

The two sources above are not consistent and clear. Please clarify the source, makeup capability and seismic category of each emergency fuel pool water makeup source to the spent fuel pool.

Enclosure