

August 27, 2007

LICENSEE: PPL Susquehanna, LLC

FACILITY: Susquehanna Steam Electric Station, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 26, 2007,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PPL
SUSQUEHANNA, LLC, CONCERNING DRAFT REQUESTS FOR ADDITIONAL
INFORMATION PERTAINING TO THE SUSQUEHANNA STEAM ELECTRIC
STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of PPL Susquehanna, LLC held a telephone conference call on July 26, 2007, to discuss and clarify the staff's draft requests for additional information (D-RAIs) concerning the Susquehanna Steam Electric Station, Units 1 and 2, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's D-RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the D-RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Evelyn Gettys, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosures:

1. List of Participants
2. List of Draft Requests for
Additional Information

cc w/encls: See next page

August 27, 2007

LICENSEE: PPL Susquehanna, LLC

FACILITY: Susquehanna Steam Electric Station, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 26, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PPL SUSQUEHANNA, LLC, CONCERNING DRAFT REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of PPL Susquehanna, LLC held a telephone conference call on July 26, 2007, to discuss and clarify the staff's draft requests for additional information (D-RAIs) concerning the Susquehanna Steam Electric Station, Units 1 and 2, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's D-RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the D-RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Evelyn Gettys, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosures:

1. List of Participants
2. List of Draft Requests for Additional Information

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: ML072330167

OFFICE	PM:RLRA:DLR	LA:DLR	BC:RLRA:DLR
NAME	EGettys	SFigueroa	LLund
DATE	08/22/07	08/22/07	08/27/07

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

LIST OF PARTICIPANTS

JULY 26, 2007

PARTICIPANTS

Evelyn Gettys
George Thomas
David Jeng
Duane Filchner
Ross Gardner

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
PPL Susquehanna, LLC
PPL Susquehanna, LLC

DRAFT REQUESTS FOR ADDITIONAL INFORMATION
SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION

July 26, 2007

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of PPL Susquehanna, LLC held a telephone conference call on July 26, 2007, to discuss and clarify the following draft requests for additional information (D-RAIs) concerning the Susquehanna Steam Electric Station (SSES), Units 1 and 2 license renewal application (LRA).

D-RAI 2.4-1

The first sentence in the fourth paragraph of the LRA Section 2.4 "Scoping and Screening Results: Structures" states that "The major structures in the scope of license renewal are the: ...". Per Title 10 of the *Code of Federal Regulations*, Part 54.4 (10 CFR 54.4), all structures that perform an intended function stated in 10 CFR 54.4(a) are required to be included within the scope of license renewal and not just the major structures. Please confirm that the in-scope structures and structure categories listed in Section 2.4 is all inclusive. Please clarify the language used in that section of the LRA, "The major structures in the scope ...". Please include any remaining structures that may be within the scope of license renewal and provide corresponding scoping, screening and aging management review (AMR) results information relevant to the LRA.

Discussion: The applicant will remove the term "major" and list the structures as discussed. They indicated that the question is clear. This D-RAI will be sent as a formal RAI.

D-RAI 2.4.1-2

Table 2.4-1 lists penetrations (mechanical and electrical, primary containment boundary) as components subject to an AMR. This does not seem to include the penetrations through the Reactor Shield Wall with hinged doors or removable plugs that facilitate piping (feedwater, reactor recirculation, recirculation inlet, etc.) connections to the reactor vessel which would provide access for in-service inspection (see FSAR Section 3.8.3.1.3 and drawings C-1932 Sheets 3 & 5). Please confirm the inclusion or exclusion of these penetrations and their doors/plugs from the scope of license renewal (LR) and subject to an AMR. If they were not included as an oversight, please provide a description of their scoping, screening and AMR. If they are excluded from the scope of license renewal, please provide the technical basis for the exclusion.

Discussion: The applicant indicated that the question is clear. This D-RAI will be sent as a formal RAI.

RAI 2.4.1-3

Section 2.4.1 and Table 2.4-1 list Access Hatches (equipment hatch, personnel airlock, suppression chamber access hatches, and the control rod drive removal hatch) as Primary Containment components subject to an AMR. It is not explicitly clear from Table 2.4-1 and

Table 2.4-10 if the flange double-gaskets, hatch locks, hinges and closure mechanisms that help prevent loss of sealing/leak-tightness for these listed hatches are included within the scope of LR and subject to an AMR. Please confirm the inclusion or exclusion of these components. If they were not included as an oversight, please provide a description of their scoping and AMR. If they are excluded from the scope of LR, please provide the technical basis for the exclusion

Discussion: The applicant indicated that the question is clear. This D-RAI will be sent as a formal RAI.

RAI 2.4.1-4

Based on information provided in LRA Section 2.4.1 and Tables 2.4-1 and 2.4-10, it is not clear if all drywell pipe restraints/whip restraints are within the scope of LR. If they are not included as an oversight, please provide a description of their scoping and AMR. If they are covered somewhere else in the LRA, please indicate the location. If they are excluded from the scope of LR, please provide the technical basis for the exclusion.

Discussion: The applicant indicated that the question is clear. This D-RAI will be sent as a formal RAI.

RAI 2.4.10-1

Sections 2.4.1 thru 2.4.9 state that the structural commodities for these respective structures are addressed in the bulk commodities evaluation in Section 2.4.10. Table 2.4-10 lists the Bulk Commodities Components Subject to an AMR in categories based on the material of the component type. This table does not identify the specific structures addressed in Sections 2.4.1 thru 2.4.9 in which these individual component types are located. Please add a column to Table 2.4-10 listing the structure(s) in which each bulk commodity component type is located. Clearly state if the intent of the Table is for every occurrence (all inclusive) of these component types in each of the applicable structures are in-scope and subject to an AMR. If not, specifically identify those cases which are in-scope and subject to an AMR and those that are not in-scope and excluded from an AMR with technical justification for exclusion. Please confirm and address if there is or is not any Lubrite sliding support bearings/surfaces in-scope and subject to an AMR and will need to be included in Table 2.4-10.

Discussion: The applicant indicated that the question is clear. This D-RAI will be sent as a formal RAI.

Letter to PPL Susquehanna, from E. Gettys, dated August 27, 2007

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JULY 26, 2007,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PPL
SUSQUEHANNA, LLC, CONCERNING DRAFT REQUESTS FOR ADDITIONAL
INFORMATION PERTAINING TO THE SUSQUEHANNA STEAM ELECTRIC
STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

SSmith (srs3)

SDuraiswamy

RidsNrrDlr

RidsNrrDlrRlra

RidsNrrDlrRlrb

RidsNrrDlrRlrc

RidsNrrDlrReba

RidsNrrDlrRebb

RidsNrrDci

RidsNrrDra

RidsNrrDe

RidsNrrDeEemb

RidsNrrDeEeeb

RidsNrrDss

RidsOgcMailCenter

RidsNrrAdes

YDiaz

RGuzman

BRogers

EGettys

Susquehanna Steam Electric Station,
Units 1 and 2

cc:

Robert A. Saccone
Vice President - Nuclear Operations
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB3
Berwick, PA 18603-0467

Terry L. Harpster
General Manager - Plant Support
PPL Susquehanna, LLC
769 Salem Blvd., NUCSA4
Berwick, PA 18603-0467

Rocco R. Sgarro
Manager - Nuclear Regulatory Affairs
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Walter E. Morrissey
Supervising Engineer
Nuclear Regulatory Affairs
PPL Susquehanna, LLC
769 Salem Blvd., NUCSA4
Berwick, PA 18603-0467

Michael H. Crowthers
Supervising Engineer
Nuclear Regulatory Affairs
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Steven M. Cook
Manager - Quality Assurance
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB2
Berwick, PA 18603-0467

Luis A. Ramos
Community Relations Manager,
Susquehanna
PPL Susquehanna, LLC
634 Salem Blvd., SSO
Berwick, PA 18603-0467

Bryan A. Snapp, Esq.
Associate General Counsel
PPL Services Corporation
Two North Ninth Street, GENTW3
Allentown, PA 18101-1179

Supervisor - Document Control Services
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Richard W. Osborne
Allegheny Electric Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, PA 17108-1266

Director, Bureau of Radiation Protection
Pennsylvania Department of
Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 35, NUCSA4
Berwick, PA 18603-0035

Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Board of Supervisors
Salem Township
P.O. Box 405
Berwick, PA 18603-0035

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
443 Orlando Avenue
State College, PA 16803

Susquehanna Steam Electric Station,
Units 1 and 2

-2-

cc:

Ms. Julie Keys
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708