

ENCLOSURE 1

REVISED PAGES OF RENEWED FACILITY OPERATING LICENSE DPR-28

DOCKET NOS. 50-271

VERMONT YANKEE NUCLEAR POWER STATION

Replace the following page of the Renewed Facility Operating License. The revised pages are identified by the date of the letter issuing these pages and contain marginal lines indicating the areas of change.

REMOVE

Page 13

-----

INSERT

Page 13

Page 14

7. The requirements of paragraph 4 above for meeting the SDMP shall be implemented upon issuance of the EPU license amendment and shall continue until the completion of one full operating cycle at EPU. If an unacceptable structural flaw (due to fatigue) is detected during the subsequent visual inspection of the steam dryer, the requirements of paragraph 4 shall extend another full operating cycle until the visual inspection standard of no new flaws/flaw growth based on visual inspection is satisfied.
8. This license condition shall expire upon satisfaction of the requirements in paragraphs 5, 6, and 7 provided that a visual inspection of the steam dryer does not reveal any new unacceptable flaw or unacceptable flaw growth that is due to fatigue.

N. Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
    1. Pre-defined coordinated fire response strategy and guidance
    2. Assessment of mutual aid fire fighting assets
    3. Designated staging areas for equipment and materials
    4. Command and control
    5. Training of response personnel
  - (b) Operations to mitigate fuel damage considering the following:
    1. Protection and use of personnel assets
    2. Communications
    3. Minimizing fire spread
    4. Procedures for implementing integrated fire response strategy
    5. Identification of readily-available pre-staged equipment
    6. Training on integrated fire response strategy
    7. Spent fuel pool mitigation measures
  - (c) Actions to minimize release to include consideration of:
    1. Water spray scrubbing
    2. Dose to onsite responders
- O. The licensee shall implement and maintain all Actions required by Attachment 2 to NRC Order EA-06-137, issued June 20, 2006, except the last action that requires incorporation of the strategies into the site security plan, contingency plan, emergency plan and/or guard training and qualification plan, as appropriate.

4. This license is effective as of the date of issuance and shall expire at midnight on March 21, 2012.

A-127  
12/17/90

FOR THE ATOMIC ENERGY COMMISSION

Original Signed By  
Roger S. Boyd /f/

A. Giambusso, Deputy Director  
for Reactor Projects  
Directorate of Licensing

Enclosures:  
Appendix A Technical Specifications

Date of Issuance:  
Feb. 28, 1973