

August 23, 2007

Mr. Christopher M. Crane
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3, AND QUAD CITIES
NUCLEAR POWER STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING CLARIFICATION OF THE BACKUP STABILITY
PROTECTION METHODOLOGY EVALUATION (TAC NOS. MD4866 THRU
MD4869)

Dear Mr. Crane:

By letter to the Nuclear Regulatory Commission (NRC) dated March 9, 2007, Exelon Generation Company, LLC submitted a request to revise the safety evaluation for the April 4, 2006, amendment to reflect that the immediate scram region is defined as the area in the power-flow map where the decay ratio is > 0.8 , and the controlled entry region is defined as the area in the power-flow map where the decay ratio is > 0.8 - cycle uncertainty, for the Dresden Nuclear Power Station, Units 2 and 3, and the Quad Cities Nuclear Power Station, Units 1 and 2.

The NRC staff is reviewing your submittal and has determined that additional information is required to complete the review. The specific information requested is addressed in the enclosure to this letter. A facsimile of the questions was sent to your staff on July 17, 2007. During a discussion with Mr. Ken Nicely of your staff on August 16, 2006, Mr. Nicely indicated a clarification conference call was not needed for these questions, and agreed that you would provide a response by September 14, 2007.

C. Crane

- 2 -

The NRC staff considers that timely responses to requests for additional information help ensure sufficient time is available for staff review and contribute toward the NRC's goal of efficient and effective use of staff resources. If circumstances result in the need to revise the requested response date, please contact me at (301) 415-1470.

Sincerely,

/RA/

Christopher Gratton, Senior Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-237 and 50-249; and
50-254 and 50-265

Enclosure:
Request for Additional Information

cc w/encl: See next page

C. Crane

- 2 -

The NRC staff considers that timely responses to requests for additional information help ensure sufficient time is available for staff review and contribute toward the NRC's goal of efficient and effective use of staff resources. If circumstances result in the need to revise the requested response date, please contact me at (301) 415-1470.

Sincerely,

/RA/

Christopher Gratton, Senior Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-237 and 50-249; and
50-254 and 50-265

Enclosure:
Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC
RidsNrrPMCGratton
RidsOgcRp
THuang, NRR

LPL3-2 R/F
RidsNrrLAEWhitt
RidsRgn3MailCenter
RidsNrrPMMThorpe-Kavanaugh

RidsNrrDorlLpl3-2
RidsAcrcAcnwMailCenter
RidsNrrDorlDpr

ADAMS Accession Number: ML072330244 NRR-088

OFFICE	LPL3-2/PM	LPL3-2/LA	LPL3-2/BC
NAME	CGratton	EWhitt	RGibbs
DATE	8/20/07	8/20/07	8/23/07

OFFICIAL RECORD COPY

Dresden and Quad Cities Nuclear Power Stations

cc:

Site Vice President - Dresden Nuclear Power Station
via e-mail

Plant Manager - Dresden Nuclear Power Station
via e-mail

Manager Regulatory Assurance - Dresden
via e-mail

U.S. Nuclear Regulatory Commission
Dresden Resident Inspectors Office
6500 N. Dresden Road
Morris, IL 60450-9766

Chairman
Grundy County Board
Administration Building
1320 Union Street
Morris, IL 60450

Illinois Emergency Management Agency
Division of Disaster Assistance & Preparedness
1035 Outer Park Dr
Springfield, IL 62704

Document Control Desk - Licensing
via e-mail

Senior Vice President Operations Support
via e-mail

Vice President - Regulatory Affairs
via e-mail

Director - Licensing and Regulatory Affairs
via e-mail

Associate General Counsel
via e-mail

Manager Licensing - Dresden and Quad Cities
via e-mail

Site Vice President - Quad Cities
via e-mail

Plant Manager - Quad Cities
via e-mail

Regulatory Assurance Manager - Quad Cities
via e-mail

Senior Resident Inspector
Quad Cities Resident Inspectors Office
via e-mail

David C. Tubbs
via e-mail

Senior Vice President - Midwest Operations
via e-mail

Vice President - Law and Regulatory Affairs
MidAmerican Energy Company
One River Center Place
106 E. Second Street
P.O. Box 4350
Davenport, IA 52808

Chairman
Rock Island County Board of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, IL 61201

REQUEST FOR ADDITIONAL INFORMATION

DRESDEN NUCLEAR STATION, UNITS 2 AND 3, AND

QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2

DOCKET NOS. 50-237, 50-249, 50-254, AND 50-265

The NRC staff has reviewed the March 9, 2007, Safety Evaluation revision request and has identified the following questions to be addressed by the licensee in order to complete our evaluation.

- A. Please document the procedure used to calculate the cycle uncertainty (cu) term used to define the controlled entry region.
- B. Please provide the specific values for cu used for the latest reload in Dresden Nuclear Station, Units 2 and 3 (DNPS), and Quad Cities Nuclear Power Station, Units 1 and 2 (QCNPS).
- C. Please describe which approved codes are used to generate the cycle uncertainty. Include a short description of any benchmark data to support the generic or plant-specific cu values used in DNPS and QCNPS.

Enclosure