



SOUTHERN CALIFORNIA
EDISON[®]

An EDISON INTERNATIONAL[®] Company

Dr. Raymond W. Waldo
Vice President - Nuclear
San Onofre

August 17, 2007

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: **Docket No. 50-361**
Licensee Event Reports Nos. 2007-001 and 2007-002
San Onofre Nuclear Generating Station, Unit 2

Dear Sir or Madam:

On June 20, 2007, San Onofre Nuclear Generating Station (SONGS) Unit 2 Instrument Air System failed and Operators manually tripped the reactor. This letter provides two Licensee Event Reports (LER) associated with this event. The LER 2007-001 discusses the Instrument Air system failure and reactor trip. The LER 2007-002 discusses a separate Technical Specification violation that occurred following that reactor shutdown. This event did not affect the health and safety of either plant personnel or the public.

If you require any additional information, please contact me.

Sincerely,

Raymond Waldo

Unit 2 LER No. 2007-001
Unit 2 LER No. 2007-002

cc: B. S. Mallett, NRC Regional Administrator, Region IV
C. C. Osterholtz, NRC Senior Resident Inspector, San Onofre Units 2 & 3

Mail Stop D45
P.O. Box 128
San Clemente, CA 92672
949-368-8725
Fax 949-368-6183
waldorw@songs.sce.com

IE22
NRR