

(1) Maximum Power Level

Carolina Power & Light Company is authorized to operate the facility at reactor core power levels not in excess of 2900 megawatts thermal (100 percent rated core power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. \_\_\_\_\_, are hereby incorporated into this license. Carolina Power & Light Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Antitrust Conditions

Carolina Power & Light Company shall comply with the antitrust conditions delineated in Appendix C to this license.

(4) Initial Startup Test Program (Section 14)<sup>1</sup>

Any changes to the Initial Test Program described in Section 14 of the FSAR made in accordance with the provisions of 10 CFR 50.59 shall be reported in accordance with 50.59(b) within one month of such change.

(5) Steam Generator Tube Rupture (Section 15.6.3)

Prior to startup following the first refueling outage, Carolina Power & Light Company shall submit for NRC review and receive approval of a steam generator tube rupture analysis, including the assumed operator actions, which demonstrates that the consequences if the design basis steam generator tube rupture event for the Shearon Harris Nuclear Power Plant are less than the acceptance criteria specified in the Standard Review Plan, NUREG-0800, at §15.6.3 Subparts II(1) and (2) for calculated doses from radiological releases. In preparing their analysis Carolina Power & Light Company will not assume that operators will complete corrective actions within the first thirty minutes after a steam generator tube rupture.

---

<sup>1</sup>The parenthetical notation following the title of many license conditions denotes the section of the Safety Evaluation Report and/or its supplements wherein the license condition is discussed.

TABLE 2.2-1 (continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TOTAL ALLOWANCE (TA)</u>	<u>Z</u>	<u>SENSOR ERROR (S)</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
12. Reactor Coolant Flow-Low	4.58	1.98	0.6	≥ 90.5% of loop full indicated flow	≥ 89.5% of loop full indicated flow
13. Steam Generator Water Level Low-Low	25.0	17.45	2.0	≥ 25.0% of narrow range instrument span	≥ 23.5% of narrow range instrument span
14. Steam Generator Water Level - Low Coincident With Steam/Feedwater Flow Mismatch	8.9	5.95	2.0	≥ 25.0% of narrow range instrument span	≥ 24.05% of narrow range instrument span
	20.0	3.01	Note 6	≤ 40% of full steam flow at RTP**	≤ 43.1% of full steam flow at RTP**
15. Undervoltage - Reactor Coolant Pumps	14.0	1.3	0.0	≥ 5148 volts	≥ 4920 volts
16. Underfrequency - Reactor Coolant Pumps	5.0	3.0	0.0	≥ 57.5 Hz	≥ 57.3 Hz
17. Turbine Trip					
a. Low Fluid Oil Pressure	N.A.	N.A.	N.A.	≥ 1000 psig	≥ 950 psig
b. Turbine Throttle Valve Closure	N.A.	N.A.	N.A.	≥ 1% open	≥ 1% open
18. Safety Injection Input from ESF	N.A.	N.A.	N.A.	N.A.	N.A.

\*\*RTP = RATED THERMAL POWER

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TOTAL ALLOWANCE (TA)</u>	<u>Z</u>	<u>SENSOR ERROR (S)</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
5. Turbine Trip and Feedwater Isolation (Continued)					
b. Steam Generator Water Level--High-High (P-14)	22.0	8.15	2.0	≤ 78.0% of narrow range instrument span.	≤ 79.5% of narrow range instrument span.
c. Safety Injection	See Item 1. above for Safety Injection Trip Setpoints and Allowable Values.				
6. Auxiliary Feedwater					
a. Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
c. Steam Generator Water Level--Low-Low	25.0	17.45	2.0	≥ 25.0% of narrow range instrument span.	≥ 23.5% of narrow range instrument span.
d. Safety Injection Start Motor-Driven Pumps	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.				
e. Loss-of-Offsite Power Start Motor-Driven Pumps and Turbine-Driven Pump	See Item 9. below for all Loss-of-Offsite Trip Setpoint and Allowable Values.				
f. Trip of All Main Feedwater Pumps Start Motor-Driven Pumps	N.A.	N.A.	N.A.	N.A.	N.A.