

September 7, 2007

Mr. Kevin T. Walsh
Vice President of Operations
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-3093

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - EVALUATION OF
FINITE ELEMENT ANALYSIS IN SUPPORT OF ALLOY 82/182 PRESSURIZER
BUTT WELD INSPECTIONS IN 2008 AS PROVIDED BY CONFIRMATORY
ACTION LETTER NRR-07-006 (TAC NO. MD4196)

Dear Mr. Walsh:

On March 20, 2007, the U.S. Nuclear Regulatory Commission (NRC) issued Confirmatory Action Letter (CAL) No. NRR-07-006 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070710563) regarding dissimilar metal welds in the pressurizer surge, spray, and safety/relief nozzle-to-safe end welds at Waterford Steam Electric Station, Unit 3 (Waterford 3). The CAL and the supporting commitment letter (ADAMS Accession No. ML070590205) indicate that inspection and mitigation actions may be conducted during your spring 2008 refueling outage, contingent on the industry providing an analysis that demonstrates an acceptable level of safety to the NRC for the operation of these welds until spring 2008. This letter acknowledges receipt of your letter dated August 7, 2007 (ADAMS Accession No. ML072410201), informing the NRC that the analysis referred to by this CAL and the supporting commitment letter has been completed, and that the analysis is applicable to your plant.

The NRC received MRP-216, Rev. 1, "Materials Reliability Program: Advanced FEA [Finite Element Analysis] Evaluation of Growth of Postulated Circumferential PWSCC [Primary Water Stress-Corrosion Cracking] Flaws in Pressurizer Nozzle Dissimilar Metal Welds" on August 13, 2007 (ADAMS Accession No. ML072410235). Based on our review of this report, the NRC concludes that the analysis provides adequate justification to permit inspections during your spring 2008 refueling outage, and that the analysis is applicable to Waterford 3. The results of the staff's review are contained in a safety assessment dated August 31, 2007 (ADAMS Accession No. ML072400199), and the associated contractor report (ADAMS Accession No. ML072470394).

Based on the above, the NRC concludes that a plant shutdown by December 31, 2007, is no longer required. Therefore, the pressurizer surge, spray, and safety/relief nozzle-to-safe end Alloy 82/182 butt weld inspections for Waterford 3 must be performed prior to exiting your scheduled spring 2008 refueling outage. All other requirements of the CAL and the supporting commitment letter regarding enhanced inspection and leakage monitoring requirements for the reactor coolant system and associated reports remain valid.

The CAL will remain open until all CAL commitments pertaining to Waterford 3 are complete.

Current NRC guidance regarding CALs is contained in the NRC Enforcement Policy and the NRC Enforcement Manual, which are available at the NRC web site at <http://www.nrc.gov/about-nrc/regulatory/enforcement.html> (click on Enforcement Policy or Enforcement Guidance) or by contacting the Government Printing Office (GPO) toll-free at 1-888-293-6498. The GPO is open from 7:00 a.m. to 9:00 p.m. EST, Monday through Friday (except Federal holidays).

In accordance with Title 10 of the *Code of Federal Regulations*, Part 2, Section 390, of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm.html>.

Sincerely,

/RA/

Catherine Haney, Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

Current NRC guidance regarding CALs is contained in the NRC Enforcement Policy and the NRC Enforcement Manual, which are available at the NRC web site at <http://www.nrc.gov/about-nrc/regulatory/enforcement.html> (click on Enforcement Policy or Enforcement Guidance) or by contacting the Government Printing Office (GPO) toll-free at 1-888-293-6498. The GPO is open from 7:00 a.m. to 9:00 p.m. EST, Monday through Friday (except Federal holidays).

In accordance with Title 10 of the *Code of Federal Regulations*, Part 2, Section 390, of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm.html>.

Sincerely,

/RA/

Catherine Haney, Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

DISTRIBUTION:

PUBLIC	RidsNrrPMKKalyanam	RidsNrrDorl
LPL4 R/F	RidsNrrLAJBurkhardt	RidsNrrDirS
RidsAcrsAcnwMailCenter	RidsNrrDorlLpl4	DPelton, EDO RIV
RidsEdoMailCenter	RidsOEMailCenter	VDricks, OPA, RIV
RidsNrrDci	RidsOgcRp	WMaier, RIV SLO
RidsNrrDciCpnB	RidsRgn4MailCenter	TLupold, NRR
RidsNrrPMBMoroney	RidsNrrOd	ESullivan, NRR

ADAMS Accession No. ML072490169

OFFICE	DCI/CPNB	DCI/CPNB	LPL4/PM	LPL4/LA	LPL4/BC
NAME	TLupold	TChan	KKalyanam	JBurkhardt	Thiltz, BKS for
DATE	9/6/07	9/6/07	9/6/07	9/6/07	9/7/07
OFFICE	DCI/D	DRP/D, RGN4	DORL/D		
NAME	MEvans	DChamberlain	CHaney		
DATE	9/7/07	9/7/07 Wjones for	9/7/07		

OFFICIAL RECORD COPY

Waterford Steam Electric Station, Unit 3

cc:

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Ms. Kimberly S. Cook, Director
Nuclear Safety Assurance
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-0751

Mr. Joe Kowalewski
General Manager, Plant Operations
Waterford Steam Electric Station, Unit 3
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-0751

Manager, Licensing
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-0751

Resident Inspector
Waterford NPS
P.O. Box 822
Killona, LA 70057-0751

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Parish President Council
St. Charles Parish
P.O. Box 302
Hahnville, LA 70057

Mr. Jeff Forbes
Senior Vice President and
Chief Operating Officer
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Mr. John McCann
Director, Nuclear Safety & Licensing
Entergy Services, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Louisiana Department of Environmental
Quality Radiological Emergency Planning
and Response Division
P.O. Box 4312
Baton Rouge, LA 70821-4312

Louisiana Department of Environmental
Quality
Office of Environmental Compliance
P.O. Box 4312
Baton Rouge, LA 70821-4312

Chairman
Louisiana Public Services Commission
P.O. Box 91154
Baton Rouge, LA 70825-1697

Richard Penrod, Senior Environmental
Scientist/State Liaison Officer
Office of Environmental Services
Northwestern State University
Russell Hall, Room 201
Natchitoches, LA 71497

May 2007