

**From:** "Sanchez, Edward" <esanch1@entergy.com>  
**To:** "Denise A. Lamoureux" <dmarrie@entergy.com>, "Perry Buckberg" <PHB1@nrc.gov>  
**Date:** 8/23/2007 2:28:36 PM  
**Subject:** RE: Entergy Letter transmitting response for Pilgrim LRA commitment 47

This is a resend with date provided on the letter. Please discard copy sent earlier today.

Ed Sanchez  
Pilgrim Licensing

-----Original Message-----

From: Sanchez, Edward  
Sent: Thursday, August 23, 2007 2:06 PM  
To: 'Perry Buckberg'; Lamoureux, Denise A.  
Subject: Entergy Letter transmitting response for Pilgrim LRA commitment 47

Perry,

Attached for your use is a PDF copy of Entergy's response to LRA commitment 47 (to submit to the NRC by September 15, 2007 an action plan to improve benchmarking data to support approval of new P-T curves for Pilgrim.) Original is being put in US mail.

Regards,  
Ed Sanchez  
Pilgrim Licensing

**Hearing Identifier:** PilgrimRenewalNonPublic  
**Email Number:** 25

**Mail Envelope Properties** (46E50485.HQGWDO01.TWGWPO03.200.2000011.1.1006CF.1)

**Subject:** RE: Entergy Letter transmitting response for Pilgrim LRA commitment 47  
**Creation Date:** 8/23/2007 2:28:36 PM  
**From:** "Sanchez, Edward" <esanch1@entergy.com>

**Created By:** esanch1@entergy.com

**Recipients**

"Denise A. Lamoureux" <dmarrie@entergy.com>  
"Perry Buckberg" <PHB1@nrc.gov>

**Post Office**  
TWGWPO03.HQGWDO01

**Route**  
nrc.gov

<b>Files</b>	<b>Size</b>
MESSAGE	657
LRA commitment 47 response.pdf	
9/10/2007 8:47:01 AM	
Mime.822	354288

<b>Date &amp; Time</b>
8/23/2007 2:28:36 PM
256447
9/10/2007 8:47:01 AM

**Options**

<b>Priority:</b>	Standard
<b>Reply Requested:</b>	No
<b>Return Notification:</b>	None
	None

<b>Concealed Subject:</b>	No
<b>Security:</b>	Standard



Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360

Stephen J. Bethay  
Director, Nuclear Assessment

August 23, 2007

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

SUBJECT: Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
Docket No. 50-293 License No. DPR-35  
License Renewal Application Commitment 47 Response

REFERENCES: 1. Entergy Letter, License Renewal Application, dated  
January 25, 2006 (TAC MC9669)  
2. Entergy Letter, Proposed Change to the Applicability of Pilgrim's  
Pressure-Temperature Curves, dated January 15, 2007  
3. Entergy Letter, License Renewal Application Amendment 16,  
dated May 1, 2007.

LETTER NUMBER: 2.07.069

Dear Sir or Madam:

In Reference 1, Entergy Nuclear Operations, Inc. applied for renewal of the Pilgrim Nuclear Power Station operating license.

In Reference 2, Entergy made a commitment to submit to the NRC an action plan to improve benchmarking data to support approval of new P-T curves beyond cycle 18 for Pilgrim. This commitment was reaffirmed in Reference 3 as part of License Renewal Application Amendment 16. Attachment A provides the action plan to address this commitment.

This letter contains no new commitments.

Please contact Mr. Bryan Ford, (508) 830-8403, if you have questions regarding this subject.

Sincerely,

A handwritten signature in cursive script that reads "Stephen J. Bethay".

Stephen J. Bethay  
Director, Nuclear Safety Assessment

ERS/dl

Attachment A: Action Plan to Improve Benchmarking Data

cc: with Attachments

Mr. Perry Buckberg  
Project Manager  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Alicia Williamson  
Project Manager  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Susan L. Uttal, Esq.  
Office of the General Counsel  
U.S. Nuclear Regulatory Commission  
Mail Stop O-15 D21  
Washington, DC 20555-0001

Sheila Slocum Hollis, Esq.  
Duane Morris LLP  
1667 K Street N.W., Suite 700  
Washington, DC 20006

cc: without Attachments

Mr. James S. Kim, Project Manager  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
One White Flint North O-8C2  
11555 Rockville Pike  
Rockville, MD 20852

Mr. Jack Strosnider, Director  
Office of Nuclear Material and Safeguards  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-00001

Mr. Samuel J. Collins, Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

NRC Resident Inspector  
Pilgrim Nuclear Power Station

Mr. Joseph Rogers  
Commonwealth of Massachusetts  
Assistant Attorney General  
Division Chief, Utilities Division  
1 Ashburton Place  
Boston, MA 02108

Mr. Matthew Brock, Esq.  
Commonwealth of Massachusetts  
Assistant Attorney General  
Environmental Protection Division  
One Ashburton Place  
Boston, MA 02108

Diane Curran, Esq.  
Harmon, Curran, and Eisenberg, L.L.P.  
1726 M Street N.W., Suite 600  
Washington, DC 20036

Mr. Robert Walker, Director  
Massachusetts Department of Public Health  
Radiation Control Program  
Schraft Center, Suite 1M2A  
529 Main Street  
Charlestown, MA 02129

Mr. Ken McBride, Director  
Massachusetts Energy Management Agency  
400 Worcester Road  
Framingham, MA 01702

Mr. James E. Dyer, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-00001

## **ATTACHMENT A to Letter 2.07.069**

(1 page)

### **Action Plan to Improve Benchmarking Data**

By letter dated January 15, 2007, Entergy made a commitment to submit to the NRC an action plan to improve benchmarking data to support approval of new P-T curves for Pilgrim Station for operation beyond cycle 18. In addition, the draft Safety Evaluation Report for Pilgrim's license renewal application issued in March 2007 contained Open Item (OI) 4.2 related to neutron fluence calculations necessary to support new Pressure-Temperature (P-T) curves for Pilgrim Station beyond cycle 18. By letter dated May 1, 2007 Entergy submitted license renewal application amendment 16 which contained a response to address OI 4.2 that included commitment #47 to submit to the NRC an action plan to improve benchmarking data to support approval of new P-T curves for Pilgrim Station.

The benchmarking validation of the RAMA fluence calculation is ongoing for the Pilgrim reactor vessel and internals. Uncertainties between the calculated and measured results from the dosimetry are still being examined to determine a possible cause for the discrepancy. The following is the current action plan that Entergy is pursuing to resolve the issue.

- Perform a sensitivity study based on the fact that most of the core power history is from dosimetry that was removed from the Pilgrim vessel during refueling outage (RFO) 4. Entergy will further review the power history developed at Pilgrim Station and determine, based on the sensitivity study, if adjustments to the power history are warranted.
- Determine whether it would be useful to analyze jet pump swing gate samples that were removed from the Pilgrim vessel during RFO 16 in 2007 to obtain fluence information to validate the RFO 4 dosimetry.
- Review data from a similar BWR-3 to determine if this data can be used to improve the Pilgrim calculated to measured (C/M) bias or provide additional benchmarking information.
- The copper flux wires from the RFO 4 capsule pull were recently retested and results were similar to the original measurements. Entergy has also independently reviewed and validated the dosimetry counting methods used by the contracted vendor. They are considered to be accurate and correct.
- Research to confirm as-built vessel dimensions of the dosimetry location.
- Evaluate the removal of dosimetry from a surveillance capsule in the Pilgrim vessel during RFO 17 scheduled for the spring of 2009, if the C/M bias is not adequately resolved by the preceding actions. This dosimetry would then be used to obtain the full fluence history for use in developing new P-T curves.
- Consider contracting an independent vendor to model the vessel and perform a fluence calculation as a verification of the current results.

This letter meets the commitment made by Entergy in the two letters referenced above and will allow for successful resolution of the data benchmarking issue to support the development of new P-T curves for Pilgrim.