

September 17, 2007

Mr. Christopher M. Crane
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL
INFORMATION RELATED TO RELIEF REQUEST I3R-05 FOR POST-
TENSIONING SYSTEM INSPECTION SCHEDULE FOR SITES WITH TWO
PLANTS (TAC NOS. MD5467 AND MD5468)

Dear Mr. Crane:

By letter to the Nuclear Regulatory Commission (NRC) dated April 30, 2007, Exelon Generation Company, LLC submitted a request for relief associated with the third inservice inspection (ISI) interval and the second containment inservice inspection (CISI) interval, for the LaSalle County Station, Units 1 and 2.

The NRC staff is reviewing your submittal and has determined that additional information is required to complete the review. The specific information requested is addressed in the enclosure to this letter. During a discussion with your staff on September 10, 2007, it was agreed that you would provide a response within 30 days from the date of this letter.

The NRC staff considers that timely responses to requests for additional information help ensure sufficient time is available for staff review and contribute toward the NRC's goal of efficient and effective use of staff resources. If circumstances result in the need to revise the requested response date, please contact me at (301) 415-3154.

Sincerely,

/RA/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:
Request for Additional Information

cc w/encl: See next page

Mr. Christopher M. Crane
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

September 17, 2007

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION RELATED TO RELIEF REQUEST I3R-05 FOR POST-TENSIONING SYSTEM INSPECTION SCHEDULE FOR SITES WITH TWO PLANTS (TAC NOS. MD5467 AND MD5468)

Dear Mr. Crane:

By letter to the Nuclear Regulatory Commission (NRC) dated April 30, 2007, Exelon Generation Company, LLC submitted a request for relief associated with the third inservice inspection (ISI) interval and the second containment inservice inspection (CISI) interval, for the LaSalle County Station, Units 1 and 2.

The NRC staff is reviewing your submittal and has determined that additional information is required to complete the review. The specific information requested is addressed in the enclosure to this letter. During a discussion with your staff on September 10, 2007, it was agreed that you would provide a response within 30 days from the date of this letter.

The NRC staff considers that timely responses to requests for additional information help ensure sufficient time is available for staff review and contribute toward the NRC's goal of efficient and effective use of staff resources. If circumstances result in the need to revise the requested response date, please contact me at (301) 415-3154.

Sincerely,

/RA/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:
Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	LPL3-2 R/F	RidsNrrDorlLpl3-2
RidsNrrPMSSands	RidsNrrLAEWhitt	RidsAcraAcnwMailCenter
RidsOgcRp	RidsRgn3MailCenter	RidsNrrDorlDpr

ADAMS Accession Number: ML072550030 NRR-088

OFFICE	LPL3-2/PM	LPL3-2/LA	LPL3-2/BC
NAME	SSands	EWhitt	RGibbs
DATE	9/13/07	9/13/07	9/17/07

OFFICIAL RECORD COPY

LaSalle County Station, Units 1 and 2

cc:

Site Vice President - LaSalle County Station
via e-mail

Plant Manager - LaSalle County Station
via e-mail

Manager Regulatory Assurance - LaSalle
via e-mail

LaSalle Senior Resident Inspector
U.S. Nuclear Regulatory Commission
via e-mail

Phillip P. Steptoe, Esquire
Sidley and Austin
One First National Plaza
Chicago, IL 60603

Assistant Attorney General
100 W. Randolph St. Suite 12
Chicago, IL 60601

Chairman
LaSalle County Board
707 Etna Road
Ottawa, IL 61350

Attorney General
500 S. Second Street
Springfield, IL 62701

Chairman
Illinois Commerce Commission
527 E. Capitol Avenue, Leland Building
Springfield, IL 62706

Robert Cushing, Chief, Public Utilities Division
Illinois Attorney General's Office
100 W. Randolph Street
Chicago, IL 60601

Illinois Emergency Management Agency
Division of Disaster Assistance &
Preparedness
via e-mail

Document Control Desk - Licensing
via e-mail

Senior Vice President - Operations Support
via e-mail

Director - Licensing and Regulatory Affairs
via e-mail

Vice President - Regulatory Affairs
via e-mail

Associate General Counsel
via e-mail

Manager Licensing - Braidwood, Byron,
and LaSalle
via e-mail

Senior Vice President - Midwest Operations
via e-mail

REQUEST FOR ADDITIONAL INFORMATION

LASALLE COUNTY STATION, UNITS 1 AND 2

DOCKET NOS. 50-373 AND 50-374

In reviewing the Exelon Generation Company's (Exelon's) submittal dated April 30, 2007, related to Relief Request I3R-05, "Request for Relief for Post-Tensioning System Inspection Scheduling Requirements For Sites with Two Plants In Accordance with 10 CFR 50.55a(a)(3)(i) [Title 10 of the *Code of Federal Regulations* (10 CFR)]," for the LaSalle County Station (LSCS), Units 1 and 2, the NRC staff has determined that the following information is needed in order to complete its review:

In light of the fact that several LSCS, Unit 1 containment tendons were found severely degraded during an inservice inspection in 2003, please discuss your program for substantiating the structural integrity of one unit when severely degraded tendon conditions are found during tendon surveillance of the other unit, for surveillances scheduled based on IWL-2421(b) for sites with multiple plants. How was this finding addressed when the degraded conditions were identified for LSCS, Unit 1 tendons in 2003, that ensured an acceptable level of quality and safety of the post-tensioning systems of both units?