



RE: 0738-EQ

September 7, 2007

CERTIFIED MAIL 7006 0810 0004 5717 8590  
RETURN RECEIPT REQUESTED

Ms. Roshini Nambiar  
Enforcement and Compliance  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
P.O. Box 1677  
Oklahoma City, OK 73101-1677


Re: OPDES Permit OK0000191  
Sequoyah Fuels Corporation

Dear Ms. Nambiar:

The pH measured during a storm water event at Outfall 008 was slightly less than the permitted acceptable range of 6 to 9 on September 6, 2007. A value of 5.9 was measured near the end of the 24 hour event. The pH ranged from 5.9 to 6.5 during the event with the majority of the measurements being in the 6.3 to 6.4 range. Andy Potter of the Oklahoma Department Environmental Quality was notified by phone on September 6<sup>th</sup>. The source of this exceedance is contaminated water present in Pond 2. This is a continuation of a problem that has persisted for the past several months and was described in a letter to you dated June 14, 2007. Planned corrective actions were also described in that letter.

If you have any questions or require further information, you may contact Scott Munson, Environmental Manager, at 918/489-5511 (Extension 20).

Sincerely,



Craig L. Harlin, Director  
Regulatory Affairs

CLH:bt

Enclosures: As Stated Above

cc: Bob Evans, NRC Region IV  
Myron H. Fliegel, NRC Headquarters