

October 5, 2007

MEMORANDUM TO: AFB File

FROM: Alex R. Klein, Acting Chief **/RA/**
Fire Protection Branch
Division of Risk Assessment
Office of Nuclear Reactor Regulation

SUBJECT: CLOSE-OUT OF NATIONAL FIRE PROTECTION ASSOCIATION 805
FREQUENTLY ASKED QUESTION 06-0016 ON CLARIFYING
GUIDANCE FOR COUNTING ELECTRICAL PANELS AND CABINETS

Disposition of Frequently Asked Question (FAQ) 06-0016

FAQ 06-0016, Revision 0 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070030348) was proposed to clarify the guidance from NUREG/CR-6850 (EPRI 1011989), "EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities," on counting electrical cabinets and panels for NFPA (National Fire Protection Association) 805 transition applicants. The authors of NUREG/CR-6850, i.e., the Office of Nuclear Regulatory Research (RES) and its contractors and the Electric Power Research Institute (EPRI) were subsequently consulted to provide this clarification. They have provided their response via "RES & EPRI Team Response to FAQ 06-0016, NUREG/CR-6850 (EPRI TR-1011989)," dated February 2007. The U.S. Nuclear Regulatory Commission (NRC) endorses the response submitted by the RES & EPRI Team ADAMS Accession No. ML070580334. FAQ 06-0016, Revision 1 (ADAMS Accession No. ML071020174) was submitted to the NRC on March 22, 2007, and is consistent with the RES & EPRI Team Response (ADAMS Accession No. ML070580334). The NRC Staff accepted the proposed FAQ 06-0016, Revision 1, guidance for counting fire ignition frequencies for electrical panels and cabinets.

CONTACTS: Naeem Iqbal, NRR/DRA
(301) 415-3346

Ray Gallucci, NRR/DRA
(301) 415-1255

MEMORANDUM TO: AFPB File

FROM: Alex R. Klein, Acting Chief
Fire Protection Branch
Division of Risk Assessment
Office of Nuclear Reactor Regulation

SUBJECT: CLOSE-OUT OF NATIONAL FIRE PROTECTION ASSOCIATION 805
FREQUENTLY ASKED QUESTION 06-0016 ON CLARIFYING
GUIDANCE FOR COUNTING ELECTRICAL PANELS AND CABINETS

Disposition of Frequently Asked Question (FAQ) 06-0016

FAQ 06-0016, Revision 0 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070030348) was proposed to clarify the guidance from NUREG/CR-6850 (EPRI 1011989), "EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities," on counting electrical cabinets and panels for NFPA (National Fire Protection Association) 805 transition applicants. The authors of NUREG/CR-6850, i.e., the Office of Nuclear Regulatory Research (RES) and its contractors and the Electric Power Research Institute (EPRI) were subsequently consulted to provide this clarification. They have provided their response via "RES & EPRI Team Response to FAQ 06-0016, NUREG/CR-6850 (EPRI TR-1011989)," dated February 2007. The U.S. Nuclear Regulatory Commission (NRC) endorses the response submitted by the RES & EPRI Team ADAMS Accession No. ML070580334. FAQ 06-0016, Revision 1 (ADAMS Accession No. ML071020174) was submitted to the NRC on March 22, 2007, and is consistent with the RES & EPRI Team Response (ADAMS Accession No. ML070580334). The NRC Staff accepted the proposed FAQ 06-0016, Revision 1, guidance for counting fire ignition frequencies for electrical panels and cabinets.

DISTRIBUTION:

RGallucci NIqbal PLain JSHyslop MSalley CMoulton

ADAMS Accession No.: ML072700475

NRR-106

OFFICE	NRR/DRA/AFPB	NRR/DRA/AFPB	BC:RES/DFERR/FRB	BC:NRR/DRA/AFPB
NAME	NIqbal	RGallucci	MSalley	AKlein
DATE	10/ 01 /07	10/ 03 /07	10/ 04 /07	10/ 05 /07

OFFICIAL RECORD COPY