

## PLANT SYSTEMS

### 3/4.7.5 ULTIMATE HEAT SINK

#### LIMITING CONDITION FOR OPERATION

---

- 3.7.5 The ultimate heat sink shall be OPERABLE with:
- a. A minimum water level at or above elevation 674 feet mean sea level USGS datum, and
  - b. An average ERCW supply header water temperature of less than or equal to 87°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

With the requirements of the above specification not satisfied, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.7.5.1 The ultimate heat sink shall be determined OPERABLE at least once per 24 hours by verifying the average ERCW supply header temperature and water level to be within their limits.

## PLANT SYSTEMS

### 3/4.7.5 ULTIMATE HEAT SINK

#### LIMITING CONDITION FOR OPERATION

---

- 3.7.5 The ultimate heat sink shall be OPERABLE with:
- a. A minimum water level at or above elevation 674 feet mean sea level USGS datum, and
  - b. An average ERCW supply header water temperature of less than or equal to 87°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

With the requirements of the above specification not satisfied, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.7.5.1 The ultimate heat sink shall be determined OPERABLE at least once per 24 hours by verifying the average ERCW supply header temperature and water level to be within their limits.