

## **15.2 Increase in Reactor Pressure**

The information in this section of the reference ABWR DCD, including all subsections, tables, and figures, is incorporated by reference with the following departures and supplements.

STD DEP T1 2.3-1

STD DEP 8.3-1

### **15.2.1.3.1 Inadvertent Closure of One Turbine Control Valve**

The following site-specific supplement addresses the COL License Information Item in this section of the reference ABWR DCD.

The analysis for the initial core will be provided as an amendment to the FSAR in accordance with 10 CFR 50.71(e), at least one year prior to fuel load. This analysis will reflect the final fuel design for the initial core loading. (COM 15.2-1)

### **15.2.2.3.2.3 Generator Load Rejection with Failure of All Bypass Valves**

The following site-specific supplement addresses the COL License Information Item in this section of the reference ABWR DCD.

The analysis for the initial core will be provided as an amendment to the FSAR in accordance with 10 CFR 50.71(e), at least one year prior to fuel load. This analysis will reflect the final fuel design for the initial core loading. (COM 15.2-2)

### **15.2.4.1.1 Identification of Causes**

STD DEP T1 2.3-1

*Various steamline and nuclear system malfunctions, or operator actions, can initiate main steamline isolation valve (MSIV) closure. Examples are low steamline pressure, high steamline flow, ~~high steamline radiation~~, low water level or manual action.*

### **15.2.6.1.1 Identification of Causes**

STD DEP 8.3-1

*The non-emergency AC power to the station auxiliaries is provided by three unit auxiliary transformers. The unit auxiliary transformers are powered by the unit turbine/generator via a medium voltage generator breaker. ~~Each~~ Two of the unit auxiliary ~~transformer~~ transformers (UAT) ~~provides~~ provide power to ~~three~~ two electrical buses which provide power to the unit's auxiliary loads, including the reactor internal pumps (RIPs), as follows: UAT-A and UAT-B ~~each provides~~ provide power to a RIP MG set with 3 RIPs and both UATs have a separate bus providing powers power to 2 RIPs directly (i.e. no MG set); ~~UAT-B powers 2 RIPs directly (i.e., no MG), and UAT-C provides power to a RIP MG with 3 RIPs.~~ Following a generator trip and during plant startup, the medium voltage generator breaker is open but the high voltage*

*breaker at the switchyard remains closed to backfeed power from the normal preferred power grid to the unit auxiliary transformers.*

## **15.2.10 COL License Information**

### **15.2.10.1 Radiological Effects of MSIV Closures**

The following site-specific supplement addresses COL License Information Item 15.4.

The STP site-specific Exclusion Area Boundary (EAB) long-term routine release (annual average)  $\chi/Q$  is  $3.3\text{E-}06 \text{ sec/m}^3$ . This  $\chi/Q$  value conservatively assumes no decay. ABWR DCD Table 15.2-12 provides MSIV closure doses as a function of  $\chi/Q$ . The STP EAB doses associated with the inadvertent closure of MSIVs are provided below:

<b>Dispersion sec/m<sup>3</sup></b>	<b>Thyroid mGy</b>	<b>W Body mGy</b>	<b>Beta mGy</b>	<b>Skin mGy</b>
3.3E-06	9.9E-05	2.9E-03	4.4E-03	7.3E-03