

## **19B Resolution of Applicable Unresolved Safety Issues and Generic Safety Issues**

The information in this appendix of the reference ABWR DCD, including all subsections and tables, is incorporated by reference with the following supplement.

### **19B.3.1 COL Applicant Safety Issues**

The following standard supplement addresses COL License Information Item 19.28

All information in Appendix 19B that refers to COL Applicant is addressed in FSAR 1.9S.

### **19B.3.2 Testing of Isolators**

The following standard supplement addresses COL License Information Item 19.28a.

The inspection and test program for fiber optic-type isolators used between safety-related and non-safety-related systems and will be established prior to fuel loading. If other types of isolators are used (those subject to electrical leakage due to maximum credible electrical faults), the required testing, inspection and replacement guidance will be developed prior to fuel loading (COM 19B-1).

