



10 CFR 50.4  
10 CFR 50.54(q)

ZS-2010-0324

September 21, 2010

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Zion Nuclear Power Station, Units 1 and 2  
Facility Operating License Nos. DPR-39 and DPR-48  
NRC Docket Nos. 50-295 and 50-304

Subject: Changes to Emergency Plan

In accordance with the requirements of 10 CFR 50, Appendix E, "Emergency Planning and Preparedness for Production and Utilization Facilities," Zion Solutions, LLC is submitting Revision 13 to the Defueled Station Emergency Plan (DSEP) for Zion Nuclear Power Station.

These changes were evaluated under the requirements of 10 CFR 50.54(q) and were determined not to result in a decrease in the effectiveness of the DSEP. The revised DSEP was implemented on September 1, 2010, and is being submitted within 30 days of implementation as required by 10 CFR 50.54(q).

Attachment 1 provides Revision 13 of the Defueled Station Emergency Plan.

There are no commitments in this letter. If there are any questions regarding this letter, please contact me at (224) 789-4042.

Respectfully,

Tom R. Tramm  
Director, Regulatory Affairs & QA  
Zion Solutions, LLC

Enclosures:

- (1) Revision 13, "Zion Nuclear Power Station, Defueled Station Emergency Plan (DSEP)"

cc: Regional Administrator, Region III, US NRC

Attachment 1

“Defueled Station Emergency Plan (DSEP)”

Revision 13

**September 1, 2010**

Revision 13



Zion Station

**Defueled  
Station Emergency Plan  
(DSEP)**

# DEFUELED STATION EMERGENCY PLAN

## TABLE OF CONTENTS

TABLE OF CONTENTS .....	2
1.0 INTRODUCTION .....	5
1.1 FACILITY DESCRIPTION.....	5
2.0 DEFINITIONS AND ACRONYMS.....	6
3.0 PLAN SUMMARY .....	7
4.0 ORGANIZATIONAL CONTROL OF EMERGENCIES .....	9
4.1 ONSHIFT POSITIONS .....	11
4.1.1 SHIFT SUPERVISOR .....	11
4.1.2 EQUIPMENT OPERATORS .....	11
4.2 SUPPORT POSITIONS.....	11
4.2.1 RADIATION PROTECTION (RPTs) AND CHEMISTRY TECHNICIANS (CTs).....	11
4.2.2 SECURITY .....	11
4.3 AUGMENTED POSITIONS .....	11
4.3.1 EMERGENCY DIRECTOR (minimum staff).....	12
4.3.2 TECHNICAL DIRECTOR (minimum staff) .....	12
4.3.3 RADIATION PROTECTION DIRECTOR (minimum staff).....	12
4.4 CORPORATE RESPONSE .....	13
4.5 FUNCTIONAL RESPONSIBILITIES .....	13
4.6 STATE AND LOCAL GOVERNMENT RESPONSE.....	13
5.0 CLASSIFICATION OF EMERGENCIES .....	14
6.0 EMERGENCY MEASURES.....	29
6.1 NOTIFICATION AND ACTIVATION .....	29
6.1.1 NUCLEAR ACCIDENT REPORTING SYSTEM (NARS) .....	29
6.1.2 NRC EVENT NOTIFICATION SYSTEM (ENS) .....	29
6.2 ASSESSMENT ACTIONS.....	29
6.2.1 INITIAL ASSESSMENT.....	29
6.2.2 DOSE ASSESSMENT.....	30
6.3 CORRECTIVE ACTIONS .....	30
6.4 PROTECTIVE ACTIONS .....	30
6.4.1 ASSEMBLY/ACCOUNTABILITY .....	30
6.4.2 RADIOLOGICAL POSTED AREAS (RPAs).....	31
6.4.3 EXPOSURE CONTROL .....	32
6.4.4 PERSONNEL CONTAMINATION CONTROL.....	32

## DEFUELED STATION EMERGENCY PLAN

6.4.5 ACCESS CONTROL .....	32
6.4.6 PROTECTIVE EQUIPMENT AND SUPPLIES .....	32
6.4.7 MEDICAL TRANSPORT .....	32
7.0 EMERGENCY RESPONSE FACILITIES AND EQUIPMENT .....	33
7.1 FACILITIES .....	33
7.1.1 CONTROL ROOM .....	33
7.2.1 COMMUNICATIONS .....	33
7.3 ASSESSMENT RESOURCES .....	34
7.3.1 ONSITE METEOROLOGICAL MONITORING INSTRUMENTATION .....	34
7.3.1.1 INSTRUMENTATION .....	34
7.3.1.2 METEOROLOGICAL MEASUREMENT PROGRAM .....	34
7.3.2 RADIATION MONITORING .....	34
7.3.2.1 RADIATION MONITORING SYSTEM .....	34
7.3.2.2 RADIOLOGICAL NOBLE GAS EFFLUENT MONITORING .....	34
7.3.2.3 PARTICULATE EFFLUENT MONITORING .....	35
7.3.2.4 STATION SURVEY AND COUNTING EQUIPMENT .....	35
7.3.3 FIRE DETECTION .....	35
7.3.4 SITE HYDROLOGICAL .....	35
8.0 MAINTAINING EMERGENCY PREPAREDNESS .....	36
8.1 ORGANIZATION .....	36
8.1.1 DECOMMISSIONING PLANT MANAGER .....	36
8.1.2 OVERSIGHT .....	36
8.2 TRAINING .....	36
8.2.1 EMERGENCY PREPAREDNESS TRAINING (EPT) MATRIX .....	37
8.2.2 EMERGENCY RESPONSE ORGANIZATION TRAINING .....	37
8.2.2.2 NON-EXELON EMERGENCY RESPONSE SUPPORT .....	37
8.2.2.3 STATION EMERGENCY RESPONSE ORGANIZATION .....	38
8.3 DRILLS .....	38
8.3.1 PERFORMANCE DRILLS .....	38
8.3.2 EQUIPMENT AND PROFICIENCY DRILLS .....	38
8.3.2.1 COMMUNICATIONS DRILLS .....	38
8.3.2.2 HEALTH PHYSICS DRILLS .....	38
8.3.2.3 MEDICAL EMERGENCY DRILLS .....	38
8.3.2.4 ASSEMBLY AND ACCOUNTABILITY DRILLS .....	39
8.3.2.5 OFFSHIFT STATION AUGMENTATION DRILL .....	39

**DEFUELED STATION EMERGENCY PLAN**

8.4 CONTROLLED	DOCUMENTS .....	39
8.5	NUCLEAR STATION SECURITY PLAN AND DSEP.....	40

## DEFUELED STATION EMERGENCY PLAN

### 1.0 INTRODUCTION

This Defueled Station Emergency Plan (DSEP) describes Exelon's plan for responding to emergencies that may arise at Zion Station while in a permanently shutdown and defueled configuration. In this condition, no reactor operations can take place. All irradiated fuel is stored in a Spent Fuel Pool and the station is prohibited from moving the fuel from the Spent Fuel Pool to the reactor vessel. An analysis of the possible design basis events and consequences is presented in the evaluation of the Defueled Safety Analysis Report (DSAR) Accident Assessment.

The analysis of the potential radiological impact of an accident for Zion Station in a permanently defueled condition indicates that any releases beyond the Restricted Area Boundary (RAB) are limited to small fractions of the Environmental Protection Agency (EPA) Protective Action Guide (PAG) exposure levels, as detailed in EPA-400-R-92-001, "Manual of Protective Action Guides and Protective Actions for Nuclear Incidents." Exposure levels, which warrant pre-planned response measures, are limited to onsite areas. For this reason, radiological emergency planning is focused onsite.

In light of the substantially reduced risk and consequences of any potential incidents in a permanently shutdown and defueled condition, the overall purpose of the plan is to delineate the actions necessary to safeguard onsite personnel and minimize damage to property.

Emergency services are afforded by local public and private providers. Fire, rescue and ambulance services are provided by the City of Zion, Illinois. Medical services are provided by Vista Medical Center East in Waukegan, Illinois.

### 1.1 FACILITY DESCRIPTION

Both units are certified to have ceased power operations and are permanently defueled in accordance with 10CFR50.82(a)(1)(i) and (ii).

The Zion Station, Units 1 and 2, are sited on a tract of land of approximately 250 acres in the extreme eastern portion of the city of Zion, Lake County, Illinois, on the west shore of Lake Michigan. The site is approximately 6 miles NNE of the center of the city of Waukegan, Illinois and 8 miles south of the center of the city of Kenosha, Wisconsin. Lake Michigan and Zion City Water supply cooling water for the Station.

The plant consisted of two identical Pressurized Water Reactor (PWR) Nuclear Steam Supply Systems (NSSS) and turbine generators furnished by Westinghouse Electric Corporation, which contained Brown-Boveri low-pressure components. Each Nuclear Steam Supply System was designed for a power output of 3250 MWt.

All spent fuel from both units is stored in a Spent Fuel Pool (SFP). The SFP is a reinforced concrete structure with seam welded stainless steel plate liners. The borated SFP water is cooled via a closed loop cooling system and maintained in accordance with the Defueled Technical specification requirements. A complete description is provided in Section 3 of the Station DSAR.

For more specific site location information, refer to the Station DSAR.

## DEFUELED STATION EMERGENCY PLAN

### 2.0 DEFINITIONS AND ACRONYMS

#### ALERT \_\_\_\_\_

Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of the EPA PAG exposure levels.

#### ANNUAL \_\_\_\_\_

Frequency of occurrence equal to once per calendar year, January 1 to December 31.

#### ASSEMBLY/ACCOUNTABILITY \_\_\_\_\_

Discretionary protective action taken for all persons onsite that involves the gathering of personnel into pre-designated areas and the subsequent verification that the location of all personnel is known.

#### CLASSIFICATION \_\_\_\_\_

The process of observation of initiating conditions that relate to Emergency Action Levels (EALs) which determine severity.

#### DERO \_\_\_\_\_

Defueled Emergency Response Organization

#### DRILL \_\_\_\_\_

A supervised instruction period aimed at testing, developing and maintaining skills in a particular operation.

#### DSAR \_\_\_\_\_

Defueled Safety Analysis Report

#### DSEP \_\_\_\_\_

Defueled Station Emergency Plan

#### EMERGENCY ACTION LEVELS (EALs)

A pre-determined, observable threshold for a plant initiating condition that places the station in a given emergency class.

#### EM \_\_\_\_\_ EMERGENCY DIRECTOR

The designated position described in the DSEP that assumes Command and Control responsibilities.

#### INITIATING \_\_\_\_\_ CONDITION

A pre-determined condition where either an actual or potential radiological or other emergency exists.

#### M \_\_\_\_\_ MONTHLY

Frequency of occurrence equal to once per calendar month.

#### OFFSITE DOSE CALCULATION MANUAL (ODCM)

The ODCM presents a discussion of the following:

- The ways in which the station can affect the environment radiologically
- The regulations which limit radiological effluents; and
- The methodology used to assess radiological impact on the environment and compliance with regulations.



## DEFUELED STATION EMERGENCY PLAN

### PROTECTIVE ACTIONS

Emergency measures taken for the purpose of preventing or minimizing radiological exposure to onsite workers.

### QUARTERLY

Frequency of occurrence equal to once in each of the following four periods: January 1 through March 31; April 1 through June 30; July 1 through September 30; and October 1 through December 31.

### RELEASE

For reporting purposes, whenever an event has been classified and a release in progress exceeds the ODCM release rate limits.

### SHIFT SUPERVISOR

The senior on shift operations position at the station.

### SPENT FUEL NUCLEAR ISLAND

An area containing spent fuel storage and fuel handling systems, which are capable of functioning independent of other existing plant systems, structures and components to support wet spent fuel storage in the Fuel Handling Building.

### THRESHOLD VALUE

Measurable, observable detailed conditions that must be satisfied to determine an EAL applicability.

### UNMONITORED RELEASE

Any abnormal release that cannot be quantified within 15 minutes.

### UNUSUAL EVENT

Events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. No releases of radioactive material requiring off-site response or monitoring are expected unless further degradation of safety systems occurs.

## 3.0 PLAN SUMMARY

Sect ion 1 provides a description of the overall basis for and concept of Zion Station and offsite emergency response.

Sect ion 2 provides definitions and acronyms that may be used in emergency response.

Sect ion 3 provides a section by section summary of the Defueled Station Emergency Plan (DSEP).

Sect ion 4 describes the normal station organization, activation and transition to the station Defueled Emergency Response Organization (DERO).

Sect ion 5 describes the emergency classification process and provides the Initiating Conditions (ICs) and Emergency Action Levels (EALs). Recovery and termination conditions are described.

Sect ion 6 describes the emergency condition assessment actions, corrective actions, protective actions, and aid to affected personnel that would be used to mitigate the consequences of an incident. Also described is the notification of events and activation of the DERO.

**DEFUELED STATION EMERGENCY PLAN**

Sect       ion 7 describes the emergency response capabilities including facilities, communications, equipment and first aid medical provisions.

Sect       ion 8 describes provisions for maintaining the DSEP, implementing procedures, equipment, training, drills, and exercises used to ensure that the DERO maintain familiarity with the required responses to emergencies.

## DEFUELED STATION EMERGENCY PLAN

### 4.0 ORGANIZATIONAL CONTROL OF EMERGENCIES

The Defueled Emergency Response Organization (DERO) replaces the normal station organization to respond to declared emergencies when activated. Personnel are trained and assigned to the DERO based on either their normal job qualifications or by being specifically trained to fill a position.

The DERO is activated when an Alert is declared or at the discretion of the Shift Supervisor for an Unusual Event. The on shift staff is supplemented by station personnel who report to the Control Room Complex after being notified. The Shift Supervisor is responsible for ensuring that a callout is initiated to augment the on shift staff.

The goal of the DERO is to augment the Control Room staff within four hours at an Alert classification or at the discretion of the Emergency Director for an Unusual Event. The minimum augmented staff is a Radiation Protection Director and a Technical Director. An on call duty team will be the augmented staff.


The Shift Supervisor assumes the responsibilities of the Emergency Director. The Shift Supervisor position is required to be staffed at all times. Additional personnel available to the shift are governed by approved Technical Specifications.

Augmenting the DERO is accomplished by the assignment of specific personnel to assist the DERO as needed. Operations, maintenance, radiation protection and engineering personnel shall be briefed and dispatched to assigned tasks from the Control Room. Exelon Nuclear Corporate and Station resources can supply augmentation of the staff and long-term shift relief.

The Nuclear Duty Officer (NDO) is notified when any event occurs including classifications. Corporate support will be coordinated through the NDO or designee.

**DEFUELED STATION EMERGENCY PLAN**

**DEFUELED EMERGENCY RESPONSE ORGANIZATION**



## DEFUELED STATION EMERGENCY PLAN

### 4.1 ONSHIFT POSITIONS

The minimum on shift positions are governed by approved Technical Specifications.

#### 4.1.1 SHIFT SUPERVISOR

The Shift Supervisor is at the station 24 hours a day and is the senior management position at the station during off-hours. This position is responsible for monitoring conditions and approving all onsite activities. When an abnormal situation becomes apparent, the Shift Supervisor shall assume the position of Emergency Director with Command and Control once the emergency classification has been made.

#### 4.1.2 EQUIPMENT OPERATORS

Equipment Operators perform system and component manipulations. The organizational relationship to the Emergency Director is the same during normal and abnormal situations.

#### 4.1.3 RADIATION PROTECTION

Radiation Protection (RP) staff are available during normal day shift business hours. At all other times, Radiation Protection support is available on shift or through callout.

### 4.2 SUPPORT POSITIONS

#### 4.2.1 RADIATION PROTECTION (RPTs) AND CHEMISTRY TECHNICIANS (CTs)

Technicians perform radiological monitoring and surveys of plant areas and radioisotopic analysis of air and water samples. When an event is classified and the DSEP is implemented, the Technicians report to the Emergency Director to provide radiological and chemistry analysis support. Their responsibilities when implementing the DSEP include:

- Perform radiological monitoring and surveys as directed
- Ensure the habitability of the occupied areas of the plant
- Monitor personnel exposures
- Perform radioisotopic analysis as directed
- Provide radiological and first aid support to search and rescue and medical emergencies.
- Maintain a record of event activities and surveys performed

#### 4.2.2 SECURITY

Station Security is administered by the Security Plan. The Security force will report to the Emergency Director when implementing the DSEP.

### 4.3 AUGMENTED POSITIONS

The augmented staff shall be activated at an Alert classification. The augmented staff may be activated at the discretion of the Emergency Director for an Unusual Event.

## **DEFUELED STATION EMERGENCY PLAN**

### **4.3.1 EMERGENCY DIRECTOR (minimum staff)**

The Emergency Director shall assume overall Command and Control of a classified event. The Emergency Director cannot delegate the following responsibilities:

- Classification of event
- Authorize Corporate Nuclear Duty Officer (NDO), State and NRC notifications
- Authorization of radiation exposures in excess of 10CFR20 limits

Other responsibilities assumed by the Emergency Director include:

- Management of available station resources
- Initiate mitigative actions
- Initiate corrective actions
- Initiate onsite protective actions
- Decision to call for offsite police, fire or ambulance assistance
- Augment the emergency staff as deemed necessary
- Coordinate Security activities
- Implement recovery activities
- Terminate the emergency condition when appropriate
- Maintain a record of event activities

### **4.3.2 TECHNICAL DIRECTOR (minimum staff)**

The Technical Director reports to the Emergency Director. The responsibilities of the Technical Director when implementing the DSEP include:

- Evaluate technical data pertinent to plant conditions
- Augment the emergency staff as deemed necessary with maintenance, technical, engineering and communications personnel
- Assist with classification determination
- Recommend mitigative and corrective actions
- Direct search and rescue
- Direct maintenance and equipment restoration
- Maintain a record of event activities
- Establish and maintain communications as desired by the Emergency Director
- Record significant events on the significant event log.
- Maintain Status Boards as desired by the Emergency Director

### **4.3.3 RADIATION PROTECTION DIRECTOR (minimum staff)**

- Monitor personnel accumulated dose
- Advise the Emergency Director concerning Radiological EALs
- Augment the emergency staff as deemed necessary with RadChem personnel
- Establish and monitor Radiologically Controlled Areas (RCAs)
- On-Site Dose Assessment
- Maintain a record of event activities
- Establish and maintain communications as desired by the Emergency Director
- Maintain Status Boards as desired by the Emergency Director
- Record significant events on the significant event log.

## DEFUELED STATION EMERGENCY PLAN

### 4.4 CORPORATE RESPONSE

Corporate response may be activated at the discretion of the Nuclear Duty Officer (NDO) and may assume the following responsibilities:

- Interface with the State and local agencies
- 
- Environmental Monitoring
- Management of available corporate resources
- Media relations / public information
- Maintain a record of event activities
- Augment the staff at Zion Station if deemed necessary.

### 4.5 FUNCTIONAL RESPONSIBILITIES

Plant Operations are monitored and supervised from the Control Room under the direction of the Emergency Director.

Onsite Radiological Survey and Monitoring is performed by the Radiation Protection Technicians (RPTs) under the direction of the Radiation Protection Director.

First Aid treatment is available at all times and is provided by trained personnel (Emergency Director) assigned to the shift or by RPTs when on shift.

Decontamination is performed by RPTs under the direction of the Radiation Protection Director.

Security and Access Control are performed by the Security Force per the Security Plan.

Maintenance, Repair and Damage Control are provided by personnel from the plant staff under the direction of the Technical Director.

C ommunications are the responsibility of the Emergency Director, are maintained at the ERFs and consist of telephone and radio equipment.

Record keeping is maintained through logs kept in the Control Room by all responders designated in Sections 4.3 and 4.4.

### 4.6 STATE AND LOCAL GOVERNMENT RESPONSE

State and local government agency response will be in accordance with each agency's plans and procedures, and commensurate with the hazard posed by the emergency. Letters of Agreement are in place for those local agencies that will respond to the site, and for the hospital that will treat a contaminated injured individual from the site.

Arrangements are in place through Letters-of-Agreement for police, fire, hospital and ambulance response as requested by the station.

## DEFUELED STATION EMERGENCY PLAN

### 5.0 CLASSIFICATION OF EMERGENCIES

This Section describes the classification of emergencies into two levels. They are the Unusual Event and Alert. These classification levels are entered by meeting the criteria of Emergency Action Levels (EALs) provided in this section as a combination of Initiating Conditions (ICs) and Threshold Values used to determine if the conditions meet the EAL.

**Unusual \_\_\_\_\_ Event:** Events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. No releases of radioactive material requiring off-site response or monitoring are expected unless further degradation of safety systems occurs.

**Alert: \_\_\_\_\_** Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of the EPA PAG exposure levels.

The higher classifications required for operating nuclear power plants are exempted by the NRC for a permanently defueled facility once the determination is made that credible accident scenarios can no longer exceed the Protective Action Guidelines specified by the Environmental Protection Agency.

The Initiating Condition Matrix contains the ICs for the defueled plant. An emergency is classified by assessing plant conditions and comparing abnormal conditions to Initiating Conditions defined on the Initiating Condition Matrix.

The matrix is set up in three Recognition Categories. The first is designated as "R" and relates to Abnormal Radiological Conditions / Abnormal Radiological Effluent Releases. The second is designated as "M" and relates to System Malfunctions. The third is designated as "H" and relates to Hazards and Other Conditions. All Recognition Categories should be reviewed for applicability prior to classification.

The Initiating Conditions are coded with a two letter and one number code. The first letter is the Recognition Category designator, the second letter is the Classification Level and the number is a sequential number for that Recognition Category series. All Initiating Conditions that are describing the severity of a common condition (series) will have the same number.

The code is then used to reference a corresponding Threshold Value page(s) that provides additional information pertaining to the Initiating Condition;

- Threshold Value
- Basis
- Termination / Recovery Considerations.

Threshold Values are the measurable, observable detailed conditions that must be met in order to classify the event. Classification shall not be made without referencing, comparing and satisfying the Threshold Values. When the Threshold Value is met, the appropriate Emergency Action Level is to be classified. The Basis provides definitions of terms, explanations and justification for including the Initiating Condition and Threshold Values. Site specific definitions are provided for terms with the intent to be used for that particular Initiating Condition/Threshold Value and may not be applicable to other uses of that term in any other EAL, the DSEP or procedures. Also included are references to other documents that were used to develop the EAL. Termination/Recovery Considerations are to be used as a guide for determining when the Initiating Condition is no longer a threat.

When two or more Emergency Action Levels are determined, declaration will be made on the highest classification level for the plant.



## **DEFUELED STATION EMERGENCY PLAN**

A classification of Recovery is made when repairs are being made as required to return to an acceptable condition and parameters are stable or improving. Termination is declared when no EAL Threshold Values are exceeded and the DERO is no longer needed.

## DEFUELED STATION EMERGENCY PLAN

ALERT UNUSUAL	EVENT
<b>ABNORMAL RAD LEVELS / EFFLUENTS</b>	
<b>RA1 (p.17)</b> UNPLANNED release of gaseous or liquid radioactivity to the environment $\geq 200$ times the Technical Specification Release Limit for $\geq 15$ Minutes.	<b>RU1 (p.18)</b> UNPLANNED release of gaseous or liquid radioactivity to the environment $\geq 2$ times the Technical Specification Release Limit for $\geq 60$ Minutes.
<b>RA2 (p.19)</b> UNCONTROLLED increase in plant radiation levels that impedes operations.	<b>RU2 (p.20)</b> UNCONTROLLED increase in plant radiation levels.
<b>SYSTEM MALFUNCTIONS</b>	
	<b>MU1 (p.21)</b> Decrease in Spent Fuel Pool level OR temperature increase that is not the result of a planned evolution.
<b>HAZARDS AND OTHER CONDITIONS</b>	
<b>HA1 (p.22)</b> Confirmed Security Event in the Fuel Building.	<b>HU1 (p.23)</b> Confirmed security event with potential loss of level of safety of the plant.
<b>HA2 (p.24)</b> Other conditions judged warranting declaration of ALERT.	<b>HU2 (p.25)</b> Other conditions judged warranting declaration of an UNUSUAL EVENT.
	<b>HU3 (p.26)</b> Natural OR destructive phenomena inside the Restricted Area affecting the ability to maintain spent fuel integrity.

## DEFUELED STATION EMERGENCY PLAN

# RA1

### Initiating Condition -- ALERT

UNPLANNED release of gaseous or liquid radioactivity to the environment  $\geq 200$  times the Technical Specification Release Limit for  $\geq 15$  Minutes.

#### Emergency Action Levels Threshold Values: (1 or 2)

1. UNPLANNED VALID reading on any effluent monitor that is  $\geq 200$  times the Technical Specification Release Limit for  $\geq 15$  Minutes.
2. Confirmed sample analyses for gaseous or liquid releases indicates concentrations or release rates, for  $\geq 15$  minutes and  $\geq 200$  times (site –specific the Technical Specifications limits).

#### Basis:

An UNPLANNED release of this magnitude that cannot be terminated in 15 minutes represents an uncontrolled situation that is an actual or potential substantial degradation of the level of safety of the plant. The degradation in plant control implied by the fact that the release cannot be terminated in 15 minutes is the primary concern. The Emergency Director should not wait until 15 minutes has elapsed, but should declare an ALERT as soon as the release is determined to be uncontrolled or projected to be unisolable within 15 minutes.

The EAL 1 release rate limit ensures compliance with 10CFR20.1301 dose limits to the public. For noble gas release rates, 200 times the Technical Specification limit equals  $6.8\text{E}+05 \mu\text{Ci/sec}$ . For particulate release rates, 200 times the Technical Specification limit equals  $248 \mu\text{Ci/sec}$ . For liquid effluent release rates, 200 times the Technical Specification limit equals 2000 times the value specified in Table 2 of 10CFR20, Appendix B.

The EAL 2 grab samples are used to determine gaseous release rates or liquid concentrations to confirm monitor readings or when the effluent monitors are not in service.

### Termination / Recovery Considerations

The source of the release is determined and isolated (terminated).

## DEFUELED STATION EMERGENCY PLAN

RU1

### Initiating Condition -- UNUSUAL EVENT

UNPLANNED release of gaseous or liquid radioactivity to the environment  $\geq 2$  times the Technical Specification Release Limit for  $\geq 60$  Minutes.

#### Emergency Action Levels Threshold Values: (1 or 2)

1. UNPLANNED VALID reading on any effluent monitor that is  $\geq 2$  times the Technical Specification Release Limit for  $\geq 60$  Minutes.
2. Grab sample results indicate UNPLANNED gaseous release rates or liquid concentrations  $\geq 2$  times the Technical Specification Release Limit for  $\geq 60$  Minutes.

#### Basis:

An UNPLANNED release that cannot be terminated in 60 minutes represents an uncontrolled situation that is a potential degradation of the level of safety of the plant. The degradation in plant control implied by the fact that the release cannot be terminated in 60 minutes is the primary concern. The Emergency Director should not wait until 60 minutes has elapsed, but should declare an UNUSUAL EVENT as soon as the release is determined to be uncontrolled or projected to be unisolable within 60 minutes.

The EAL 1 limit ensures compliance with 10CFR20.1301 dose limits to the public. For noble gas release rates, two times the Technical Specification limit equals  $6.8\text{E}+03 \mu\text{Ci/sec}$ . For particulate release rates, two times the Technical Specification limit equals  $2.48 \mu\text{Ci/sec}$ . For liquid effluent release rates, two times the Technical Specification limit equals 20 times the value specified in Table 2 of 10CFR20, Appendix B.

The EAL 2 grab samples are used to determine gaseous release rates or liquid concentrations to confirm monitor readings or when the effluent monitors are not in service.

### Termination / Recovery Considerations

The source of the release is determined and isolated (terminated).

## DEFUELED STATION EMERGENCY PLAN

# RA2

### Initiating Condition -- ALERT

UNCONTROLLED increase in plant radiation levels that impede operations

#### Emergency Action Levels Threshold Value:

1. Area Radiation Monitor readings or survey results indicate an UNCONTROLLED increase in radiation level by 100 mR/hr that is not the result of a planned evolution and impedes access to areas needed to maintain control of radioactive material or operation of systems needed to maintain spent fuel integrity.
  - Auxiliary Building
  - Fuel Building
  - Radwaste Annex
  - Unit 1 and Unit 2 Containments(Site-specific) list

#### Basis:

An increase in radiation levels that is not the result of a planned evolution that impedes operations necessary to maintain control of radioactive material or allow maintenance of spent fuel integrity warrants the classification of an ALERT.

Damage to spent fuel represents a substantial degradation in the level of safety of the plant and therefore warrants an ALERT classification.

### Termination / Recovery Considerations

The source of the increased radiation is determined and levels have decreased below the threshold value.

**DEFUELED STATION EMERGENCY PLAN****RU2****Initiating Condition -- UNUSUAL EVENT**

UNCONTROLLED increase in plant radiation levels.

**Emergency Action Level Threshold Value:**

1. Area Radiation Monitor readings or survey results indicate an uncontrolled increase in radiation level by 25 mR/hr that is not the result of a planned evolution.

**Basis:**

UNCONTROLLED means an increase in < 12 hours of monitored radiation level that is not the result of a planned evolution and the source of the increase is not immediately recognized and controlled.

Classification of an UNUSUAL EVENT is warranted as a precursor to more serious events. The concern of this EAL is the loss of control of radioactive material representing a potential degradation of the level of safety of the plant.

**Termination / Recovery Considerations**

The source of the increased radiation level has been determined and levels have decreased to below the threshold value. Radiological controls have been implemented and are effective.

**DEFUELED STATION EMERGENCY PLAN****MU1****Initiating Condition -- UNUSUAL EVENT**

Decrease in Spent Fuel Pool Level OR temperature increase that is not the result of a planned evolution.

**Emergency Action Levels Threshold Values: (1 or 2)**

1.       a.     An uncontrolled water level decrease in spent fuel pool to < 611 feet with all irradiated fuel assemblies remaining covered by water.

**AND**

- b.     UNPLANNED VALID Fuel Building Area Radiation Monitor 0RT-AR21 or 0RT-AR22 reading increases to > 15 mR/hr
2.     Spent Fuel Pool temperature increase to > 125 °F that is not the result of a planned evolution.

**Basis:**

Classification of an Unusual Event for the EAL threshold value is warranted as a precursor to more serious events and a potential degradation in the level of safety of the plant. Since loss of level or continued pool boiling would result in increased radiation levels exceeding the criteria of RA2, continued system related loss of level type events are bounded by RA2.

**Termination / Recovery Considerations**

The cause of the loss of water inventory or cooling capability has been determined and actions to recover water level and/or temperature control are successful.

**DEFUELED STATION EMERGENCY PLAN****HA1****Initiating Condition -- ALERT**

Confirmed Security Event in the Fuel Building.

**Emergency Action Levels Threshold Values:**

1. INTRUSION into the Fuel Building by a HOSTILE FORCE.

**Basis:**

This class of security event represents an escalated threat to plant safety above that contained in the UNUSUAL EVENT. A confirmed INTRUSION report is satisfied if physical evidence indicates the presence of a HOSTILE FORCE within the Fuel Building.

**Termination / Recovery Considerations**

The threat to the level of safety of the plant no longer exists.



## DEFUELED STATION EMERGENCY PLAN

# HU1

### Initiating Condition -- UNUSUAL EVENT

Confirmed Security Event with potential loss of level of safety of the plant.

#### Emergency Action Levels Threshold Values: (1 or 2)

1. A credible threat to the station reported by the NRC.
2. A CONFIRMED threat that meets ALL of the following criteria:
  - A credible threat reported by any other outside agency or security procedures.
  - Is specifically directed toward the station
  - Is IMMINENT

#### Basis:

This EAL is based on Zion Station Site Security Plans. Security events, which do not represent a potential degradation in the level of safety of the plant, are reported under 10CFR73.71 or in some cases under 10CFR50.72.

INTRUSION into the Fuel Building by a HOSTILE FORCE would result in EAL escalation to an ALERT.

Consultation with security shift supervision is required because these individuals are the designated personnel on-site qualified and trained to confirm that a security event is occurring or has occurred. Training on security event classification confirmation is closely controlled due to the strict secrecy controls placed on the plant Security Plan.

Imminent – The threatened action or event will occur within 2 hours.

Confirmed – Determination that the threat or event is actual

A CONFIRMED security threat per the Safeguards Contingency Plan outside the Fuel Building is a potential degradation in the level of safety of the plant.

### Termination / Recovery Considerations

The threat to the level of safety of the plant no longer exists.

**DEFUELED STATION EMERGENCY PLAN****HA2****Initiating Condition -- ALERT**

Other conditions judged warranting declaration of ALERT.

**Emergency Action Levels Threshold Values:**

1. Other conditions exist which in the judgment of the Emergency Director indicate that plant systems may be substantially degraded and that increased monitoring of plant functions is warranted. Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

**Basis:**

A condition exists which, in the judgment of the Emergency Director, presents an actual or potential substantial degradation in the level of safety of the plant. Emergency Director judgment is to be based on known conditions and the expected response to mitigating activities.

**Termination / Recovery Considerations**

The threat to the level of safety of the plant no longer exists.

**DEFUELED STATION EMERGENCY PLAN****HU2****Initiating Condition -- UNUSUAL EVENT**

Other conditions judged warranting declaration of an UNUSUAL EVENT

**Emergency Action Levels Threshold Values:**

1. Other conditions exist which in the judgment of the Shift Supervisor / Emergency Director indicates a potential degradation in the level of safety of the plant.

**Basis:**

Any condition not explicitly detailed as an EAL threshold value, which, in the judgment of the Emergency Director, is a potential degradation in the level of safety of the plant. Emergency Director judgment is to be based on known conditions and the expected response to mitigating activities within a short time period.

**Termination / Recovery Considerations**

In the judgment of the Emergency Director, an UNUSUAL EVENT no longer exists and the hazard to the level of safety of the plant no longer exists.

## DEFUELED STATION EMERGENCY PLAN

# HU3

### Initiating Condition -- UNUSUAL EVENT

Natural or destructive phenomena inside the RESTRICTED AREA affecting the ability to maintain spent fuel integrity

#### Emergency Action Levels Threshold Values: (1 or 2 or 3 or 4 or 5 or 6 or 7)

1. CONFIRMED Seismic event felt by plant personnel.
2. Report by plant personnel of tornado or high winds greater than 80 mph striking within the RESTRICTED AREA that has the potential to affect equipment needed to maintain spent fuel integrity.
3. Vehicle crash into plant structures or systems within the RESTRICTED AREA boundary that has the potential to affect equipment needed to maintain spent fuel integrity.
4. Report by plant personnel of an unanticipated EXPLOSION within the RESTRICTED AREA boundary resulting in VISIBLE DAMAGE that has the potential to affect equipment needed to maintain spent fuel integrity.
5. Uncontrolled flooding in the Fuel Building that has the potential to affect equipment needed to maintain spent fuel integrity.
6. FIRE in the Fuel Building not extinguished within 15 minutes of Control Room notification or verification of a control room alarm that has the potential to affect equipment needed to maintain spent fuel integrity.
7. Toxic or flammable gas within the RESTRICTED AREA that has the potential to affect the operation of equipment needed to maintain spent fuel integrity.

#### Basis:

Unusual Events in this IC are categorized on the basis of the occurrence of an event of sufficient magnitude to be of concern to plant operators. Areas identified in the EALs define the location of the event based on the potential for damage to equipment contained therein.

EAL #1 should be CONFIRMED by a call to the National Earthquake Center. Damage may be caused to some portions of the site, but should not affect ability to operate spent fuel pool equipment. Method of detection can be based on validation by a reliable source or operator assessment. As defined in the EPRI-sponsored "Guidelines for Nuclear Plant Response to an Earthquake", dated October 1989, a "felt earthquake" is:

An earthquake of sufficient intensity such that: (a) the vibratory ground motion is felt at the nuclear plant site and recognized as an earthquake based on a consensus of control room operators on duty at the time.

## DEFUELED STATION EMERGENCY PLAN

EAL #2 is based on the assumption that a tornado striking (touching down) or high winds within the restricted area may have potentially damaged plant structures containing functions or systems required to maintain spent fuel integrity. The high wind value in EAL#2 is based on the FDSAR 100-year design basis value. “Sustained” means for more than 60 minutes.

EAL #3 is intended to address crashes of vehicles that cause significant damage to plant structures containing functions and systems necessary to maintain spent fuel integrity.

EAL #4 addresses only those EXPLOSIONs of sufficient force to damage equipment needed to maintain spent fuel integrity. No attempt is made in this EAL to assess the actual magnitude of the damage. The occurrence of the EXPLOSION with reports of evidence of damage is sufficient for declaration. The Emergency Director also needs to consider any security aspects of the EXPLOSION, if applicable.

EAL #5 addresses the effect of flooding caused by internal events such as component failures or equipment misalignment that has the potential to affect equipment needed to maintain spent fuel integrity. The site-specific areas include those areas that contain systems required to maintain fuel integrity that are not designed to be wetted or submerged.

EAL #6 addresses FIRES that may have the potential to affect the ability to maintain spent fuel integrity. As used here, *Detection* is visual observation and report by plant personnel or sensor alarm indication. The 15-minute time period begins within a credible notification that a FIRE is occurring, or indication of a VALID fire detection system alarm. Verification of a VALID fire detection system alarm includes actions that can be taken with the control room or within the Fuel Building to ensure that the alarm is not spurious. A verified alarm is assumed to be an indication of a FIRE unless it is disproved within the 15-minute period by personnel dispatched to the scene. In other words, a personnel report from the scene may be used to disprove a sensor alarm if received within 15 minutes of the alarm, but shall not be required to verify the alarm.

The intent of this 15-minute duration is to size the FIRE and to discriminate against small FIRES that are readily extinguished (e.g., smoldering waste paper basket). This excludes FIRES within administration buildings, wastebasket FIRES, and other small FIRES of no safety consequence.

EAL #7 addresses toxic or flammable gas in the restricted area that has the potential to affect the ability to maintain spent fuel integrity due to the potential damage to equipment or the evacuation of personnel preventing operation or maintenance of spent fuel pool equipment.

Escalation to the ALERT level will be via RA2 if any of the above events has caused damage that results in radiation levels increasing by 100 mR/hr and impedes operation of systems needed to maintain spent fuel integrity.

### Termination / Recovery Considerations

EAL #1 – No further hazard exists and a damage assessment, per EPRI NP-6695, Guidelines for Nuclear Plant Response to an Earthquake, is in progress.

EAL #2, #3, #4, #5 & #7 - No further hazard exists and a damage assessment is in progress.

EAL #6 – The fire is extinguished and the operational impact of the fire has been evaluated

## **DEFUELED STATION EMERGENCY PLAN**

THIS PAGE INTENTIONALLY LEFT BLANK

## **DEFUELED STATION EMERGENCY PLAN**

### **6.0 EM ERGENCY MEASURES**

Emergency measures begin with the recognition of abnormal conditions, identification of established Initiating Conditions and classification to a Defueled Emergency Action Level. Emergency measures also include notifications, mitigative actions, corrective actions and onsite protective actions for the station personnel.

#### **6.1 NOTIFICATION AND ACTIVATION**

The authority and responsibility for initially classifying and declaring emergencies, initiating notification to the NDO, State and NRC officials, and initiating corrective and mitigative actions resides with the Emergency Director Position which is assumed by the Shift Supervisor upon the declaration of an emergency.

The Shift Supervisor is the Emergency Director and assumes Command and Control upon classification of the event. Predetermined schedules are in place to determine the next qualified Emergency Director to relieve the Emergency Director. The Emergency Director being relieved shall announce that the Emergency Director coming on shift now has Command and Control and the DERO will report directly to this individual. Transfer of Command and Control shall be verbal and direct.

During normal working hours, the DERO is activated by a PA announcement. Off-hours staffing will be performed by a callout initiated by the Emergency Director. The State will be notified by the Nuclear Accident Reporting System (NARS) notification network.

##### **6.1.1 NUCLEAR ACCIDENT REPORTING SYSTEM (NARS)**

The NARS is a dedicated phone system using a two number code to connect the corporate organization and the Illinois Emergency Management Agency (IEMA). It contains information that identifies the station, classification, meteorological data and Emergency Action Level (EAL). In the event of failure of the NARS network, commercial telephone lines would be used to make notifications to IEMA.

Wisconsin Emergency Management is notified using commercial lines after notification is made to IEMA.

Illinois State agencies will be notified within 30 minutes of event classification or change of classification. Local agency notifications are made by the State.

##### **6.1.2 NRC EVENT NOTIFICATION SYSTEM (ENS)**

The ENS is a dedicated telephone system used to notify the NRC Operations Center. The NRC will be notified immediately after State notifications and within 1 hour of event classification or change in classification. In the event of failure of the ENS, commercial phone lines would be used to notify the NRC.

### **6.2 ASSESSMENT ACTIONS**

#### **6.2.1 INITIAL ASSESSMENT**

Classification of events is performed by the Shift Supervisor in accordance with EALs provided in Section 5.0. Once the classification has been made the Shift Supervisor becomes the Emergency Director until the next qualified Emergency Director assumes the responsibilities of Command and Control.

## DEFUELED STATION EMERGENCY PLAN

### 6.2.2 DOSE ASSESSMENT

Dose Assessments are performed by the Control Room and supplemented by the augmented DERO. Dose assessment by the Control Room is required for accident classification purposes. The basis for the classifications of Unusual Event (RU1) and Alert (RA1) was established in Design Basis Accident dose calculation and Technical Specification dose rate limits. Based on this fixed methodology, the Control Room requires only an assessment of the station release rate. Guidance for determining release rate is procedurally provided. Classification levels for RU1 and RA1 are directly provided in Section 5. The augmented DERO provides full on-site dose assessment capability.

### 6.3 CORRECTIVE ACTIONS

Station Normal and Abnormal Operating Procedures and Emergency Plan Implementing Procedures provide preventive and/or corrective actions that mitigate the consequences of fuel damage events. Instrumentation, control systems and radiation monitoring systems provide indications of the safe and orderly operations. These systems provide the operator with the information needed to monitor the Spent Fuel Pool and supporting systems. They further provide the means to monitor and cope with an emergency condition should one occur. System indications and controls are in the Control Room at locations convenient to the Operations staff. These instruments provide the basis for event classification and initiation of onsite protective actions.

In the event of a fire, the Zion Fire Department is called.

### 6.4 PROTECTIVE ACTIONS

Protective actions for onsite personnel are provided for their health and safety. Implementation guidelines for onsite protective actions is provided in Emergency Plan Implementing Procedures (EPIPs).

#### 6.4.1 ASSEMBLY/ACCOUNTABILITY

Assembly and accountability should be considered and used as a protective action whenever a site wide risk to health or safety exists and prudence dictates. When the site wide risk is a Security Threat, consult with security to determine if assembly is prudent.

Assembly is accomplished by sounding the Assembly siren.

- On-duty shift personnel (operators, RP technicians, etc.) not otherwise directed by the Emergency Director are to report to the Control Room.
- The DERO (Emergency Director, RP Director, Technical Director) are to report to the Control Room.

#### NOTE

In order to minimize distractions to emergency response actions, access to the control room during an Unusual Event or Alert condition is limited to those personnel requiring event response-related access or are specifically assigned to the Control Room for emergency related duties.

- All other onsite personnel are to report to the Building 4 (ENC Building) or Nuclear General Employee Training (NGET) Building assembly areas.
- Contaminated or potentially contaminated personnel shall report to the Decontamination Room.
- Accountability of all personnel onsite should be accomplished within 60 minutes after an Assembly is announced.



## DEFUELED STATION EMERGENCY PLAN

Security personnel will perform accountability. The security area exit card readers can be used to accomplish accountability from plant areas. The Emergency Director shall maintain accountability for all onsite personnel throughout the event.

### 6.4.2 RADIOLOGICALLY CONTROLLED AREAS ( RCAs)

RPTs or the Radiation Protection Director may establish Radiologically Controlled Areas (RCAs) in response to the event. The RP Director shall control access to all RCAs unless immediate access is authorized by the Emergency Director to facilitate emergency repairs.

## DEFUELED STATION EMERGENCY PLAN

### 6.4.3 EXPOSURE CONTROL

Individuals authorized to enter RCAs are required to have in their possession dosimetry capable of measuring a dose received from external sources of ionizing radiation. RPTs may be assigned to Emergency Inplant Teams to provide radiological controls and to monitor team exposure if deemed necessary by the RP Director.

### 6.4.4 PERSONNEL CONTAMINATION CONTROL

All personnel are monitored for radioactive contamination prior to leaving the site. Portable radiation survey meters are available to frisk personnel for suspected contamination. RPTs trained in decontamination procedures, if necessary, will perform decontamination. Documentation of surveys, contamination and decontamination efforts shall be maintained.

### 6.4.5 ACCESS CONTROL

Normal access control shall be maintained unless otherwise directed. The Emergency Director will control access to the station when the DERO is activated.

### 6.4.6 PROTECTIVE EQUIPMENT AND SUPPLIES

Protective clothing and respiratory equipment is maintained at the entry to the RPA for use by Emergency Inplant Teams as directed by the RP Director.

### 6.4.7 MEDICAL TRANSPORT

Injured or radioactively contaminated injured personnel requiring medical assistance are transported through agreement with the Zion Rescue Department to Vista Medical Center East in Waukegan. Ambulance service is available at all times. Personnel qualified in radiation protection practices are directed to report to the hospital or accompany the injured and contaminated patient(s). Communication to the hospital is made with commercial telephones. The ambulance crews are trained to address contaminated injured cases. The hospital is equipped for contaminated injuries and the staff is trained for these contingencies. Contaminated wounds are treated and decontaminated by the hospital staff.

## DEFUELED STATION EMERGENCY PLAN

### 7.0 EMERGENCY RESPONSE FACILITIES AND EQUIPMENT

#### 7.1 FACILITIES

##### 7.1.1 C CONTROL ROOM

The Control Room is where plant systems and equipment parameters are monitored continuously. The Control Room is the initial onsite center for emergency Command and Control. Control Room personnel assess plant conditions, evaluate the magnitude and potential consequences of abnormal conditions, initiate preventative, mitigating and corrective actions and perform notifications. When activated, the DERO reports to the Control Room. The Shift Supervisor shall assume the position of Emergency Director with Command and Control once the decision to classify the event has been made.

### 7.2 COMMUNICATIONS CAPABILITIES

Dedicated communications systems at Zion Station allow effective coordination of any emergency response.

#### 7.2.1 C COMMUNICATIONS

Following an event classification, the Shift Supervisor or a designee makes initial notifications in accordance with Sections 6.1.1 and 6.1.2.

Reliable intraplant and plant-to-offsite communications include:

- A public address system
- A commercial telephone system
- Portable Radios
- NARS

## **DEFUELED STATION EMERGENCY PLAN**

### **7.3 ASSESSMENT      RESOURCES**

#### **7.3.1      ONSITE METEOROLOGICAL MONITORING INSTRUMENTATION**

Meteorological monitoring capabilities are described in the DSAR.

##### **7.3.1.1 INSTRUMENTATION**

The meteorological tower conforms to the recommendations of Regulatory Guide 1.23 and ANSI/ANS 2.5 (1984). The equipment is placed on booms oriented into the generally prevailing wind at the site. Equipment signals are brought to an instrument building with controlled environmental conditions. The building at the base of the tower houses the recording equipment, signal conditioners, etc., used to process and re-transmit the data to the end point users.

##### **7.3.1.2 METEOROLOGICAL MEASUREMENT PROGRAM**

Cooperation between the corporate office and the meteorological contractor assures that a timely restoration of any outage can be made. Emergency field visits to the site are made as quickly as possible.

The meteorological consultant provides a 24-hour a day, seven days per week data source consisting of all routinely available National Weather Service Information. This allows for the detailed preparation of forecasts for the duration of an emergency.

### **7.3.2 RADIATION      MONITORING**

The Zion DSAR describes the radiation monitoring system (RMS) in detail.

#### **7.3.2.1 RADIATION MONITORING SYSTEM**

The installed Radiation Monitoring System (RMS) is designed to continuously monitor Fuel Building activity and station liquid effluents. The system includes Control Room readouts and recorders for selected parameters that are monitored and an audible or visual Control Room alarm when predetermined setpoints are exceeded. The system can be subdivided into process instrumentation and an area monitoring system.

The process instrumentation consists of pumps, filter samplers, detectors, and associated electronics to determine noble gas, and particulate concentrations in air or liquid effluents. Liquid effluent pathways have control functions that will terminate a release at a predetermined setpoint. These setpoints are premised on compliance with federal regulations.

The area monitoring system provides information on existing radiation levels in the Fuel Building to ensure safe occupancy and to provide early indication of changing radiological conditions. It is equipped with Control Room and local readout and audible alarms to warn personnel of an increased radiation level.

#### **7.3.2.2 RADIOLOGICAL NOBLE GAS EFFLUENT MONITORING**

The ventilation exhaust from Zion Station Auxiliary Building is reduced to two effluent streams. Each stream provides a readily available sampling pathway for effluent quantification.

The method of converting instrument readings to release rates are determined using EIPs. Actual releases are quantified by collecting grab samples, counting the samples, and calculating the releases.

## DEFUELED STATION EMERGENCY PLAN

### 7.3.2.3 PARTICULATE EFFLUENT MONITORING

The ventilation exhaust from the Auxiliary Building stack effluent pathways are continuously sampled for effluent quantification.

The method of converting instrument readings to release rates are determined using EIPs. Actual releases are quantified by collecting grab samples, counting the samples, and calculating the releases.

### 7.3.2.4 STATION SURVEY AND COUNTING EQUIPMENT

Zion Station maintains portable survey instrumentation to assess contamination levels, exposure rates, and airborne gaseous and particulate concentrations. This equipment includes GMs, ion chambers and air samplers.

The Zion Station counting room contains Germanium gamma spectrometer systems, gas-flow proportional counters for alpha and beta/gamma analysis, and liquid scintillators for tritium analysis.

The Station uses various combinations of TLDs, and electronic dosimeters to monitor personnel exposures. In addition, a whole body counting system for bioassay determinations is available at other nuclear facilities to quantify internal exposure.

### 7.3.3 FIRE DETECTION

Onsite Fire Detection Instrumentation capabilities are described in the Zion Fire Protection Report.

### 7.3.4 SITE HYDROLOGICAL

Site Hydrological Characteristics of the Zion Station are described in the Zion Station DSAR.

## **DEFUELED STATION EMERGENCY PLAN**

### **8.0 MAINTAINING EMERGENCY PREPAREDNESS**

#### **8.1 ORGANIZATION**

The Decommissioning Plant Manager is responsible for staffing the station Defueled Emergency Response Organization (DERO) and approval of the Emergency Plan Implementing Procedures (EPIPs). The ZionSolutions (ZS) Vice President, Environmental, Safety, and Health (ES&H) shall assign a staff member as the Emergency Preparedness Coordinator (EPC). The EPC shall be responsible for maintaining the ability to implement the DSEP through the EPIPs and appropriate training of station personnel.

The Defueled Station Emergency Plan (DSEP) shall be maintained by the ES&H organization under the ZS Vice President, ES&H. Changes to the DSEP shall be controlled as delineated in Section 8.4.

##### **8.1.1 DECOMMISSIONING PLANT MANAGER**

The Decommissioning Plant Manager has the following additional responsibilities:

- Ensure the operational readiness of station communication systems for use during an emergency, by verification during drills (as described in this Section);
- Ensure the operational readiness of station emergency equipment and supplies;
- Ensure that Station EPIPs and lesson plans are prepared and are reviewed every two years.

##### **8.1.2 OVER SIGHT**

To meet the requirements of 10CFR50.54 (t), the ZS Vice President, ES&H shall provide for a review of the Emergency Preparedness Program by persons who have no direct responsibility for implementation of the program. Actions shall be taken for evaluation and correction of all review findings.

#### **8.2 TRAINING**

The proficiency of emergency response personnel (as defined in 10CFR50 Appendix E) is ensured by the following means:

- Assigning persons to emergency duties that are similar to those performed as a part of their regular work assignment.
- Initial training and annual retraining on the DSEP and corresponding implementing procedures. Individuals not demonstrating the required level of knowledge in initial or retraining classes receive additional training on the areas requiring improvement. Annual retraining is to be conducted on a calendar year basis.
- Training on DSEP changes shall be completed within thirty (30) days of implementation of the change.
- Participation in drills designed to sharpen those skills which they are expected to use in the event of an emergency.

## DEFUELED STATION EMERGENCY PLAN

### 8.2.1 EM ERGENCY PREPAREDNESS TRAINING (EPT) MATRIX

The training program for emergency response personnel is developed based on the requirements of 10CFR50 Appendix E and position specific responsibilities as defined in this document. Emergency response personnel in the following categories receive initial training and retraining each year:

Shift Supervisors, Emergency Directors, Technical Directors and Radiation Protection Directors shall have training conducted such that proficiency is maintained on the topics listed below. These subjects shall be covered as a minimum on an annual basis.

- Emergency Action Level Classification
- On-Site Dose Assessment
- Nuclear Accident Reporting System (NARS) Form completion and use of the NARS system
- Federal, state and local notification procedures as appropriate.
- Site specific procedures for activating the onsite DERO.

Emergency response personnel, in the following categories perform emergency response activities as an extension of their normal duties and are trained annually as part of their duty specific training. Additional Emergency Preparedness information is provided as part of the Nuclear Station General Employee Training.

Equipment Operators and Maintenance personnel are trained to function as Emergency Inplant Teams.

Radiation Protection and Chemistry personnel are trained to assess the radiological hazards associated with equipment repair and instruct personnel as to the appropriate protective clothing requirements, respiratory protection requirements, time limits, and other protective actions specific to the conditions present.

Medical Support Personnel. Offsite ambulance and hospital personnel are offered annual training in accordance with a program provided by Corporate Emergency Preparedness.

Security Personnel. Station security personnel are trained in accordance with training defined by the Station Security Program.

### 8.2.2 EMERGENCY RESPONSE ORGANIZATION TRAINING

The EPC has the responsibility for ensuring that the Emergency Response Organization receives all necessary training and retraining.

#### 8.2.2.2 NON-EXELON EMERGENCY RESPONSE SUPPORT

The Decommissioning Plant Manager shall make an annual written offer to train those non-Exelon organizations which may provide specialized services during a nuclear plant emergency (e.g., local law enforcement, fire-fighting, medical services, transport of injured, etc.). The training made available by Exelon or State of Illinois personnel shall acquaint the participants with the special problems potentially encountered during an emergency, notification procedures and their expected roles. Those organizations that must enter the site shall also receive site specific emergency response training. They shall also be instructed as to the identity (by position and title) of those persons in the onsite organization who will control their support activities.

## **DEFUELED STATION EMERGENCY PLAN**

### **8.2.2.3 STATION EMERGENCY RESPONSE ORGANIZATION**

Station management shall ensure the attendance of onsite personnel for training. Using approved lesson plans, the Station shall conduct onsite emergency personnel initial and retraining for the Emergency Response Organization.

### **8.3 DR ILLS**

#### **8.3.1 PERFORM ANCE DRILLS**

The EPC shall ensure that Federally prescribed exercises are conducted biennially in order to test the adequacy of the implementing procedures and methods; test emergency equipment and communication networks; and to ensure that emergency personnel are familiar with their duties. For alternate years, a drill will be conducted meeting the same requirements. Both the exercise and drill will include activation of the DERO in conjunction with the Control Room.

An offer to participate in the exercise or drill shall be made to the State agencies. A written scenario shall be prepared. The scenario shall include:

- Objectives
- Dates, time period, facilities activated and participating organizations
- Simulated event descriptions
- Timeline containing a schedule of real and simulated events
- Narrative Summary describing how the drill will be presented including expected actions
- List of qualified participants

A critique shall be conducted as soon as practical after each drill. The critique shall evaluate the ability of the organization to respond to a simulated emergency situation.

### **8.3.2 EQUIPMENT AND PROFICIENCY DRILLS**

#### **8.3.2.1 C OMMUNICATIONS DRILLS**

Monthly - The capability of the Nuclear Accident Reporting System (NARS) and ENS shall be demonstrated.

Annually - The emergency communications systems shall be fully tested.

#### **8.3.2.2 HEALTH PHYSICS DRILLS**

Health Physics Drills shall be conducted annually. These drills shall include response to, and analysis of, simulated radioactive airborne and liquid samples within the plant.

#### **8.3.2.3 MEDICAL EMERGENCY DRILLS**

A medical emergency drill, involving a simulated contaminated individual, and containing provisions for participation by local support services organizations (i.e., ambulance and support hospital) shall be conducted annually. The medical drill may be performed as part of the required annual Performance Drill.



## **DEFUELED STATION EMERGENCY PLAN**

### **8.3.2.4 ASSEMBLY AND ACCOUNTABILITY DRILLS**

An assembly and accountability drill shall be conducted annually. The drill shall include identifying the locations of all individuals onsite. Successful demonstration of assembly and accountability as a part of the annual Performance Drill shall serve as the successful completion of this drill requirement in that calendar year.

### **8.3.2.5 OFFSHIFT STATION AUGMENTATION DRILL**

An unannounced offshift notification drill shall be conducted semi-annually. These drills shall involve implementation of the notification procedure and documentation of the times at which persons are notified. No actual travel is required. Participants provide an estimation of their travel time to the station. This drill shall serve to demonstrate the capability to augment the onshift staff in a short period after declaration of an emergency.

### **8.4 CONTROLLED DOCUMENTS**

To ensure that the DSEP and the corresponding EIPs and lesson plans are maintained current, the EPC shall ensure the following:

- DSEP and EIPs shall be distributed on a controlled basis to all positions and locations requiring them and all appropriate NRC offices;
- The DSEP will be reviewed on an annual basis. The DSEP shall be updated as needed. The most current approved revisions shall remain in effect until revised so long as it is certified as current. In those years when the review does not warrant a revision, a letter to that affect will be issued.
- Proposed revisions to the DSEP and Implementing Procedures shall be reviewed and approved per Station program administration EIP. Documentation regarding this review and approval shall be maintained by Document Control.
- The Decommissioning Plant Manager shall approve the DSEP for use.
- All locations of a controlled document shall receive approved changes. Revised pages of these documents shall be dated with effective change date and marked to show where changes have been made. Where the extent of the changes is broad enough to warrant a summary of changes, the summary is included with the document's distribution; the new pages shall be added and the old pages shall be deleted;
- Emergency Plan Implementing Procedures and corresponding lesson plans shall be developed consistent with the DSEP within 1 month of any DSEP revision and reviewed every two years. The Decommissioning Plant Manager shall ensure that this review is conducted for EIPs;
- Names and phone numbers of the emergency response organization and support personnel shall be reviewed and updated at least quarterly;
- Whenever exercises or drills indicate deficiencies in the DSEP or corresponding EIPs, such documents shall be revised as necessary to ensure corrective action,
- Letters of Agreement or contracts for services.

## DEFUELED STATION EMERGENCY PLAN

### 8.5 NUCLEAR STATION SECURITY PLAN AND DSEP

The station shall have a Security Plan that complies with the requirements of 10CFR73.

The interface between the DSEP and the Station Security Plan is one of parallel operation. The plans are compatible. The DSEP emergency response measures, once initiated, are executed in parallel with measures taken in accordance with the Station Security Plan.

The Station Security Plan, Appendix C, Contingency Events, identifies situations that could be initiating conditions for emergency response measures. The Station Security Plan provides guidance for decisions and actions to be taken for each security contingency event. As guidance, the Security Plan allows for differing responses depending upon the assessment of the actual situation within each contingency event classification.

The assessment of any security contingency event and the decision to initiate, or not to initiate the DSEP, will be the responsibility of the Emergency Director.