

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

830 Power Building

OCT 18 1978

Cent Files

438/439

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - PURCHASE REQUESTS WITHOUT IEEE  
QUALIFICATIONS SPECIFIED - NCR BNP-7 - THIRD INTERIM REPORT

The subject condition was initially reported to NRC-OIE Inspector  
L. E. Foster on November 25, 1977. Interim reports were submitted on  
December 15, 1977, and June 30, 1978. Enclosed is our third interim  
report. We expect to submit our next written report by March 8, 1979.

If you have any questions regarding this matter, please get in touch  
with M. R. Wisenburg at FTS 854-2581.

Very truly yours,

*J. E. Gilleland*  
for J. E. Gilleland  
Assistant Manager of Power

Enclosure

cc: Mr. John G. Davis, Acting Director (Enclosure)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

*notified TVA 11/20/78 re missing acc # 15*  
*76*

781103257

*Mr 2*  
*26*

ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2  
PURCHASE REQUESTS ISSUED WITHOUT  
IEEE QUALIFICATIONS SPECIFIED  
NCR BNP-7

THIRD INTERIM REPORT

Interim Progress

Affected procurement requests for process flow equipment have been revised and sent to the respective vendors for assurance that the equipment does meet IEEE Class IE standards. TVA is continuing its investigation into the qualification of HVAC equipment that has been affected by this nonconformance. TVA will propose a corrective action upon receipt of this information.

781103