



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2860

AUG 30 1974

Wisconsin Public Service Corporation  
ATTN: Mr. E. W. James, Senior Vice President  
Power Generation and Engineering  
P. O. Box 1200  
Green Bay, Wisconsin 54305

Docket No. 50-305

Gentlemen:

REFERENCE RO BULLETIN NO. 74-9  
DEFICIENCY IN GENERAL ELECTRIC MODEL 4KV  
MAGNE-BLAST BREAKERS

A partial omission was made in the referencing details of the subject breakers at the bottom of page No. 1 of the above bulletin. The information should read as follows:

Manufacturer: General Electric Company  
Type: AMH - 4.76 - 250 - OD or  
AMD - 4.76 - 250 - 1D Breakers with Stationary Auxiliary Switch  
Assemblies in MC - 4.76 Horizontal Drawout Metal Clad Switchgear.

Please make this addition to your Bulletin No. 74-9 forwarded to you on August 9, 1974.

Sincerely,

James G. Keppler  
Regional Director

bcc: RO Files  
DR Central Files  
Local PDR  
PDR

cb