

PMComanchePeakPEm Resource

From: Otto, Ngola
Sent: Thursday, August 04, 2011 11:39 AM
To: Woodlan, Don
Cc: Monarque, Stephen; Conly, John; ComanchePeakCOL Resource; Evans, Todd; Bird, Bobby
Subject: RE: 2011-08-02 Woodlan, Comanche Peak Chapter 8 - Draft ACRS Presentation
Attachments: NRC Staff CPNPP Chapter 8 COL ACRS Presentation .pptx

Don,

Attached is our current draft presentation for chapter 8.

Thank you

Ngola Otto
Project Manager, US-APWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors
(301) 415-6695

From: Woodlan, Don [<mailto:Donald.Woodlan@luminant.com>]
Sent: Tuesday, August 02, 2011 12:33 PM
To: Otto, Ngola
Cc: Monarque, Stephen; Conly, John; ComanchePeakCOL Resource; Evans, Todd; Bird, Bobby; nicholas.kellenberger@mnes-us.com; 'tapia_joseph@mnes-us.com'; russell.bywater@mnes-us.com
Subject: 2011-08-02 Woodlan, Comanche Peak Chapter 8 - Draft ACRS Presentation

Ngola,

Attached is our draft presentation for ACRS. Todd Evans has the lead to develop the slides and will be making the presentation for us.

Please let us know if you see any conflicts or unnecessary overlap with your presentation. We plan to submit our final slides to ACRS one week before the briefing.

Donald R. Woodlan

Manager, Nuclear Regulatory Affairs

Luminant Power

O- 254-897-6887 C- 214-542-7761

Confidentiality Notice: This email message, including any attachments, contains or may contain confidential information intended only for the addressee. If you are not an intended recipient of this message, be advised that any reading, dissemination, forwarding, printing, copying or other use of this message or its attachments is strictly prohibited. If you have received this message in error, please notify the sender immediately by reply message and delete this email message and any attachments from your system.

Hearing Identifier: ComanchePeak_COL_Public
Email Number: 1452

Mail Envelope Properties (6566BAEC3DB1314381965386524904EC3F48A5D30F)

Subject: RE: 2011-08-02 Woodlan, Comanche Peak Chapter 8 - Draft ACRS Presentation
Sent Date: 8/4/2011 11:38:56 AM
Received Date: 8/4/2011 11:38:58 AM
From: Otto, Ngola

Created By: Ngola.Otto@nrc.gov

Recipients:

"Monarque, Stephen" <Stephen.Monarque@nrc.gov>
Tracking Status: None
"Conly, John" <John.Conly@luminant.com>
Tracking Status: None
"ComanchePeakCOL Resource" <ComanchePeakCOL.Resource@nrc.gov>
Tracking Status: None
"Evans, Todd" <Eric.Evans@luminant.com>
Tracking Status: None
"Bird, Bobby" <Robert.Bird@luminant.com>
Tracking Status: None
"Woodlan, Don" <Donald.Woodlan@luminant.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1603	8/4/2011 11:38:58 AM
NRC Staff CPNPP Chapter 8 COL ACRS Presentation .pptx		114133

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:



Presentation to the ACRS Subcommittee

**Comanche Peak Nuclear Power Plant, Units 3 and 4
COL Application Review**

Safety Evaluation Report

CHAPTER 8: ELECTRIC POWER

August 17, 2011

Staff's Presentation Order



- **Stephen Monarque** - Comanche Peak COLA Lead Project Manager
- **Ngola Otto** - Project Manager
- **Tania Martinez Navedo**- Technical Staff Presenter

Overview of COLA Review

SRP Section/Application Section		No. of Questions	Number of OI
8.1	Introduction	2	1
8.2	Offsite Power System	30	1
8.3.1	Onsite Power System	1	0
8.3.2	DC Power System	0	0
8.4	Station Blackout	3	0
Totals		36	2

Section 8.1 Electric Power

Introduction



- ***Open Item No. 08.01-1 (RAI 2576, Question 08.01-2)***
 - ♦ COL Information Item No. 8.2(3) – switchyard description
 - ♦ Issue:
 - GDC 5 is applicable to Comanche Peak because its switchyard is shared between 2 units.
 - COL applicant was requested to address how it meets GDC 5, in terms of the capacity of the transmission lines and switchyard components to support loads in the event of an accident in one unit and safe shutdown of the adjacent unit.
- Subsequently, the applicant committed to provide a demonstration of compliance with GDC 5.

Section 8.2

Offsite Power System



- ***Open Item No. 08.02-1 (RAI 5116, Question 08.02-30)***
 - ♦ COL Information Item No. 8.2(11) – Offsite power stability studies
 - ♦ Issue:
 - The Comanche Peak FSAR language is not consistent with the DCD language with respect to the 3-second time delay after a turbine trip to maintain adequate voltage to the Reactor Coolant Pumps in the following area:
 - The DCD states that the main generator breaker is opened by the turbine trip signal after a time delay of 15-seconds
 - The Comanche Peak FSAR states that the main generator breaker is opened by a reverse power relay after a time delay of 15-seconds
- Subsequently, the NRC staff has requested the DCD applicant to clarify the language in the DCD to eliminate the inconsistency between the two documents.

Acronyms



- COL – combined license
- COLA – combined license application
- DBA – design basis accident
- FSAR – Final Safety Analysis Report
- GDC – General Design Criteria
- IBR – incorporated by reference
- SER – Safety Evaluation Report
- RAI – request for additional information
- RCOL – reference combined license