

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

(TEMPORARY FORM)

CONTROL NO: 5783

FILE: 410

FROM: Iowa Electric Light & Power Co. Cedar Rapids, Iowa G. G. Hunt			DATE OF DOC 6-19-74	DATE REC'D 6-25-74	LTR X	TWX	RPT	OTHER
TO: James G. Keppler			ORIG 1	CC	OTHER	SENT AEC PDR XXX SENT LOCAL PDR XXX		
CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D	DOCKET NO:			
	XXX			1	50-331			

DESCRIPTION:

Ltr adv that abnormal occurrence of 6-14-74
should be disregarded as info was incorrect....

ENCLOSURES:

ACKNOWLEDGED
DO NOT REMOVE

PLANT NAME: DUANE ARNOLD

FOR ACTION/INFORMATION 6-26-74 GMC

✓ BUTLER (L)	SCHWENCER (L)	ZIEMANN (L)	REGAN (E)
W/ 7CYS	W/ CYS	W/ CYS	W/ CYS
CLARK (L)	STOLZ (L)	DICKER (E)	
W/ CYS	W/ CYS	W/ CYS	W/ CYS
W/ CYS	VASSALLO (L)	KNIGHTON (E)	W/ CYS
W/ CYS	W/ CYS	W/ CYS	W/ CYS
KNIEL (L)	PURPLE (L)	YOUNGBLOOD (E)	
W/ CYS	W/ CYS	W/ CYS	W/ CYS

INTERNAL DISTRIBUTION

✓ REG FILE	✓ TECH REVIEW	DENTON	LIC ASST	A/T IND
✓ AEC PDR	✓ HENDRIE	GRIMES	DIGGS (L)	BRAITMAN
✓ OGC	✓ SCHROEDER	GAMMILL	GEARIN (L)	SALTZMAN
✓ MUNTZING/STAFF	✓ MACCARY	KASTNER	GOULBOURNE (L)	B. HURT
✓ CASE	✓ KNIGHT	BALLARD	KREUTZER (E)	
GIAMBUSO	✓ PAWLICKI	SPANGLER	LEE (L)	PLANS
BOYD	✓ SHAO		✓ MAIGRET (L)	MCDONALD
✓ MOORE (L)(LWR-2)	✓ STELLO	ENVIRO	REED (E)	CHAPMAN
✓ DEYOUNG (L)(LWR-1)	✓ HOUSTON	MULLER	SERVICE (L)	DUBE w/input
SKOVHOLT (L)	✓ NOVAK	DICKER	SHEPPARD (L)	E. COUPE
GOLLER (L)	✓ ROSS	KNIGHTON	SLATER (E)	
P. COLLINS	✓ IPPOLITO	YOUNGBLOOD	SMITH (L)	✓ D. THOMPSON (2)
DENISE	✓ TEDESCO	REGAN	TEETS (L)	✓ KLECKER
✓ REG OPR	✓ LONG	PROJECT MGR	WILLIAMS (E)	✓ EISENHUT
✓ FILE & REGION (3)	✓ LAINAS		WILSON (L)	
✓ MORRIS	✓ BENAROYA	HARLESS		
✓ STEELE	✓ VOLLMER			

EXTERNAL DISTRIBUTION

✓ 1 - LOCAL PDR CEDAR RAPIDS, IOWA	(1)(2)(10)-NATIONAL LABS	1-PDR-SAN/LA/NY
✓ 1 - TIC (ABERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-BROOKHAVEN NAT LAB
✓ 1 - NSIC (BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	1-G. ULRIKSON, ORNL
1 - ASLB	1-B&M SWINEBROAD, Rm E-201 GT	1-AGMED (RUTH GUSSMAN)
1 - P. R. DAVIS	1-CONSULTANTS	Rm B-127 GT
✓ 16 - AGRS HOLDING	NEWARK/BLUME/AGBABIAN	1-RD..MUELLER, Rm F-309
Sento Lic Asst Maigret 6-26-74		GT

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA

DUANE ARNOLD ENERGY CENTER

PALO, IOWA

JUNE 19, 1974

DAEC - 74 - 228

Mr. James G. Keppler
Regional Director
Directorate of Regulatory Operations
U. S. Atomic Energy Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

SUBJECT: Abnormal Occurrence reported to USAEC
Region III on June 15, 1974.
FILE: A-118a


Dear Mr. Keppler:

On June 15, 1974, your office was notified by telephone and telegram that an Abnormal Occurrence took place at the Duane Arnold Energy Center on June 14, 1974. We reported that the occurrence (DPR 49/74-12) involved the discovery of incorrectly installed pins in pressure sensing line snubbers in HPCI and RCIC High Flow Isolation instrumentation.

The purpose of this letter is to advise you that an investigation of the occurrence has determined that the pins were correctly installed in the pressure sensing line snubbers and that our earlier report of an Abnormal Occurrence should be disregarded. The earlier report was based on information provided by the supplier of the snubbers, and after contacting the manufacturer, it was determined that the information was incorrect.

We apologize for any inconvenience caused by this matter.

Yours very truly,




G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

DLW/GGH/bh

CC: John O'Leary D. L. Wilson
C. W. Sandford H. W. Rehrauer-Chairman-Safety Committee
J. A. Wallace L. D. Root
E. L. Hammond J. R. Newman
B. R. York B. L. Hopkins

REGULATORY DOCKET FILE COPY



5783
5783