



C-C

(0.4)  
(1.0)

▽ DESIGN WATER TABLE  
 ▽ WATER TABLE (24 HR)  
 MH SOIL CLASSIFICATION  
 13 BLOW COUNT  
 ▨ POTENTIALLY LIQUEFIABLE SOIL  
 (SEE NOTE)  
 -WS WEATHERED SHALE

NOTE:  
I. LIQUEFACTION BASED ON TOP OF  
GROUND ACCELERATION OF 0.4g  
AND SEED-IDRISS (1971)  
CORRELATION FOR SANDS.

**Added by Amendment 50**

**WATTS BAR NUCLEAR PLANT  
FINAL SAFETY  
ANALYSIS REPORT**

---

**ERCW PIPELINE  
SECTION C-C  
FIGURE 2.5-573**