

7/20/2011
76 FR 43356

(2)

NRCREP Resource

From: Paul Reichert [paul.reichert@verizon.net]
Sent: Friday, August 05, 2011 3:11 PM
To: NRCREP Resource
Subject: Response from "Comment on NRC Documents"

RECEIVED

11:03 PM 5:25

FILES
DIRECTIVES

Below is the result of your feedback form. It was submitted by

Paul Reichert (paul.reichert@verizon.net) on Friday, August 05, 2011 at 15:11:26

Document Title: DRAFT REGULATORY GUIDE DG-1270, "EVALUATIONS OF EXPLOSIONS POSTULATED TO OCCUR AT NEARBY FACILITIES AND ON TRANSPORTATION ROUTES NEAR NUCLEAR POWER PLANTS"

Comments: The following document should be considered for applicability and use in this regulatory guide revision.

NUREG/CR-2462 (SAND-83-1250), "Capacity of Nuclear Power Plant Structures to Resist Blast Loadings", Kennedy, R.P. ; Blejwas, T.E. ; Bennett, D.E.

The existing 1 psi criteria may, on many occasions, be excessively conservative for nuclear plant structures.

Added guidance may also be useful on protection of other components such as safety related HVAC system building openings.

organization:

address1: 4811 Warrington Ave.

address2:

city: Philadelphia

state: PA

zip: 19143

country: United States

phone: 267-847-6166

SUNSI Review Complete
Template = ADM-013

E-RDS = ADM-03
Add = m. Mysic
(mmb1)
m. Cuel(mjc)