

50-331

## NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: MR K R GOLLER

FROM: IOWA ELECTRIC LIGHT & POWER  
COMPANY.....CEDAR RAPIDS,  
IOWA.....LEELIU

DATE OF DOCUMENT

8-17-76

DATE RECEIVED

8-23-76

☒ LETTER  
☒ ORIGINAL  
☐ COPY☐ NOTORIZED  
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 SIGNED

## DESCRIPTION

LTR TRANS THE FOLLOWING.....

PLANT NAME: DWANE ARNOLD

## ENCLOSURE

REFUELING INFORMATION REQUEST FOR THEIR  
1977 REFUELING OUTAGE.....DO NOT REMOVE  
ACKNOWLEDGE

## SAFETY

## FOR ACTION/INFORMATION

## ENVIRO

8-27-76 RB

ASSIGNED AD:  
✓ BRANCH CHIEF: (6) G. LEAR  
PROJECT MANAGER:  
✓ LIC. ASST.: (17) K. PARRISH

ASSIGNED AD:  
BRANCH CHIEF:  
PROJECT MANAGER:  
LIC. ASST.:

## INTERNAL DISTRIBUTION

REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
✓ NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
✓ I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
✓ OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACCARRY	KIRKWOOD	ERNST
CASE	KNIGHT		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	CAMMILL
BOYD	ROSS	✓ EISENHUT	STEPP
P. COLLINS	NOVAK	✓ SHAO	HULMAN
HOUSTON	ROSZTOCZY	✓ BAER	
PETERSON	CHECK	✓ BUTLER	SITE ANALYSIS
MELTZ		✓ GRIMES	VOLLNER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		✓ J. COLLINS
	RUTBERG		KREGER

## EXTERNAL DISTRIBUTION

✓ LPDR: Cedar Rapids, Ia.  
✓ TIC:  
✓ NSIC:  
ASLB:  
ACRS/6 CYS HOLDING/SENT

NAT LAB:	BROOKHAVEN NAT LAB
REG. VIE	ULRIKSON (ORNL)
LA PDR	
CONSULTANTS	

CONTROL NUMBER

8623

# IOWA ELECTRIC LIGHT AND POWER COMPANY



General Office  
CEDAR RAPIDS, IOWA

August 17, 1976  
IE-76-1238

LEE LIU  
VICE PRESIDENT - ENGINEERING

Regulatory Docket File

50-331



Mr. Karl R. Goller  
Assistant Director for Operating Reactors  
Division of Operating Reactors  
US Nuclear Regulatory Commission  
Washington, D.C. 20545

Dear Mr. Goller:

Enclosed herewith is a Refueling Information Request for our 1977 refueling outage.

Your letter of June 18, 1975 requested that we incorporate this information into our annual operating report. As this would require about a one year lead time which would not result in an accurate forecast, we will continue to forward this information as a separate report.

Very truly yours,

A handwritten signature in dark ink, appearing to be 'Lee Liu'.

Lee Liu  
Vice President, Engineering

LL/KAM/ms

Enc.

cc: K. Meyer  
D. Arnold  
L. Root  
J. Newman  
File J-60a

8623

### REFUELING INFORMATION REQUEST

1. Name of facility - Duane Arnold Energy Center
2. Scheduled date for next refueling shutdown - March 15, 1977
3. Scheduled date for restart following refueling - April 15, 1977
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? - Yes

If answer is yes, what, in general, will these be? - Appropriate MCPR and MAPLHGR limits as derived from safety analyses. MCPR's will be exposure dependent.

5. Scheduled dates for submitting proposed licensing action and supporting information - January 15, 1977.
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures -
  - a) The reload will consist of 100 8x8 bundles with drilled tie plates.