

WBN2Public Resource

From: Boyd, Desiree L [dlboyd@tva.gov]
Sent: Friday, August 05, 2011 12:24 PM
To: Epperson, Dan; Poole, Justin; Raghavan, Rags; Milano, Patrick; Campbell, Stephen
Cc: Crouch, William D; Hamill, Carol L; Boyd, Desiree L
Subject: TVA letter to NRC_08-05-2011_FSAR Ch 15.5 Dose Response
Attachments: 08-05-2011_FSAR Ch 15.5 Dose Response_Final.pdf

Please see attached TVA letter that was sent to the NRC today.

Thank You,

~*~*~*~*~*~*~*~*~*~

Desiree L. Boyd

**WBN 2 Licensing Support
Sun Technical Services**

dlboyd@tva.gov

423-365-8764

Hearing Identifier: Watts_Bar_2_Operating_LA_Public
Email Number: 465

Mail Envelope Properties (7AB41F650F76BD44B5BCAB7C0CCABFAF219CAC36)

Subject: TVA letter to NRC_08-05-2011_FSAR Ch 15.5 Dose Response
Sent Date: 8/5/2011 12:23:42 PM
Received Date: 8/5/2011 12:24:26 PM
From: Boyd, Desiree L

Created By: dlboyd@tva.gov

Recipients:

"Crouch, William D" <wdcrouch@tva.gov>
Tracking Status: None
"Hamill, Carol L" <clhamill@tva.gov>
Tracking Status: None
"Boyd, Desiree L" <dlboyd@tva.gov>
Tracking Status: None
"Epperson, Dan" <Dan.Epperson@nrc.gov>
Tracking Status: None
"Poole, Justin" <Justin.Poole@nrc.gov>
Tracking Status: None
"Raghavan, Rags" <Rags.Raghavan@nrc.gov>
Tracking Status: None
"Milano, Patrick" <Patrick.Milano@nrc.gov>
Tracking Status: None
"Campbell, Stephen" <Stephen.Campbell@nrc.gov>
Tracking Status: None

Post Office: TVANUCXVS2.main.tva.gov

Files	Size	Date & Time
MESSAGE	312	8/5/2011 12:24:26 PM
08-05-2011_FSAR Ch 15.5 Dose Response_Final.pdf		301659

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

August 05, 2011

10 CFR 50.34(b)
10 CFR 100

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Watts Bar Nuclear Plant, Unit 2
NRC Docket No. 50-391

Subject: Watts Bar Nuclear Plant (WBN) Unit 2 – Final Safety Analysis Report (FSAR) – Chapter 15.5 Design Basis Accident Dose Analysis

References: 1. TVA letter to NRC dated June 27, 2011 "Watts Bar Nuclear Plant (WBN) Unit 2 – Final Safety Analysis Report (FSAR) – Response to Request for Additional Information (RAI) Regarding Accident Dose Analysis Basis"

This letter provides revised FSAR Design Basis Accident (DBA) dose analysis results. The submittal of these analyses was a TVA commitment to NRC described in Reference 1.

Enclosure 1 provides updated FSAR tables for each of the DBAs discussed in FSAR Section 15.5 with the exception of the Fuel Handling Accident. The updated tables will be included in a future FSAR Amendment. The results reflect the use of the most recent meteorology data for the 20 year period of 1991 to 2010 as opposed to the 1976 to 1993 data used for licensing Unit 1. The use of the more recent meteorological data resulted in minor changes to the results but no regulatory dose limits were exceeded and margins to the limits were virtually unchanged. A change in the main control room isolation time from 20.6 seconds to 40 seconds was included in the analyses. A revised Fuel Handling Accident will be provided in a separate correspondence by August 31, 2011. A list of new commitments is provided in Enclosure 2.

U.S. Nuclear Regulatory Commission
Page 2
August 05, 2011

I declare under penalty of perjury that the foregoing is true and correct. Executed on the 5th day of August, 2011.

Respectfully,

A handwritten signature in black ink, appearing to read 'David Stinson', with a stylized flourish at the end.

David Stinson
Watts Bar Unit 2 Vice President

Enclosures:

1. WBN Unit 2 Revised FSAR Section 15.5 Accident Dose Analysis Results Tables
2. Regulatory Commitments

cc (Enclosures):

U. S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, Georgia 30303-1257

NRC Resident Inspector Unit 2
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

U.S. Nuclear Regulatory Commission
Page 3
August 05, 2011

bcc (Enclosures):

Stephen Campbell
U.S. Nuclear Regulatory Commission
MS 08H4A
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

Charles Casto, Deputy Regional Administrator for Construction
U. S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, Georgia 30303-1257

Enclosure 1

WBN Unit 2 Revised FSAR Section 15.5 Accident Dose Analysis Results Tables

The following revised FSAR Chapter 15.5 DBA Tables are provided in this enclosure:

Table 15.5.2	Doses from Loss of A/C Power
Table 15.5-5	Doses from Gas Decay Tank Rupture
Table 15.5-9	Doses from Loss-of-Coolant Accident
Table 15.5-13	Doses From Recirculation Loop Leakage Following A LOCA
Table 15.5-14	Atmospheric Dilution Factors At The Control Building
Table 15.5-17	Doses From Main Steam Line Break
Table 15.5-18	Parameters Used In Steam Generator Tube Rupture Analysis
Table 15.5-19	Doses From Steam Generator Tube Rupture
Table 15A-2	Accident Atmospheric Dilution Factors (sec/m ³)

Table 15.5-2 Doses From Loss Of A/C Power

Conservative Analysis (rem)	2HR EAB	30 DAY LPZ	CONTROL ROOM	
Gamma	7.45E-04	4.18E-04	2.12E-04	
Beta	4.48E-04	2.52E-04	2.55E-03	
Thyroid - ICRP-30	4.57E-02	2.57E-02	2.11E-02	
Realistic Analysis (rem)	2HR EAB	30 DAY LPZ	CONTROL ROOM	
Gamma	1.80E-08	1.01E-08	5.11E-09	
Beta	1.66E-05	9.29E-06	1.81E-04	
Thyroid - ICRP-30	1.10E-06	6.18E-07	5.09E-07	

Table 15.5-5 Doses From Gas Decay Tank Rupture

Regulatory Guide 1.24 Analysis (rem)	2HR EAB	30 DAY LPZ	CONTROL ROOM	
Gamma	5.96E-01	1.67E-01	8.43E-01	
Beta	1.61E+00	4.51E-01	7.28E+00	
Thyroid - ICRP-30	1.29E-02	3.60E-03	6.99E-03	
Realistic Analysis (rem)	2HR EAB	30 DAY LPZ	CONTROL ROOM	
Gamma	2.88E-02	8.05E-03	3.81E-02	
Beta	1.10E-01	3.08E-02	5.01E-01	
Thyroid - ICRP-30	1.21E-02	3.37E-03	6.50E-03	

Table 15.5-9 DOSES FROM LOSS-OF-COOLANT ACCIDENT

(rem)	2Hr EAB	30 Day LPZ	Control Room	
Gamma	2.12	2.18	1.05	
Beta	1.25	2.61	9.10	
Thyroid - ICRP - 30	40.4	14.33	3.75	

Breakdown of Control Room Personnel Dose

(rem)	Airborne	Shine	Ingress/Egress	Total	
Gamma	1.02	0.005	0.027	1.05	
Beta	9.04	0.000	0.060	9.10	
Thyroid - ICRP - 30	3.66	0.000	0.090	3.75	

Table 15.5-13 Doses From Recirculation Loop Leakage Following A LOCA

(rem)	2HR EAB	30 Day LPZ	Control Room
Gamma	4.14E-03	2.28E-02	1.51E-03
Beta	1.36E-03	8.54E-02	1.62E-02
Thyroid - ICRP - 30	1.40E-03	1.53E-01	3.69E-02

Table 15.5-14 Atmospheric Dilution Factors At The Control Building

DILUTION FACTOR (sec/m³)				
Time Period (hr)	LOCA/FHA	SGTR/MSLB	LOSS OF A/C POWER	WGDT
0-2	1.09E-03	3.85E-03	2.61E-03	2.56E-03
2-8	9.44E-04	3.22E-03	2.15E-03	1.17E-03
8-24	1.56E-04	N/A	N/A	7.26E-04
24-96	1.16E-04	N/A	N/A	5.21E-04
96-720	9.59E-05	N/A	N/A	4.30E-04

GENERAL CONTROL ROOM PARAMETERS

Volume	257,198 cu ft
Makeup/pressurization flow	711 cfm
Recirculation flow	2889 cfm
Unfiltered intake	51 cfm
Filter efficiency	95% first pass
	70% second pass
	0% for noble gases, Tritium
Isolation time, T	40 seconds
Occupancy factors:	
0-24 hr	100%
1-4 days	60%
4-30 days	40%

Table 15.5-17 Doses From Main Steam Line Break

1 gpm Primary-to-Secondary Leakage (ARCON-96 x/Q)	Control Room Operator (rem)	SRP Guidance for GDC 19 Limits (rem)	30-Day LPZ (rem)	2-Hour EAB (Site boundary (rem)	SRP Guidance for 10CFR100 Limits (rem)
Accident Initiated Iodine Spike Case (0.265 $\mu\text{Ci/gm}$ steady state)					
Gamma:	8.10E-03	5	1.25E-01	1.04E-01	2.5
Beta:	6.52E-02	30	3.02E-02	2.54E-02	30
Inhalation (ICRP-30):	10.4E+00	30	4.78E+00	3.09E+00	30
Pre-Accident Iodine Spike Case (14 $\mu\text{Ci/gm}$ max peak)					
Gamma:	4.36E-03	5	1.11E-02	2.74E-02	25
Beta:	4.00E-02	30	4.20E-03	8.80E-03	300
Inhalation (ICRP-30):	7.44E+00	30	1.21E+00	2.41E+00	300

Table 15.5-18 Parameters Used In Steam Generator Tube Rupture Analysis

Primary Side Activity	Technical Specification Limit
Secondary Side Activity	ANSI/ANS-18.1-1984 (Expected levels, 150 gpd/SG)
Iodine Spiking Factor	Case 1: Accident initiated spike of 500 times equilibrium iodine concentration Case 2: Pre-accident spike of 14 $\mu\text{Ci/gm}$ I-131 dose equivalent
Iodine Partition Factor	100
Secondary Side Mass Release (Ruptured Steam Generator)	
0 - 2 hours	103,300 lbm
2 - 8 hours	32,800 lbm
Secondary Side Mass Release (Intact Steam Generator)	
0 - 2 hours	492,100 lbm
2 - 8 hours	900,200 lbm
Primary Coolant Mass Release (Total)	
0 - 2 hours	191,400 lbm
Primary Coolant Mass Release (Flashed)	
0 - 2 hours	10,077.2 lbm
Atmospheric diffusion coefficients for control room	2.61×10^{-3} - (0 - 2 hrs)
Operator doses	2.15×10^{-3} - (2 - 8 hrs)

Table 15.5-19 Doses From Steam Generator Tube Rupture

Pre-Accident Initiated Spike Case (14 µCi/gm maximum peak)			
(rem)	2 HR EAB	30 DAY LPZ	CONTROL ROOM
Gamma	3.78E-01	1.11E-01	6.28E-02
Beta	2.26E-01	6.92E-02	7.07E-01
Thyroid - ICRP-30	1.39E+01	3.79E+00	1.24E+01
Accident Initiated Iodine Spike Case (0.265 µCi/gm steady state)			
(rem)	2 HR EAB	30 DAY LPZ	CONTROL ROOM
Gamma	5.46E-01	1.60E-01	5.76E-02
Beta	2.51E-01	7.73E-02	6.70E-01
Thyroid - ICRP-30	7.19E+00	2.12E+00	2.03E+00

Table 15A-2 Accident Atmospheric Dilution Factors (sec/m³)

Conservative And Regulatory Guide Analyses		
Time Period (hours)	Exclusion Area Boundary*	Low Population Zone (4828 meters)
0-2	6.382E-04	1.784E-04
2-8		8.835E-05
8-24		6.217E-05
24-96		2.900E-05
96-720		9.811E-06

* The dilution factors were calculated for a travel distance of 1100 meters, the distance from the 100 meter radius release zone to the 1200 meter radius exclusion boundary (See Section 2.3.4).

Enclosure 2

Regulatory Commitments

1. Submit the revised FSAR Section 15.5 Tables in a future amendment of the FSAR.
2. Submit a letter with a revised Fuel Handling Accident by 08/31/2011